

POSCHIAVO-ROBBIA, Switzerland

WMO: 067940

Lat: 46.3472N

Lon: 10.0631E

Elev: 1079

StdP: 89.01

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-10.8	-9.1	-21.8	0.6	-3.2	-19.1	0.8	-3.3	14.3	5.8	12.9	4.8	1.1	50	0.563

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.5	26.4	17.0	24.7	16.5	23.3	15.7	18.5	24.0	17.6	22.7	16.8	21.5	3.6	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
16.6	13.5	20.5	15.8	12.8	19.6	15.0	12.2	18.9	56.9	24.0	54.0	22.6	51.4	21.6	21.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.2	9.5	8.0	DB	-13.7	28.7	2.2	1.8	-15.2	30.0	-16.5	31.1	-17.7	32.1	-19.3	33.4	(4)
(5)			WB	-14.3	19.8	2.1	1.0	-15.9	20.5	-17.1	21.1	-18.3	21.7	-19.9	22.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	8.0	-1.1	0.0	4.0	7.5	11.4	15.2	16.7	16.4	12.3	8.6	3.9	0.3	(6)	
	DBStd	6.95	3.30	3.62	3.60	3.00	2.70	3.05	2.39	2.49	2.67	2.94	3.29	3.60	(7)	
	HDD10.0	1468	344	279	187	84	16	2	0	0	9	61	185	302	(8)	
	HDD18.3	3809	602	512	444	324	216	101	62	71	181	302	434	561	(9)	
	CDD10.0	728	0	0	2	10	58	157	206	198	79	18	1	0	(10)	
	CDD18.3	27	0	0	0	0	0	7	11	9	0	0	0	0	(11)	
	CDH23.3	319	0	0	0	0	7	97	116	97	3	0	0	0	(12)	
	CDH26.7	37	0	0	0	0	1	12	9	15	0	0	0	0	(13)	
(14) Wind	WSAvg	2.0	2.2	2.2	2.6	2.4	2.2	2.0	1.9	1.6	1.5	1.5	1.7	2.0	(14)	
(15) Precipitation	PrecAvg	920	45	31	39	62	87	106	104	106	90	100	106	45	(15)	
	PrecMax	1441	175	124	160	138	208	263	202	180	231	300	445	118	(16)	
	PrecMin	538	3	0	0	1	27	34	47	16	8	0	0	0	(17)	
	PrecStd	207	39	27	33	40	38	53	34	34	61	68	106	31	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.4	13.2	17.3	20.8	24.1	28.2	27.8	28.4	23.3	19.8	15.2	13.1	(19)	
		MCWB	4.9	5.3	7.2	10.8	14.4	16.7	17.8	17.7	15.5	11.4	7.5	5.0	(20)	
	2%	DB	8.5	9.6	14.9	18.2	21.8	25.9	26.1	25.8	21.4	17.4	12.0	9.9	(21)	
		MCWB	2.4	3.1	6.5	9.4	13.1	16.6	17.2	17.1	14.8	10.7	6.0	3.1	(22)	
	5%	DB	5.7	7.3	12.8	16.2	19.9	24.1	24.5	24.0	19.5	15.5	10.0	7.2	(23)	
		MCWB	0.7	1.8	5.3	8.1	12.2	15.8	16.6	16.7	13.5	9.9	5.8	2.0	(24)	
	10%	DB	3.8	5.4	10.6	14.2	17.9	22.1	23.0	22.2	17.7	13.7	8.5	5.2	(25)	
		MCWB	-0.2	0.8	4.3	7.1	10.9	14.9	15.8	15.8	12.5	9.6	5.5	1.4	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.4	5.7	8.2	11.7	15.8	19.1	19.7	19.4	16.9	13.5	9.8	6.0	(27)	
		MCDB	11.8	12.2	14.7	19.1	21.6	25.2	24.9	25.3	21.2	16.2	11.7	8.5	(28)	
	2%	WB	2.9	3.7	7.0	10.3	14.2	17.8	18.5	18.3	15.7	12.4	8.2	4.4	(29)	
		MCDB	6.7	8.1	12.4	16.3	20.0	23.5	24.0	23.6	19.6	14.8	10.1	7.4	(30)	
	5%	WB	1.7	2.4	6.1	9.1	13.1	16.8	17.6	17.4	14.7	11.5	7.2	3.3	(31)	
		MCDB	3.9	6.0	11.2	14.1	18.1	22.2	22.6	22.2	18.1	13.7	8.7	6.1	(32)	
	10%	WB	0.9	1.5	5.0	8.0	12.0	15.7	16.7	16.6	13.7	10.5	6.3	2.0	(33)	
		MCDB	2.7	4.2	9.7	12.4	16.1	20.7	21.4	20.8	16.5	12.7	7.7	4.2	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	8.4	8.7	9.8	10.3	10.5	11.3	11.5	10.8	9.8	9.0	7.8	8.0	(35)	
		MCDBR	10.9	11.3	14.0	14.8	14.8	14.7	13.9	13.6	12.4	12.1	10.4	10.7	(36)	
	5% WB	MCWBR	6.5	6.4	7.3	7.4	7.5	7.0	6.7	6.4	6.8	6.7	6.1	6.0	(37)	
		MCWBR	8.2	9.8	12.0	12.5	12.7	12.9	12.3	11.9	11.0	9.1	7.6	8.2	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.253	0.280	0.330	0.384	0.396	0.409	0.401	0.391	0.368	0.335	0.288	0.252	(40)	
		taud	2.333	2.266	2.212	2.159	2.225	2.241	2.270	2.315	2.356	2.419	2.443	2.377	(41)	
	Ebn at Noon		857	895	890	869	870	858	860	855	843	822	808	819	(42)	
		Edh at Noon	73	97	120	140	136	135	129	119	104	84	67	63	(43)	
(44) All-Sky Solar Radiation	RadAvg		1.60	2.54	3.79	4.51	4.96	5.74	5.79	5.02	3.88	2.55	1.56	1.33	(44)	
	RadStd		0.19	0.30	0.50	0.65	0.50	0.44	0.43	0.42	0.36	0.33	0.25	0.17	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		+0.48	+1.07	-2.07	+0.60	+0.65	+0.60	-126	-181	+79	+15	(46)
(47) Regional (99 neighbors)		+0.33	N/A	N/A	+0.68	+0.44	+0.35	N/A	N/A	+58	+13	(47)

Nomenclature: See separate page