

SCUOL, Switzerland

WMO: 067980

Lat: 46.7933N

Lon: 10.2833E

Elev: 4249

StdP: 12.58

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	5.2	8.5	-6.4	4.6	7.5	-1.2	6.0	11.1	15.5	22.5	12.3	21.8	4.5	260	0.577

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	23.1	82.6	59.5	79.4	58.7	76.1	57.5	62.0	76.4	60.4	74.0	59.1	71.8	6.1	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
57.5	82.6	64.1	55.9	78.1	62.9	54.7	74.5	61.9	29.9	76.6	28.8	74.2	27.7	71.7	68.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
13.5	11.3	9.5	DB	0.0	87.8	4.7	2.4	-3.4	89.6	-6.2	91.0	-8.8	92.4	-12.2	94.1	
			WB	-1.3	65.1	4.5	1.3	-4.5	66.0	-7.2	66.8	-9.7	67.5	-12.9	68.5	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	44.0	24.5	27.8	36.7	44.8	51.2	59.1	61.5	60.7	53.3	46.1	35.3	26.5
	DBStd	14.68	7.06	8.00	7.48	6.34	6.26	6.60	5.84	6.01	6.24	6.78	7.43	7.41
	HDD50	3435	790	621	412	175	62	9	1	2	39	154	441	729
	HDD65	7723	1255	1041	877	606	429	195	138	159	352	587	890	1194
	CDD50	1259	0	0	0	20	98	281	357	334	137	32	0	0
	CDD65	71	0	0	0	0	1	17	28	25	0	0	0	0
	CDH74	1133	0	0	0	0	24	311	420	343	34	1	0	0
	CDH80	219	0	0	0	0	1	60	85	72	1	0	0	0
Wind	WSAvg	3.4	2.8	3.0	3.6	4.2	4.3	4.0	3.7	3.5	3.1	2.8	2.5	2.8
Precipitation	PrecAvg	30.2	1.6	1.5	1.6	1.6	2.5	3.6	4.2	4.4	2.7	2.5	2.3	1.6
	PrecMax	38.8	4.1	6.9	4.1	3.3	5.0	5.9	7.0	7.9	5.5	6.0	7.6	5.6
	PrecMin	23.1	0.2	0.4	0.3	0.3	0.9	1.8	2.8	1.7	1.0	0.2	0.2	0.2
	PrecStd	3.9	1.1	1.4	0.9	0.7	0.9	1.1	1.0	1.4	1.2	1.4	1.6	1.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	43.5	50.9	62.6	70.1	77.1	85.6	86.5	86.2	78.4	69.5	56.6	43.8
		MCWB	37.5	38.9	43.6	49.6	55.2	59.7	61.3	59.9	57.4	52.3	46.1	37.3
	2%	DB	38.6	45.2	58.2	66.0	72.6	81.5	82.4	81.6	73.5	64.5	51.6	40.1
		MCWB	33.9	35.5	41.8	47.4	53.4	58.8	59.7	60.0	55.0	50.8	43.8	35.1
	5%	DB	35.8	41.4	53.9	61.9	68.5	77.7	78.9	77.9	69.6	60.8	48.0	37.5
		MCWB	32.5	33.7	40.1	45.6	51.4	57.7	58.4	59.0	54.3	49.5	41.7	33.6
	10%	DB	33.5	37.7	49.1	58.0	64.5	73.5	75.2	73.6	65.3	56.9	44.6	35.2
		MCWB	30.9	32.2	38.1	43.9	49.6	56.2	57.7	57.9	53.3	48.1	40.1	32.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	38.2	39.8	45.3	50.6	57.0	63.0	63.9	64.0	59.8	54.7	47.7	39.6
		MCDB	41.4	48.0	58.5	66.9	72.8	79.1	78.8	77.3	72.1	65.6	53.6	42.0
	2%	WB	35.0	36.6	42.8	48.4	54.7	60.5	61.9	62.0	57.5	52.6	44.7	36.6
		MCDB	37.6	43.1	55.1	63.5	68.7	75.7	76.3	75.7	68.8	61.1	49.5	38.7
	5%	WB	33.1	34.5	40.9	46.5	52.8	58.8	60.3	60.3	55.9	50.8	42.6	34.5
		MCDB	35.2	39.7	51.9	59.4	65.2	73.3	73.7	73.1	65.6	58.1	46.6	36.3
	10%	WB	31.4	32.8	38.9	44.7	51.0	57.3	59.0	58.9	54.1	49.0	40.6	32.7
		MCDB	33.4	37.0	47.8	55.6	61.9	70.7	71.5	70.4	62.8	55.4	44.1	34.8
Mean Daily Temperature Range	5% DB	MDBR	12.6	16.7	20.6	21.7	21.0	23.0	23.1	22.1	20.7	19.3	13.8	11.3
		MCDBR	13.2	19.7	27.8	28.6	28.0	29.6	29.7	29.5	28.0	24.5	18.2	12.5
		MCWBR	10.3	12.7	14.5	13.6	12.3	11.7	11.4	11.6	12.8	13.2	11.6	9.0
	5% WB	MCDBR	11.5	16.8	24.7	25.9	24.9	26.4	25.7	25.3	23.4	20.9	16.0	10.5
		MCWBR	9.6	11.3	13.2	12.6	11.4	11.2	11.0	10.9	11.5	12.1	10.9	8.4
Clear-Sky Solar Irradiance	taub	0.243	0.268	0.313	0.364	0.379	0.386	0.383	0.376	0.341	0.312	0.275	0.243	
	taud	2.335	2.266	2.211	2.201	2.264	2.296	2.306	2.345	2.427	2.480	2.466	2.381	
	Ebn at Noon	275	288	288	282	281	279	278	275	277	270	261	263	
	Edh at Noon	23	30	38	43	41	40	39	36	30	25	20	19	
All-Sky Solar Radiation	RadAvg	487	787	1166	1412	1545	1767	1771	1549	1190	799	482	403	
	RadStd	55	92	144	199	166	149	144	147	123	98	75	52	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	+1.03	N/A	N/A	N/A	N/A	N/A
(47)	Regional (107 neighbors)	+0.61	N/A	N/A	+1.15	+0.76	+0.65	N/A	N/A	+106	+29

Nomenclature: See separate page