

LE TOUQUET AP, France

WMO: 070030

Lat: 50.5144N

Lon: 1.6228E

Elev: 11

StdP: 101.19

Time Zone: 1.00 (EUC)

Period: 99-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-3.9	-2.2	-6.9	2.1	-2.8	-5.1	2.5	-1.2	11.9	7.4	10.7	7.4	2.5	150	0.576

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.7	27.2	19.7	25.0	18.9	23.0	17.8	20.5	25.9	19.4	23.8	18.5	21.9	4.4	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.5	13.4	22.9	17.7	12.7	21.6	17.0	12.2	20.3	59.0	25.9	55.4	23.7	52.2	22.1	24.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
11.8	9.5	8.3	-6.4	32.6	2.2	2.5	-8.0	34.4	-9.4	35.8	-10.6	37.2	-12.3	39.0		
			-6.9	22.9	2.2	0.7	-8.5	23.5	-9.8	23.9	-11.0	24.3	-12.7	24.8		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	11.1	5.0	5.2	7.2	9.8	12.8	15.5	17.4	17.2	15.6	12.4	8.4	6.0
	DBStd	5.43	3.73	3.44	3.00	3.07	3.00	2.73	2.53	2.41	2.66	2.96	2.99	3.70
	HDD10.0	641	156	136	95	39	8	0	0	0	1	11	67	129
	HDD18.3	2699	413	367	346	255	174	94	49	49	89	183	298	382
	CDD10.0	1034	2	2	8	34	93	164	229	224	167	87	18	6
	CDD18.3	51	0	0	0	0	2	8	19	15	6	1	0	0
	CDH23.3	397	0	0	0	1	24	79	157	101	33	2	0	0
	CDH26.7	92	0	0	0	0	3	17	43	24	4	0	0	0
(14) Wind	WSAvg	4.1	4.4	4.6	4.3	4.0	4.0	3.9	3.8	3.6	3.7	4.0	4.4	4.4
(15) Precipitation	PrecAvg	857	78	59	49	52	58	55	59	66	72	97	111	101
	PrecMax	1158	146	155	153	147	122	132	134	135	161	242	264	205
	PrecMin	572	10	15	6	2	6	23	8	11	2	23	32	24
	PrecStd	153	36	35	31	35	29	29	30	39	39	51	55	54
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.8	14.7	18.1	22.9	26.0	29.1	30.9	29.6	26.7	22.5	16.8	14.0
		MCWB	10.8	10.1	12.0	15.6	17.9	20.7	21.5	20.7	19.3	17.6	14.7	11.9
	2%	DB	11.6	11.9	15.4	20.0	23.0	25.5	27.2	26.3	23.5	19.2	15.0	12.9
		MCWB	10.2	9.5	11.4	14.2	16.7	19.2	19.8	19.5	18.6	16.2	13.1	11.4
	5%	DB	10.7	10.6	13.3	17.3	20.5	22.8	24.6	23.2	21.2	17.6	14.0	12.1
		MCWB	9.4	9.0	10.3	12.9	15.6	17.5	18.9	18.2	17.3	15.2	12.3	10.5
	10%	DB	10.0	9.7	11.4	15.0	18.2	20.6	22.2	21.2	19.7	16.7	13.1	11.2
		MCWB	8.8	8.4	9.2	11.7	14.4	16.4	17.9	17.4	16.5	14.6	11.5	9.8
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.4	11.1	13.2	16.4	19.7	21.3	22.0	21.7	20.6	17.9	15.2	12.6
		MCDB	12.2	13.2	16.3	21.0	24.5	27.7	29.2	27.8	25.3	20.8	16.5	13.3
	2%	WB	10.5	10.1	11.7	14.4	17.5	19.6	20.6	20.0	19.1	16.7	13.6	11.7
		MCDB	11.3	11.4	14.6	19.2	21.6	24.7	26.2	24.4	22.7	18.8	14.7	12.7
	5%	WB	9.7	9.4	10.5	13.2	16.0	18.0	19.3	18.8	18.0	15.8	12.6	10.9
		MCDB	10.5	10.4	12.8	16.9	19.9	22.1	23.6	22.3	20.3	17.2	13.8	11.9
	10%	WB	9.0	8.6	9.7	11.9	14.8	16.7	18.2	18.0	17.1	15.0	11.7	10.0
		MCDB	9.9	9.6	11.2	14.5	17.8	19.7	21.6	20.5	19.1	16.4	12.9	11.0
(35) Mean Daily Temperature Range	5% DB	MDBR	4.7	5.3	6.6	8.2	8.2	8.0	7.7	7.9	7.7	6.7	5.8	4.9
		MCDBR	4.1	6.4	10.1	11.6	12.4	12.8	12.9	11.8	9.9	7.6	6.0	4.5
	5% WB	MCWBR	4.0	4.9	6.4	7.0	7.2	7.3	6.9	6.4	5.8	5.3	5.0	4.3
		MCDWR	4.0	5.2	8.4	10.7	11.2	11.3	11.6	10.0	8.2	6.8	5.4	4.6
(40) Clear-Sky Solar Irradiance	taub	taub	0.331	0.349	0.386	0.406	0.414	0.413	0.411	0.403	0.382	0.366	0.340	0.324
		taud	2.387	2.370	2.267	2.233	2.267	2.293	2.305	2.349	2.391	2.418	2.409	2.371
	Ebn at Noon	Ebn	693	778	807	834	844	846	841	829	806	748	675	638
		Edh	64	84	110	127	128	126	122	112	97	79	63	57
(44) All-Sky Solar Radiation	RadAvg	0.84	1.56	2.79	4.49	5.31	5.88	5.65	4.73	3.51	1.99	0.96	0.65	(44)
	RadStd	0.07	0.23	0.34	0.38	0.38	0.50	0.45	0.32	0.21	0.18	0.10	0.08	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (67 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page