

LILLE-LESQUIN AP, France

WMO: 070150

Lat: 50.5700N

Lon: 3.0975E

Elev: 157

StdP: 14.61

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	22.6	25.9	15.8	12.3	26.8	19.8	15.0	28.3	32.5	48.8	29.9	49.4	7.9	50	0.578

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.9	85.7	67.8	81.6	66.4	78.1	64.6	69.5	81.6	67.8	78.4	66.2	75.6	8.6	60

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
65.5	94.6	73.6	63.9	89.6	72.1	62.5	85.1	70.2	33.6	81.9	32.2	78.6	30.9	75.6	75.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
25.7	22.7	20.0	DB	18.5	92.8	4.8	4.1	15.0	95.7	12.2	98.1	9.4	100.4	5.9	103.3
			WB	17.6	73.2	4.9	1.4	14.1	74.2	11.2	75.0	8.5	75.8	5.0	76.8

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	52.0	39.1	40.5	45.1	50.5	56.5	61.6	65.8	65.4	59.9	53.4	45.6	40.2
	DBStd	11.26	7.19	6.57	5.96	6.23	6.18	5.69	5.58	5.33	5.09	5.86	6.03	7.02
	HDD50	1356	339	269	171	66	11	0	0	0	1	33	156	310
	HDD65	4942	801	687	616	435	275	132	57	58	167	361	583	770
	CDD50	2097	2	3	19	82	212	350	489	476	298	138	23	5
	CDD65	210	0	0	0	1	11	32	81	69	15	1	0	0
	CDH74	1831	0	0	0	17	104	310	706	584	105	5	0	0
	CDH80	512	0	0	0	0	12	79	210	192	19	0	0	0
Wind	WSAvg	9.6	11.3	11.0	10.6	9.5	9.2	8.6	8.5	8.1	8.3	9.2	9.7	10.7
Precipitation	PrecAvg	27.5	2.1	1.6	2.2	1.8	2.4	2.4	2.5	2.3	2.4	2.4	2.8	2.6
	PrecMax	35.4	4.7	3.1	4.4	4.4	4.9	4.9	7.1	5.1	6.3	6.5	5.5	6.4
	PrecMin	17.2	0.1	0.2	0.1	0.1	0.8	0.2	0.7	0.3	0.2	0.2	0.9	0.4
	PrecStd	4.8	1.1	0.8	1.1	1.0	1.1	1.3	1.5	1.2	1.5	1.5	1.2	1.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.5	57.9	66.1	76.5	81.9	87.8	91.0	91.1	82.6	73.1	62.3	56.5
		MCWB	52.4	50.1	53.3	59.7	65.8	69.7	70.1	69.4	67.4	63.7	57.9	53.8
	2%	DB	53.3	54.0	61.1	70.7	77.1	81.5	85.4	85.5	76.8	67.6	58.7	54.6
		MCWB	50.9	49.5	52.2	57.1	61.9	66.4	67.9	67.7	64.4	60.5	55.3	52.2
	5%	DB	51.0	51.8	57.2	65.3	72.6	77.3	81.4	80.5	72.4	64.4	56.5	52.5
		MCWB	48.5	48.4	50.6	54.3	60.1	64.6	66.3	65.9	62.4	58.8	53.6	50.2
	10%	DB	48.7	49.9	54.2	61.2	68.2	73.0	77.5	76.0	69.0	62.0	54.3	50.2
		MCWB	46.4	47.0	49.1	52.5	58.0	62.4	64.8	64.3	60.6	57.7	51.7	48.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	53.4	52.4	55.7	61.6	67.5	71.2	71.7	71.9	68.3	64.3	58.8	54.5
		MCDB	54.8	55.7	60.9	73.6	79.2	84.7	86.2	85.2	78.7	70.5	61.3	55.8
	2%	WB	51.1	50.5	53.5	58.0	63.9	67.8	69.5	69.3	65.9	61.8	55.8	52.5
		MCDB	53.0	53.0	59.1	67.3	73.1	78.2	82.1	80.8	73.8	66.4	58.0	54.3
	5%	WB	48.7	48.9	51.6	55.7	61.3	65.7	67.6	67.3	63.8	60.0	54.0	50.4
		MCDB	50.7	51.3	56.2	63.6	69.6	75.4	78.3	77.6	69.8	63.6	56.2	52.3
	10%	WB	46.7	47.2	49.9	53.5	59.1	63.5	65.8	65.5	62.1	58.3	51.9	48.2
		MCDB	48.5	49.6	53.6	60.0	67.1	71.4	75.0	74.0	67.5	61.4	54.1	49.8
Mean Daily Temperature Range	5% DB	MDBR	8.4	10.1	12.9	15.7	16.1	16.8	16.9	17.3	15.7	12.9	9.6	8.3
		MCDBR	9.4	12.2	17.9	22.4	22.9	23.7	23.8	25.0	20.8	15.8	11.0	9.3
		MCWBR	8.5	9.0	10.8	11.4	11.0	11.4	9.7	9.8	10.0	9.6	8.6	8.4
	5% WB	MCDBR	9.4	10.8	15.2	19.5	20.3	21.7	20.8	21.3	17.7	14.0	10.0	9.1
		MCWBR	8.8	8.6	9.9	10.6	10.8	11.6	9.7	9.8	9.4	9.4	8.4	8.4
Clear-Sky Solar Irradiance	taub	0.331	0.352	0.390	0.416	0.426	0.423	0.424	0.414	0.389	0.369	0.343	0.327	
	taud	2.376	2.342	2.230	2.180	2.198	2.229	2.231	2.280	2.337	2.387	2.381	2.350	
	Ebn at Noon	219	245	254	261	264	265	263	259	253	235	211	200	
	Edh at Noon	21	27	36	42	43	43	42	38	32	26	20	18	
All-Sky Solar Radiation	RadAvg	260	480	855	1360	1583	1738	1649	1401	1067	625	305	206	
	RadStd	25	93	113	147	141	158	167	131	80	53	33	27	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (66 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page