

POINTE DE LA HAGUE, France

WMO: 070200

Lat: 49.7253N

Lon: 1.9397W

Elev: 12

StdP: 101.18

Time Zone: 1.00 (EUC)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	1.1	2.5	-3.9	2.7	3.0	-2.4	3.1	3.6	19.6	8.3	18.3	8.5	5.9	120	0.754

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	4.1	21.6	17.9	20.6	17.5	19.7	17.0	18.6	20.6	18.0	19.8	17.5	19.1	5.1	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
17.8	12.8	19.5	17.2	12.3	18.9	16.7	11.9	18.5	52.8	20.8	50.8	19.8	49.3	19.2	22.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 17.2	15.5	14.1	-0.9	25.8	1.8	1.9	-2.2	27.1	-3.3	28.2	-4.3	29.3	-5.5	30.7 (4)		
(5)			-2.2	20.2	1.5	1.1	-3.3	21.0	-4.1	21.6	-5.0	22.3	-6.1	23.1 (5)		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	12.2	7.8	7.6	8.5	10.0	12.3	14.8	16.8	17.5	16.5	14.3	11.2	8.8
	DBStd	4.05	2.61	2.22	2.01	1.86	1.71	1.49	1.31	1.15	1.49	2.07	2.28	2.58
	HDD10.0	286	73	70	53	21	2	0	0	0	0	1	14	52
	HDD18.3	2248	326	301	305	249	186	108	50	30	57	126	214	296
	CDD10.0	1091	5	2	6	22	74	143	211	234	196	134	49	14
	CDD18.3	12	0	0	0	0	0	1	3	6	3	1	0	0
	CDH23.3	15	0	0	0	0	1	1	4	4	4	1	0	0
	CDH26.7	1	0	0	0	0	0	0	1	0	0	0	0	0
Wind	WSAvg	7.2	8.9	8.6	7.5	6.5	6.2	5.6	5.5	5.9	6.7	7.8	8.6	8.9
Precipitation	PrecAvg	859	96	72	58	55	51	48	46	54	58	96	113	111
	PrecMax	1133	180	150	145	139	112	98	92	140	139	179	250	230
	PrecMin	631	17	10	10	4	10	11	11	13	6	22	32	25
	PrecStd	117	44	42	30	34	29	27	24	31	32	41	53	49
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.7	12.7	15.2	16.9	19.6	22.3	23.1	23.5	22.7	21.0	16.5	14.0
		MCWB	11.6	10.4	11.7	12.9	15.2	17.5	17.9	19.0	18.0	16.5	14.9	12.7
	2%	DB	12.0	11.5	13.0	14.9	17.0	19.5	21.1	21.4	20.8	18.7	15.4	13.2
		MCWB	11.0	10.1	10.5	12.0	14.1	16.3	17.7	18.2	17.6	16.2	13.9	12.0
	5%	DB	11.5	10.9	11.8	13.6	15.8	18.1	20.0	20.4	19.5	17.6	14.8	12.7
		MCWB	10.4	9.8	10.0	11.3	13.4	15.5	17.2	17.7	16.8	15.7	13.3	11.4
	10%	DB	11.0	10.4	11.1	12.6	14.9	17.2	19.2	19.6	18.6	16.9	14.2	12.1
		MCWB	9.9	9.3	9.6	10.7	12.9	14.9	16.7	17.2	16.3	15.2	12.7	10.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.1	11.2	12.2	13.4	16.0	17.8	19.1	19.7	19.0	17.7	15.4	13.2
		MCDB	12.4	11.9	14.3	16.2	18.3	21.1	21.6	22.3	21.3	19.4	16.0	13.5
	2%	WB	11.4	10.6	11.0	12.3	14.5	16.6	18.1	18.8	18.1	16.7	14.3	12.4
		MCDB	11.8	11.2	12.2	14.3	16.4	19.0	20.2	20.7	20.1	17.9	15.1	12.9
	5%	WB	10.7	10.1	10.4	11.6	13.7	15.9	17.6	18.2	17.4	16.1	13.6	11.8
		MCDB	11.3	10.7	11.4	13.2	15.4	17.7	19.4	19.7	19.0	17.2	14.6	12.5
	10%	WB	10.1	9.5	9.9	10.9	13.1	15.2	17.1	17.7	16.9	15.5	12.9	11.1
		MCDB	10.9	10.3	10.8	12.3	14.6	16.8	18.8	19.1	18.2	16.7	14.0	12.0
Mean Daily Temperature Range	5% DB	MDBR	2.8	3.0	3.5	4.2	4.2	4.4	4.5	4.1	3.9	3.5	3.1	3.1
		MCDBR	2.6	3.0	4.7	5.8	5.7	6.1	6.0	5.7	5.3	4.3	3.2	2.8
		MCWBR	3.1	2.9	3.5	4.0	3.8	4.0	3.8	3.6	3.6	3.2	3.4	3.3
	5% WB	MCDBR	2.6	2.7	4.2	5.3	5.3	5.5	5.3	4.8	4.7	3.8	3.0	2.8
		MCWBR	3.2	3.0	3.3	3.9	3.7	3.8	3.5	3.4	3.5	3.4	3.4	3.4
Clear-Sky Solar Irradiance	taub	0.337	0.353	0.387	0.399	0.404	0.398	0.392	0.386	0.376	0.366	0.340	0.330	
	taud	2.395	2.387	2.304	2.299	2.338	2.384	2.404	2.442	2.448	2.450	2.433	2.365	
	Ebn at Noon	699	782	814	846	856	862	862	851	820	759	691	645	
	Edh at Noon	66	84	107	119	120	115	111	102	92	78	63	60	
All-Sky Solar Radiation	RadAvg	0.86	1.61	2.83	4.53	5.42	5.96	5.74	4.78	3.62	2.04	1.07	0.70	
	RadStd	0.07	0.19	0.31	0.38	0.38	0.57	0.35	0.34	0.24	0.15	0.11	0.08	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (40 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page