

EVREUX HUEST AB, France

WMO: 070380

Lat: 49.0250N

Lon: 1.2217E

Elev: 453

StdP: 14.46

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 34061

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	22.6	25.7	16.9	13.2	25.4	20.7	15.8	28.2	30.7	49.6	27.6	49.2	6.3	30	0.568

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.3	86.2	67.3	82.2	65.8	78.6	64.6	69.3	81.6	67.5	78.5	65.9	75.9	8.9	60

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.3	95.0	73.6	63.7	89.6	71.6	62.2	85.1	69.9	33.6	81.6	32.2	78.7	30.9	76.0	77.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
24.0	20.9	18.5	DB	17.0	93.7	4.9	4.6	13.5	96.9	10.6	99.6	7.9	102.2	4.4	105.5	(4)
			WB	16.3	73.0	4.9	1.8	12.7	74.4	9.8	75.4	7.0	76.5	3.4	77.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	51.8	39.5	40.6	45.2	49.5	55.3	61.3	65.2	64.9	59.6	53.4	45.5	40.3	(6)
(7)		DBStd	11.04	7.20	6.71	5.96	6.03	5.86	5.84	5.53	5.42	5.18	6.04	6.12	7.10	(7)
(8)		HDD50	1358	327	265	171	79	16	0	0	0	1	36	157	306	(8)
(9)		HDD65	5017	790	683	615	464	304	142	65	68	176	361	584	765	(9)
(10)		CDD50	2005	3	2	20	65	182	340	472	462	289	141	23	6	(10)
(11)		CDD65	189	0	0	0	0	5	31	73	65	14	1	0	0	(11)
(12)		CDH74	1925	0	0	0	9	52	334	746	635	142	7	0	0	(12)
(13)		CDH80	555	0	0	0	0	3	91	227	205	29	0	0	0	(13)
(14)	Wind	WSAvg	9.0	10.3	10.2	9.6	8.8	8.4	7.9	8.2	7.9	8.1	8.9	9.2	10.0	(14)
(15)	Precipitation	PrecAvg	27.1	2.3	2.0	1.9	2.0	2.3	2.1	2.2	2.0	2.1	2.6	2.5	3.0	(15)
(16)		PrecMax	36.6	4.8	4.1	6.4	4.2	4.3	5.7	5.2	4.7	4.5	5.9	5.0	7.3	(16)
(17)		PrecMin	19.9	0.4	0.3	0.2	0.4	0.6	0.4	0.4	0.2	0.4	0.8	0.7	1.1	(17)
(18)		PrecStd	4.2	1.0	1.0	1.3	1.1	1.0	1.2	1.3	1.3	1.2	1.3	1.0	1.5	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	56.1	58.6	66.7	74.9	79.0	87.8	91.5	93.6	83.7	73.6	61.9	56.9	(19)
(20)		MCWB	53.1	50.7	53.9	59.4	65.3	68.5	68.4	69.0	65.2	63.0	58.3	54.2	(20)	
(21)		2%	DB	53.8	54.1	61.8	69.9	75.0	82.3	85.9	86.2	78.0	68.4	58.8	54.7	(21)
(22)		MCWB	51.5	50.1	52.7	57.9	62.3	66.8	67.0	67.1	63.6	61.0	55.6	52.3	(22)	
(23)		5%	DB	51.5	52.1	57.8	64.6	71.2	77.4	82.0	81.2	73.3	64.8	56.5	52.7	(23)
(24)		MCWB	49.2	48.8	51.1	54.6	60.6	64.5	65.6	65.7	61.6	58.9	53.6	50.5	(24)	
(25)		10%	DB	49.4	50.1	55.0	60.6	67.1	73.4	78.1	77.0	69.7	62.3	54.4	50.6	(25)
(26)		MCWB	47.3	47.2	50.1	52.8	58.4	62.9	64.6	63.8	60.1	57.8	51.9	48.6	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	53.9	52.7	56.3	62.2	67.5	71.9	71.1	71.4	67.8	64.5	59.3	54.8	(27)
(28)		MCDWB	55.6	55.9	62.7	72.9	77.1	83.4	85.8	86.2	78.6	71.0	61.2	56.3	(28)	
(29)		2%	WB	51.7	50.9	54.0	58.4	63.8	68.1	69.0	69.0	65.1	61.8	56.1	52.7	(29)
(30)		MCDWB	53.6	53.4	59.3	67.2	72.1	78.4	81.9	81.3	73.9	66.5	58.3	54.4	(30)	
(31)		5%	WB	49.5	49.3	52.3	55.7	61.3	65.9	67.2	67.1	63.3	60.1	54.1	50.8	(31)
(32)		MCDWB	51.2	51.7	56.9	63.2	69.2	75.4	78.5	78.2	70.7	63.9	56.1	52.6	(32)	
(33)		10%	WB	47.4	47.5	50.4	53.4	59.2	63.9	65.6	65.2	61.6	58.4	52.2	48.8	(33)
(34)		MCDWB	49.0	49.8	54.4	59.6	65.9	72.0	75.7	74.7	67.9	61.7	54.2	50.4	(34)	
(35)	Mean Daily Temperature Range		MDBR	9.4	11.5	14.6	17.3	17.5	18.5	19.3	19.3	17.9	14.1	10.7	9.5	(35)
(36)		5% DB	MCDBR	9.9	13.6	19.9	23.6	23.4	25.1	27.1	26.7	23.7	16.7	11.7	9.9	(36)
(37)			MCWBR	8.6	10.2	12.3	13.3	12.9	12.1	10.8	10.8	11.0	10.1	9.2	8.7	(37)
(38)			MCDBR	9.9	12.3	16.5	20.6	21.0	21.8	23.5	22.7	19.3	14.8	11.2	9.7	(38)
(39)		5% WB	MCWBR	8.9	9.9	11.2	12.3	12.5	12.0	10.6	10.9	10.3	9.9	9.4	8.8	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.321	0.338	0.371	0.393	0.400	0.402	0.398	0.390	0.368	0.355	0.329	0.314	(40)	
(41)		taud	2.434	2.392	2.295	2.241	2.256	2.289	2.296	2.340	2.387	2.425	2.443	2.402	(41)	
(42)		Ebn at Noon	233	256	265	270	273	273	272	269	263	246	227	217	(42)	
(43)		Edh at Noon	21	27	35	40	41	40	39	36	31	25	20	19	(43)	
(44)	All-Sky Solar Radiation	RadAvg	290	532	895	1373	1611	1803	1715	1476	1144	667	351	247	(44)	
(45)		RadStd	29	70	110	154	140	178	128	129	78	59	33	32	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (34 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page