

EVREUX HUEST AB, France

WMO: 070380

Lat: 49.0250N

Lon: 1.2217E

Elev: 138

StdP: 99.68

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 34061

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -5.2	(c) -3.5	(d) -8.4	(e) 1.9	(f) -3.6	(g) -6.3	(h) 2.3	(i) -2.1	(j) 13.7	(k) 9.8	(l) 12.3	(m) 9.6	(n) 2.8	(o) 30	(p) 0.568

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 10.7	(c) 30.1	(d) 19.6	(e) 27.9	(f) 18.8	(g) 25.9	(h) 18.1	(i) 20.7	(j) 27.6	(k) 19.7	(l) 25.8	(m) 18.8	(n) 24.4	(o) 4.0	(p) 60

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.5	13.6	23.1	17.6	12.8	22.0	16.8	12.2	21.1	60.3	27.5	56.9	25.9	53.9	24.4	25.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 10.7	(b) 9.4	(c) 8.3	(e) -8.3	(f) 34.3	(g) 2.7	(h) 2.5	(i) -10.3	(j) 36.1	(k) -11.9	(l) 37.6	(m) -13.4	(n) 39.0	(o) -15.3	(p) 40.8		
(4) 10.7	(5) 9.4	(6) 8.3	(7) -8.7	(8) 22.8	(9) 2.7	(10) 1.0	(11) -10.7	(12) 23.5	(13) -12.3	(14) 24.1	(15) -13.9	(16) 24.7	(17) -15.9	(18) 25.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	11.0	4.2	4.8	7.3	9.7	13.0	16.3	18.5	18.3	15.3	11.9	7.5	4.6
	DBStd	6.13	4.00	3.73	3.31	3.35	3.26	3.24	3.07	3.01	2.88	3.35	3.40	3.94
	HDD10.0	754	182	147	95	44	9	0	0	0	1	20	87	170
	HDD18.3	2787	439	379	342	258	169	79	36	38	98	201	324	425
	CDD10.0	1114	2	1	11	36	101	189	262	257	161	78	13	3
	CDD18.3	105	0	0	0	0	3	17	41	36	8	1	0	0
	CDH23.3	1069	0	0	0	5	29	186	414	353	79	4	0	0
	CDH26.7	308	0	0	0	0	2	51	126	114	16	0	0	0
Wind	WSAvg	4.0	4.6	4.5	4.3	3.9	3.7	3.5	3.7	3.6	3.6	4.0	4.1	4.5
Precipitation	PrecAvg	689	59	52	47	51	58	54	56	51	54	67	64	76
	PrecMax	930	121	104	163	106	110	146	133	119	115	150	126	186
	PrecMin	505	9	8	6	9	14	9	11	5	10	20	18	27
	PrecStd	106	26	26	33	28	25	30	32	32	30	33	26	37
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.4	14.8	19.3	23.8	26.1	31.0	33.0	34.2	28.7	23.1	16.6	13.8
		MCWB	11.7	10.4	12.1	15.2	18.5	20.3	20.2	20.5	18.5	17.2	14.6	12.4
	2%	DB	12.1	12.3	16.6	21.0	23.9	27.9	30.0	30.1	25.6	20.2	14.9	12.6
		MCWB	10.8	10.1	11.5	14.4	16.9	19.3	19.4	19.5	17.6	16.1	13.1	11.3
	5%	DB	10.8	11.2	14.4	18.1	21.8	25.2	27.8	27.4	22.9	18.2	13.6	11.5
		MCWB	9.5	9.3	10.6	12.5	15.9	18.1	18.7	18.7	16.4	14.9	12.0	10.3
	10%	DB	9.7	10.1	12.8	15.9	19.5	23.0	25.6	25.0	20.9	16.8	12.4	10.3
		MCWB	8.5	8.5	10.0	11.5	14.7	17.2	18.1	17.7	15.6	14.3	11.1	9.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.2	11.5	13.5	16.8	19.7	22.1	21.7	21.9	19.9	18.1	15.2	12.6
		MCDB	13.1	13.3	17.0	22.7	25.0	28.6	29.9	30.1	25.9	21.6	16.2	13.5
	2%	WB	11.0	10.5	12.2	14.7	17.7	20.1	20.6	20.6	18.4	16.6	13.4	11.5
		MCDB	12.0	11.9	15.2	19.6	22.3	25.8	27.7	27.4	23.3	19.2	14.6	12.5
	5%	WB	9.7	9.6	11.3	13.2	16.3	18.8	19.6	19.5	17.4	15.6	12.3	10.5
		MCDB	10.7	11.0	13.8	17.4	20.6	24.1	25.8	25.7	21.5	17.7	13.4	11.4
	10%	WB	8.6	8.6	10.2	11.9	15.1	17.7	18.6	18.5	16.4	14.7	11.2	9.4
		MCDB	9.5	9.9	12.4	15.3	18.8	22.2	24.3	23.7	20.0	16.5	12.3	10.2
Mean Daily Temperature Range	5% DB	MDBR	5.2	6.4	8.1	9.6	9.7	10.3	10.7	10.7	10.0	7.8	6.0	5.3
		MCDBR	5.5	7.6	11.1	13.1	13.0	14.0	15.1	14.9	13.2	9.3	6.5	5.5
		MCWBR	4.8	5.7	6.8	7.4	7.2	6.7	6.0	6.0	6.1	5.6	5.1	4.8
	5% WB	MCDBR	5.5	6.8	9.2	11.5	11.7	12.1	13.1	12.6	10.7	8.2	6.2	5.4
		MCWBR	5.0	5.5	6.2	6.8	6.9	6.7	5.9	6.0	5.7	5.5	5.2	4.9
Clear-Sky Solar Irradiance	taub	0.321	0.338	0.371	0.393	0.400	0.402	0.398	0.390	0.368	0.355	0.329	0.314	
	taud	2.434	2.392	2.295	2.241	2.256	2.289	2.296	2.340	2.387	2.425	2.443	2.402	
	Ebn at Noon	736	807	834	852	860	860	856	847	830	776	716	685	
	Edh at Noon	65	84	109	127	130	127	124	114	98	80	64	59	
All-Sky Solar Radiation	RadAvg	0.92	1.68	2.82	4.33	5.08	5.68	5.41	4.65	3.61	2.10	1.11	0.78	
	RadStd	0.09	0.22	0.35	0.48	0.44	0.56	0.41	0.41	0.25	0.18	0.10	0.10	

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46) Station Only	DBAvg	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A
(47) Regional (34 neighbors)		(m) N/A	(n) N/A	(o) N/A	(p) N/A	(q) N/A	(r) N/A	(s) N/A	(t) N/A	(u) N/A

Nomenclature: See separate page