

PONTOISE, France

WMO: 070530

Lat: 49.0903N

Lon: 2.0286E

Elev: 88

StdP: 100.27

Time Zone: 1.00 (EUC)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-6.2	-4.0	-9.9	1.6	-5.2	-6.2	2.3	-2.8	11.4	9.6	10.4	9.3	2.5	60	0.540

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.1	30.9	19.9	28.2	19.1	26.8	18.5	21.1	28.6	20.1	26.8	19.1	25.0	3.7	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.5	13.5	23.6	17.8	12.9	22.6	17.0	12.2	21.7	61.6	28.9	57.7	26.9	54.6	25.1	24.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
9.5	8.4	7.4	-8.4	36.4	4.0	2.0	-11.3	37.9	-13.7	39.1	-15.9	40.2	-18.8	41.6		
			-9.1	23.2	3.7	0.7	-11.8	23.7	-14.0	24.1	-16.1	24.4	-18.8	24.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	10.9	3.8	4.1	7.4	10.1	12.6	16.2	18.6	18.0	15.2	11.9	7.7	4.7
	DBStd	6.21	4.13	4.11	3.11	3.34	3.25	3.49	3.34	3.23	2.92	3.45	3.35	3.86
	HDD10.0	770	194	165	89	39	10	1	0	0	1	20	84	166
	HDD18.3	2823	451	397	338	248	179	82	38	46	101	202	319	421
	CDD10.0	1099	2	1	10	42	92	188	266	247	157	78	14	3
	CDD18.3	109	0	0	0	0	3	19	45	35	7	1	0	0
	CDH23.3	1437	0	0	0	15	51	263	564	447	87	10	0	0
	CDH26.7	445	0	0	0	0	3	82	193	148	19	1	0	0
Wind	WSAvg	3.4	3.7	3.9	3.9	3.3	3.3	3.2	3.1	2.9	3.0	3.2	3.7	3.8
Precipitation	PrecAvg	680	58	50	46	49	61	56	60	57	47	62	61	72
	PrecMax	969	138	99	168	123	162	122	148	110	106	153	119	181
	PrecMin	502	4	8	6	9	5	11	17	9	0	13	16	28
	PrecStd	115	28	27	34	27	31	25	31	31	29	30	26	35
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.2	15.8	20.1	25.2	27.0	32.8	35.0	34.0	29.2	24.2	17.8	14.2
		MCWB	11.2	10.3	11.9	15.6	19.6	20.7	20.9	21.0	18.8	17.4	15.3	12.2
	2%	DB	12.0	12.2	17.9	22.9	24.9	28.9	30.9	30.2	25.9	21.8	15.9	13.0
		MCWB	10.5	9.3	11.6	14.2	17.1	19.8	20.1	19.9	17.8	17.0	13.8	11.3
	5%	DB	10.9	11.0	15.2	19.2	22.2	26.2	28.2	27.9	23.2	19.0	14.2	11.9
		MCWB	9.3	9.1	10.5	13.1	16.0	19.0	19.0	19.0	16.7	15.4	12.4	10.2
	10%	DB	9.5	9.9	13.0	17.0	20.0	23.9	26.2	25.8	21.8	17.1	13.0	10.8
		MCWB	8.5	8.2	9.7	11.9	14.9	17.7	18.4	17.7	15.9	14.5	11.4	9.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.1	11.0	13.3	16.8	20.8	22.6	22.1	22.2	20.1	18.5	15.9	13.0
		MCDB	13.1	13.4	17.3	24.4	25.6	30.8	32.7	30.8	26.2	22.3	17.2	13.9
	2%	WB	10.9	10.2	12.2	14.6	18.1	20.6	20.9	20.7	18.6	17.1	13.9	11.6
		MCDB	12.0	11.7	16.6	21.1	23.1	27.0	28.7	28.2	23.3	20.6	15.6	13.0
	5%	WB	9.6	9.2	11.1	13.3	16.5	19.4	19.9	19.6	17.6	16.0	12.7	10.5
		MCDB	10.4	10.8	14.7	18.7	20.8	25.1	27.4	25.7	22.1	18.7	14.3	11.8
	10%	WB	8.4	8.1	10.0	12.3	15.3	18.2	18.8	18.5	16.7	15.0	11.6	9.3
		MCDB	9.4	9.7	12.8	16.5	19.3	22.9	24.9	23.9	20.6	16.8	13.1	10.3
Mean Daily Temperature Range	5% DB	MDBR	5.2	6.9	9.2	11.3	12.0	12.4	13.1	13.3	11.7	9.1	6.4	5.9
		MCDBR	5.7	8.6	13.9	14.8	15.9	16.5	16.9	16.9	14.4	11.2	8.0	7.2
		MCWBR	4.8	6.3	8.6	8.4	9.4	8.7	7.7	7.7	7.5	7.0	6.3	6.0
	5% WB	MCDBR	5.7	8.3	11.7	13.9	14.3	15.5	15.9	15.3	12.3	10.2	7.4	6.9
		MCWBR	5.1	6.6	7.7	8.2	9.3	9.0	7.9	8.4	7.2	6.7	6.1	6.0
Clear-Sky Solar Irradiance	taub	0.332	0.352	0.387	0.407	0.414	0.415	0.414	0.405	0.379	0.369	0.341	0.325	
	taud	2.393	2.352	2.247	2.209	2.227	2.261	2.262	2.310	2.368	2.386	2.403	2.368	
	Ebn at Noon	715	787	814	838	846	847	841	832	818	756	695	664	
	Edh at Noon	67	88	114	131	134	131	129	117	100	84	66	61	
All-Sky Solar Radiation	RadAvg	0.90	1.66	2.83	4.33	5.09	5.67	5.38	4.65	3.59	2.11	1.08	0.76	
	RadStd	0.10	0.24	0.35	0.49	0.48	0.54	0.44	0.43	0.28	0.18	0.10	0.11	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (35 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page