

PARIS BEAUVAIS TILLE AP, France

WMO: 070550

Lat: 49.4464N

Lon: 2.1272E

Elev: 359

StdP: 14.51

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	21.5	25.1	16.4	12.8	23.6	20.4	15.5	27.3	29.8	49.8	26.7	49.0	5.4	30	0.572

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.8	86.3	67.8	82.4	66.5	78.7	65.0	69.9	82.7	68.0	78.9	66.3	76.2	8.7	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
65.7	96.0	74.2	63.9	90.2	72.0	62.4	85.5	70.6	34.0	83.0	32.4	79.0	31.1	76.4	77.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.3	20.6	18.3	16.2	94.1	5.1	4.3	12.6	97.2	9.6	99.7	6.7	102.1	3.0	105.2
			15.5	73.4	5.1	1.8	11.8	74.7	8.8	75.7	5.9	76.8	2.2	78.1
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	51.4	39.0	40.1	44.6	49.1	55.1	60.9	65.0	64.6	59.1	53.0	45.1	39.9	(6)
(7)		DBStd	11.11	7.53	6.72	5.92	5.88	5.85	5.52	5.46	5.39	5.07	6.02	6.36	7.30	(7)
(8)		HDD50	1439	345	279	183	86	18	1	0	0	1	39	170	317	(8)
(9)		HDD65	5141	807	696	631	478	310	146	68	71	187	373	597	777	(9)
(10)		CDD50	1941	3	3	16	58	177	329	465	454	275	132	23	6	(10)
(11)		CDD65	167	0	0	0	0	4	24	68	60	10	1	0	0	(11)
(12)		CDH74	2039	0	0	0	9	76	329	800	688	129	8	0	0	(12)
(13)		CDH80	613	0	0	0	0	6	86	253	243	24	1	0	0	(13)
(14)	Wind	WSAvg	8.6	9.9	9.9	9.6	8.7	8.2	7.7	7.8	7.5	7.8	8.4	8.8	9.4	(14)
(15)	Precipitation	PrecAvg	28.9	2.6	2.2	2.0	2.0	2.4	2.4	2.5	2.4	2.1	2.6	2.6	3.2	(15)
(16)		PrecMax	40.5	6.3	4.6	7.0	4.8	6.3	5.8	5.4	4.4	5.1	6.8	5.0	7.8	(16)
(17)		PrecMin	20.6	0.2	0.4	0.3	0.4	0.3	0.5	0.7	0.4	0.2	0.7	0.7	1.1	(17)
(18)		PrecStd	5.0	1.3	1.2	1.4	1.2	1.3	1.2	1.2	1.3	1.4	1.3	1.1	1.6	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.8	58.7	66.6	75.1	80.3	87.6	91.8	93.2	83.4	73.9	62.3	56.8	(19)
(20)		MCWB	52.8	50.8	54.0	60.0	66.3	69.4	69.7	69.8	66.4	63.4	58.3	54.0	(20)	
(21)		2%	DB	53.9	54.3	61.8	70.1	76.0	82.0	86.1	86.7	77.6	68.3	58.7	54.6	(21)
(22)		MCWB	51.4	49.6	52.9	58.1	63.0	67.0	67.5	67.9	64.1	61.1	55.5	52.2	(22)	
(23)		5%	DB	51.4	51.9	57.6	64.7	71.9	77.4	82.2	81.8	73.0	64.6	56.5	52.7	(23)
(24)		MCWB	48.9	48.7	51.2	54.9	61.0	65.1	66.4	66.1	62.0	58.9	53.8	50.5	(24)	
(25)		10%	DB	49.3	50.0	54.7	60.7	67.7	73.3	78.2	77.0	69.5	62.1	54.4	50.4	(25)
(26)		MCWB	47.0	47.2	49.7	52.7	58.6	62.7	65.0	63.8	60.3	57.5	52.0	48.4	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	53.9	52.7	56.1	63.2	68.4	71.9	71.5	72.4	68.6	64.5	59.3	54.7	(27)
(28)		MCDB	55.5	56.4	62.3	73.1	78.0	83.8	86.8	87.2	78.8	71.1	61.6	56.1	(28)	
(29)		2%	WB	51.6	50.7	54.1	58.7	64.7	68.3	69.5	69.7	65.7	62.0	56.1	52.6	(29)
(30)		MCDB	53.5	53.3	59.5	67.4	73.4	78.9	83.0	82.3	74.5	67.2	58.2	54.3	(30)	
(31)		5%	WB	49.2	49.1	52.2	55.8	61.8	66.1	67.7	67.3	63.7	60.1	54.2	50.8	(31)
(32)		MCDB	51.0	51.5	57.0	63.3	69.6	75.8	78.9	78.1	70.6	63.9	56.2	52.6	(32)	
(33)		10%	WB	47.1	47.3	50.2	53.5	59.6	63.9	66.0	65.4	61.9	58.3	52.2	48.6	(33)
(34)		MCDB	48.9	49.8	54.0	59.5	66.6	71.6	75.8	74.7	67.8	61.3	54.3	50.3	(34)	
(35)	Mean Daily Temperature Range		MDBR	9.3	11.8	15.2	18.9	19.0	19.9	20.8	20.6	18.8	14.9	10.8	9.4	(35)
(36)		5% DB	MCDBR	9.9	14.2	21.5	26.0	26.6	27.9	29.0	29.4	25.0	18.4	11.7	9.7	(36)
(37)			MCWBR	8.6	10.8	13.8	15.4	14.8	14.7	12.8	12.6	12.9	11.8	9.1	8.5	(37)
(38)			5% WB	MCDBR	9.7	12.8	18.2	23.6	23.3	24.9	25.2	25.8	21.0	16.4	10.9	9.4
(39)		MCWBR		8.9	10.4	12.4	14.5	14.2	14.3	12.2	12.5	12.1	11.2	9.2	8.6	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.328	0.347	0.383	0.404	0.412	0.412	0.411	0.402	0.377	0.364	0.337	0.321	(40)	
(41)		taud	2.393	2.357	2.248	2.206	2.224	2.256	2.258	2.307	2.362	2.392	2.406	2.368	(41)	
(42)		Ebn at Noon	227	251	259	266	269	269	267	264	259	240	221	210	(42)	
(43)		Edh at Noon	21	27	36	42	43	42	41	37	32	26	21	19	(43)	
(44)	All-Sky Solar Radiation	RadAvg	279	515	883	1367	1604	1779	1691	1450	1120	656	332	231	(44)	
(45)		RadStd	31	76	108	157	153	170	141	135	85	56	33	33	(45)	

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (42 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page