

MEAUITE AP, France

WMO: 070590

Lat: 49.9719N

Lon: 2.7039E

Elev: 364

StdP: 14.50

Time Zone: 1.00 (EUC)

Period: 07-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	21.3	24.9	15.4	12.2	21.9	20.9	15.9	26.8	32.5	47.7	28.5	47.5	8.3	40	0.595

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.9	84.6	67.6	80.7	66.0	77.3	64.4	69.6	81.7	67.5	77.5	65.8	74.5	9.0	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.8	96.6	73.9	64.1	90.7	71.1	62.5	85.7	70.1	33.9	82.6	32.2	78.5	30.8	74.7	80.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 25.3	22.2	19.9	DB	18.2	93.7	6.0	3.9	13.9	96.5	10.4	98.8	7.1	101.0	2.7	103.8	(4)
(5)			WB	17.3	73.9	6.4	2.6	12.7	75.8	9.0	77.3	5.4	78.7	0.8	80.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	51.5	38.1	39.5	44.7	50.2	55.8	61.6	65.3	64.5	59.4	52.8	45.2	39.8	(6)
(7)		DBStd	11.28	7.21	6.62	5.74	6.13	6.16	5.51	5.41	4.98	4.79	6.02	5.97	7.03	(7)
(8)		HDD50	1455	372	296	180	69	13	0	0	0	0	39	166	320	(8)
(9)		HDD65	5116	835	715	629	444	293	135	61	69	179	379	595	782	(9)
(10)		CDD50	1988	1	1	16	76	191	347	475	449	282	126	21	3	(10)
(11)		CDD65	174	0	0	0	0	7	31	71	53	11	1	0	0	(11)
(12)		CDH74	1635	0	0	0	14	74	307	670	474	88	8	0	0	(12)
(13)		CDH80	433	0	0	0	0	5	65	202	145	15	1	0	0	(13)
(14)	Wind	WSAvg	9.8	10.9	11.0	11.2	9.5	9.2	8.9	8.7	8.5	8.8	9.3	10.4	11.1	(14)
(15)	Precipitation	PrecAvg	27.6	2.1	2.0	1.9	1.7	2.4	2.5	2.6	2.6	2.0	2.5	2.5	2.9	(15)
(16)		PrecMax	38.3	5.7	4.8	6.4	5.0	5.6	5.5	6.2	6.2	4.1	5.9	5.2	7.4	(16)
(17)		PrecMin	20.8	0.0	0.4	0.0	0.1	0.1	0.7	0.6	0.4	0.0	0.6	0.4	0.8	(17)
(18)		PrecStd	4.5	1.2	1.2	1.3	1.1	1.3	1.3	1.4	1.4	1.2	1.2	1.1	1.6	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.8	57.2	66.0	75.7	79.8	87.0	91.8	90.3	82.3	73.6	62.1	55.8	(19)
(20)			MCWB	52.2	49.6	53.1	59.2	65.7	68.8	70.9	69.7	66.1	62.8	59.0	53.6	(20)
(21)		2%	DB	52.5	52.2	61.2	71.2	75.6	80.8	84.8	84.1	75.6	67.9	58.6	53.7	(21)
(22)			MCWB	50.3	48.3	51.7	57.6	62.8	66.9	67.8	68.1	63.3	61.5	55.6	51.7	(22)
(23)		5%	DB	50.0	50.4	57.2	64.7	71.5	77.4	80.8	78.9	71.8	64.2	56.1	51.8	(23)
(24)			MCWB	48.1	47.6	50.5	55.0	60.9	64.9	65.9	64.9	61.7	59.0	53.8	49.6	(24)
(25)		10%	DB	48.0	48.6	53.6	60.9	67.6	73.3	77.1	75.0	68.4	61.0	53.8	49.8	(25)
(26)			MCWB	46.6	46.3	48.5	52.9	58.8	63.5	64.7	63.6	59.9	57.4	51.6	48.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	53.0	51.3	55.2	61.5	69.5	71.7	72.1	71.8	67.7	64.7	60.2	54.4	(27)
(28)			MCD B	54.5	55.2	61.0	72.6	78.3	82.6	87.4	86.5	77.6	70.5	61.8	55.6	(28)
(29)		2%	WB	50.8	49.6	53.0	58.1	64.2	68.4	69.6	68.5	64.8	61.9	56.1	51.9	(29)
(30)			MCD B	52.2	51.4	59.8	68.2	70.9	77.7	82.9	80.4	72.0	67.2	58.0	53.5	(30)
(31)		5%	WB	48.3	48.2	51.1	55.8	61.6	66.2	67.4	66.5	63.2	59.9	54.3	50.1	(31)
(32)			MCD B	49.6	50.3	56.3	63.7	69.1	75.2	77.8	76.0	69.7	63.4	56.4	51.4	(32)
(33)		10%	WB	46.3	46.3	49.4	53.8	59.7	63.9	65.5	64.9	61.6	58.1	52.1	48.1	(33)
(34)			MCD B	47.7	48.4	53.1	60.4	66.2	71.9	74.4	72.6	67.4	60.8	54.2	49.4	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	8.5	10.5	13.8	17.1	17.4	18.1	18.9	18.5	16.8	12.9	9.5	8.5	(35)
(36)			MCDBR	9.9	13.2	20.1	22.5	22.9	24.0	25.2	25.4	21.4	16.1	10.6	9.3	(36)
(37)			MCWBR	8.6	10.4	12.3	12.1	12.2	11.9	10.8	11.6	10.6	10.0	8.8	8.2	(37)
(38)		5% WB	MCDBR	9.2	12.4	17.1	20.5	19.0	21.8	22.5	21.4	17.9	14.3	10.1	9.1	(38)
(39)			MCWBR	8.5	10.2	11.4	11.6	11.2	12.2	10.8	11.0	9.9	9.6	8.8	8.7	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.324	0.344	0.379	0.404	0.412	0.412	0.411	0.402	0.377	0.361	0.334	0.318	(40)	
(41)		taud	2.400	2.367	2.256	2.201	2.220	2.247	2.250	2.300	2.357	2.403	2.410	2.376	(41)	
(42)		Ebn at Noon	226	251	259	266	268	269	267	264	258	240	219	208	(42)	
(43)		Edh at Noon	21	27	36	42	43	42	41	37	32	26	20	18	(43)	
(44)	All-Sky Solar Radiation	RadAvg	270	497	869	1363	1594	1755	1665	1424	1095	644	318	217	(44)	
(45)		RadStd	30	87	112	155	153	164	158	140	87	54	33	31	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (57 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page