

MEAUITE AP, France

WMO: 070590

Lat: 49.9719N

Lon: 2.7039E

Elev: 111

StdP: 100.00

Time Zone: 1.00 (EUC)

Period: 07-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-5.9	-4.0	-9.2	1.7	-5.6	-6.2	2.3	-2.9	14.5	8.7	12.7	8.6	3.7	40	0.595

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.5	29.2	19.8	27.0	18.9	25.2	18.0	20.9	27.6	19.7	25.3	18.8	23.6	4.0	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.8	13.8	23.3	17.8	13.0	21.7	16.9	12.2	21.2	60.9	28.1	57.0	25.8	53.7	23.7	26.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.3	9.9	8.9	-7.6	34.3	3.3	2.2	-10.0	35.8	-12.0	37.1	-13.9	38.3	-16.3	39.9		
(5)			-8.2	23.3	3.5	1.4	-10.7	24.3	-12.8	25.2	-14.8	26.0	-17.3	27.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	10.8	3.4	4.1	7.1	10.1	13.2	16.4	18.5	18.0	15.2	11.6	7.3	4.3
	DBStd	6.26	4.01	3.68	3.19	3.41	3.42	3.06	3.00	2.77	2.66	3.34	3.32	3.91
	HDD10.0	808	207	164	100	38	7	0	0	0	0	22	92	178
	HDD18.3	2842	464	397	349	247	163	75	34	38	99	211	331	434
	CDD10.0	1104	1	1	9	42	106	193	264	249	157	70	12	2
	CDD18.3	97	0	0	0	0	4	17	39	29	6	1	0	0
	CDH23.3	908	0	0	0	8	41	171	372	263	49	4	0	0
	CDH26.7	241	0	0	0	0	3	36	112	81	8	1	0	0
Wind	WSAvg	4.4	4.9	4.9	5.0	4.3	4.1	4.0	3.9	3.8	4.0	4.2	4.7	5.0
Precipitation	PrecAvg	701	54	51	47	44	60	63	67	65	50	63	63	73
	PrecMax	972	144	122	163	127	143	140	157	158	105	151	131	188
	PrecMin	528	1	9	1	2	2	18	16	10	1	14	10	20
	PrecStd	114	30	31	33	29	33	33	35	35	30	30	28	40
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.7	14.0	18.9	24.3	26.6	30.5	33.2	32.4	27.9	23.1	16.7	13.2
		MCWB	11.2	9.8	11.7	15.1	18.7	20.5	21.6	20.9	19.0	17.1	15.0	12.0
	2%	DB	11.4	11.2	16.2	21.8	24.2	27.1	29.4	28.9	24.2	20.0	14.8	12.0
		MCWB	10.2	9.0	11.0	14.2	17.1	19.4	19.9	20.0	17.4	16.4	13.1	10.9
	5%	DB	10.0	10.2	14.0	18.2	21.9	25.2	27.1	26.1	22.1	17.9	13.4	11.0
		MCWB	8.9	8.7	10.3	12.8	16.1	18.3	18.9	18.3	16.5	15.0	12.1	9.8
	10%	DB	8.9	9.2	12.0	16.0	19.8	22.9	25.1	23.9	20.2	16.1	12.1	9.9
		MCWB	8.1	8.0	9.2	11.6	14.9	17.5	18.2	17.6	15.5	14.1	10.9	9.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.6	10.7	12.9	16.4	20.8	22.0	22.3	22.1	19.8	18.2	15.7	12.5
		MCDB	12.5	12.9	16.1	22.6	25.7	28.1	30.8	30.3	25.3	21.4	16.5	13.1
	2%	WB	10.4	9.8	11.7	14.5	17.9	20.2	20.9	20.3	18.2	16.6	13.4	11.1
		MCDB	11.2	10.8	15.5	20.1	21.6	25.4	28.3	26.9	22.2	19.5	14.5	11.9
	5%	WB	9.0	9.0	10.6	13.2	16.5	19.0	19.7	19.2	17.3	15.5	12.4	10.1
		MCDB	9.8	10.1	13.5	17.6	20.6	24.0	25.5	24.5	20.9	17.4	13.5	10.8
	10%	WB	8.0	7.9	9.6	12.1	15.4	17.7	18.6	18.3	16.5	14.5	11.2	9.0
		MCDB	8.7	9.1	11.7	15.8	19.0	22.2	23.5	22.6	19.7	16.0	12.3	9.6
Mean Daily Temperature Range	5% DB	MDBR	4.7	5.9	7.7	9.5	9.7	10.1	10.5	10.3	9.3	7.2	5.3	4.7
		MCDBR	5.5	7.3	11.2	12.5	12.7	13.3	14.0	14.1	11.9	9.0	5.9	5.2
		MCWBR	4.8	5.8	6.8	6.7	6.8	6.6	6.0	6.4	5.9	5.5	4.9	4.6
	5% WB	MCDBR	5.1	6.9	9.5	11.4	10.5	12.1	12.5	11.9	9.9	8.0	5.6	5.1
		MCWBR	4.7	5.7	6.4	6.5	6.2	6.8	6.0	6.1	5.5	5.4	4.9	4.8
Clear-Sky Solar Irradiance	taub	0.324	0.344	0.379	0.404	0.412	0.412	0.411	0.402	0.377	0.361	0.334	0.318	
	taud	2.400	2.367	2.256	2.201	2.220	2.247	2.250	2.300	2.357	2.403	2.410	2.376	
	Ebn at Noon	713	790	818	837	846	848	841	831	814	758	691	657	
	Edh at Noon	65	85	112	131	134	132	129	118	100	81	64	58	
All-Sky Solar Radiation	RadAvg	0.85	1.57	2.74	4.30	5.02	5.53	5.25	4.49	3.45	2.03	1.00	0.69	
	RadStd	0.09	0.27	0.35	0.49	0.48	0.52	0.50	0.44	0.28	0.17	0.10	0.10	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (57 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page