

METZ NANCY LORRAINE AP, France

WMO: 070930

Lat: 48.979N

Lon: 6.243E

Elev: 265

StdP: 98.18

Time Zone: 1.00 (EUC)

Period: 99-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-7.9	-5.7	-11.2	1.5	-5.8	-8.9	1.8	-4.2	16.4	5.7	14.0	5.8	3.6	50	0.582

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.8	31.3	19.8	29.1	19.1	27.1	18.4	20.8	28.6	20.0	27.2	19.2	25.6	3.9	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.4	13.7	23.1	17.7	13.1	22.3	16.9	12.5	21.4	61.0	28.7	58.3	27.4	55.7	25.6	24.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
13.0	10.4	9.2	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
			-10.7	34.7	2.8	2.4	-12.7	36.4	-14.4	37.8	-16.0	39.1	-18.0	40.9		
			-11.1	22.5	2.8	0.8	-13.1	23.1	-14.8	23.5	-16.4	23.9	-18.4	24.5		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	10.6	2.0	3.1	6.4	10.2	13.9	17.4	19.5	19.0	15.3	11.2	6.1	3.1	(6)
(7)		DBStd	7.21	4.32	4.06	3.82	3.73	3.57	3.62	3.56	3.41	3.19	3.69	3.71	4.17	(7)
(8)		HDD10.0	986	248	195	120	43	7	0	0	0	1	31	124	217	(8)
(9)		HDD18.3	2975	506	428	368	246	144	60	29	31	101	223	366	473	(9)
(10)		CDD10.0	1219	1	1	9	48	127	223	294	280	161	67	8	1	(10)
(11)		CDD18.3	166	0	0	0	0	6	33	64	52	11	1	0	0	(11)
(12)		CDH23.3	1672	0	0	0	9	70	333	659	500	98	3	0	0	(12)
(13)		CDH26.7	542	0	0	0	0	11	98	236	181	16	0	0	0	(13)
(14)	Wind	WSAvg	4.3	5.0	5.1	5.0	4.2	3.8	3.6	3.8	3.7	3.8	4.3	4.5	5.0	(14)
(15)	Precipitation	PrecAvg	746	58	58	52	47	67	60	66	69	56	69	71	72	(15)
(16)		PrecMax	955	128	136	150	113	124	143	165	159	107	173	173	200	(16)
(17)		PrecMin	559	12	13	14	3	34	26	19	20	23	16	13	9	(17)
(18)		PrecStd	112	26	33	33	31	25	29	32	36	28	38	36	43	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.2	14.5	19.8	24.6	28.4	32.5	34.5	35.2	28.8	23.4	16.6	13.0	(19)
(20)		MCWB	10.5	9.4	11.5	15.4	19.6	20.5	20.2	20.4	18.6	16.5	13.6	10.8	(20)	
(21)		2%	DB	10.9	11.8	17.1	22.1	25.2	29.5	31.3	31.0	26.2	20.5	14.2	11.5	(21)
(22)		MCWB	9.6	8.5	10.4	13.9	17.1	19.8	19.5	20.0	17.9	15.8	12.0	9.9	(22)	
(23)		5%	DB	9.3	10.1	14.5	19.5	23.2	27.0	29.2	28.2	23.8	18.2	12.9	10.2	(23)
(24)		MCWB	8.1	8.0	9.6	12.8	16.2	18.7	19.1	18.9	17.0	14.8	11.2	8.9	(24)	
(25)		10%	DB	8.0	8.6	12.3	17.2	21.1	24.9	27.2	25.9	21.4	16.3	11.4	8.8	(25)
(26)		MCWB	6.9	7.0	8.9	11.7	15.2	17.9	18.2	18.0	15.9	13.8	10.0	7.8	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.2	10.3	12.8	16.5	20.4	22.2	21.5	21.7	19.7	17.7	14.1	11.5	(27)
(28)		MCDWB	12.0	12.8	17.5	22.9	26.8	29.4	29.9	30.8	26.2	21.2	15.6	12.4	(28)	
(29)		2%	WB	9.7	9.2	11.5	14.7	18.6	20.7	20.5	20.5	18.6	16.3	12.5	10.2	(29)
(30)		MCDWB	10.8	11.1	14.9	20.6	23.8	27.0	29.2	28.4	24.5	19.4	13.9	11.3	(30)	
(31)		5%	WB	8.2	8.1	10.4	13.3	16.9	19.7	19.7	19.7	17.6	15.1	11.3	9.0	(31)
(32)		MCDWB	9.2	9.8	13.5	18.4	21.5	25.6	27.6	26.5	22.5	17.9	12.8	10.0	(32)	
(33)		10%	WB	6.9	7.1	9.3	12.2	15.7	18.6	18.8	18.8	16.6	14.1	10.1	7.8	(33)
(34)		MCDWB	7.8	8.6	12.1	16.5	19.9	23.9	25.6	24.5	20.5	16.2	11.3	8.8	(34)	
(35)	Mean Daily Temperature Range	MDBR	4.9	6.3	8.6	10.1	10.4	11.1	10.8	10.5	9.8	7.8	5.4	4.7	(35)	
(36)		5% DB	MCDBR	5.6	9.0	12.7	14.0	13.7	14.6	14.6	15.0	13.5	10.3	7.1	5.5	(36)
(37)		MCWBR	4.7	6.2	7.4	7.4	7.1	6.7	5.5	5.9	6.4	6.0	5.2	4.5	(37)	
(38)		5% WB	MCDBR	5.5	7.4	10.2	12.6	12.1	13.2	13.2	12.6	11.9	9.4	6.6	5.2	(38)
(39)		MCWBR	4.9	5.6	6.5	7.0	6.8	6.6	5.5	5.7	6.3	5.9	5.1	4.4	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.309	0.333	0.360	0.389	0.399	0.403	0.399	0.395	0.370	0.355	0.326	0.306	(40)	
(41)		taud	2.444	2.396	2.331	2.267	2.272	2.292	2.297	2.334	2.383	2.419	2.442	2.427	(41)	
(42)		Ebn at Noon	754	814	848	857	861	858	856	842	828	776	721	702	(42)	
(43)		Edh at Noon	64	84	105	124	128	127	124	114	99	81	64	57	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.87	1.61	2.83	4.29	5.08	5.74	5.40	4.65	3.54	2.07	0.99	0.69	(44)	
(45)		RadStd	0.13	0.29	0.42	0.56	0.56	0.50	0.53	0.49	0.38	0.17	0.10	0.12	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	-0.34	N/A	N/A	N/A	N/A
(47)	Regional (47 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page