

OUESSANT-STIFF, France

WMO: 071000

Lat: 48.4733N

Lon: 5.0569W

Elev: 68

StdP: 100.51

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	2.4	3.7	-2.7	3.0	4.0	-1.3	3.4	4.8	22.3	8.5	20.3	8.6	10.3	100	0.800

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	4.7	20.9	17.6	19.8	17.1	19.0	16.6	18.3	19.8	17.7	19.0	17.2	18.4	5.4	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
17.7	12.8	18.8	17.1	12.3	18.3	16.6	11.9	17.8	52.0	19.9	50.1	19.1	48.4	18.4	22.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.5	16.5	14.8	0.5	23.8	2.1	1.7	-1.1	25.0	-2.3	26.0	-3.5	27.0	-5.1	28.2
			-1.1	19.8	2.0	0.9	-2.5	20.4	-3.6	21.0	-4.7	21.5	-6.1	22.2
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	12.3	8.8	8.4	9.3	10.4	12.5	14.6	16.3	16.6	15.5	13.7	11.3	9.4		
	DBStd	3.39	2.24	2.09	1.84	1.66	1.53	1.45	1.31	1.09	1.36	1.65	1.85	2.28		
	HDD10.0	192	48	49	34	13	1	0	0	0	0	1	8	37		
	HDD18.3	2222	297	278	282	237	182	112	64	54	86	143	212	277		
	CDD10.0	1016	9	5	11	26	77	139	196	205	165	116	47	19		
	CDD18.3	4	0	0	0	0	0	1	2	1	1	0	0	0		
	CDH23.3	6	0	0	0	0	0	1	3	2	1	0	0	0		
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0		
(14) Wind	WSAvg	7.8	9.8	9.3	8.6	7.8	7.0	6.3	6.0	5.8	6.3	7.6	9.2	9.8		
(15) Precipitation	PrecAvg	756	93	75	52	55	47	39	47	48	48	77	89	85		
	PrecMax	1019	191	189	124	136	113	94	112	130	126	110	189	153		
	PrecMin	530	17	11	9	7	5	9	6	3	5	16	16	10		
	PrecStd	118	45	40	29	35	30	24	29	33	31	25	45	39		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.2	13.0	14.6	17.0	18.9	21.6	22.5	22.2	21.5	18.6	16.0	14.2		
		MCWB	12.2	11.4	11.8	13.2	15.6	17.5	18.3	18.2	17.7	16.3	14.7	13.1		
	2%	DB	12.6	12.1	12.9	14.6	16.6	19.3	20.8	20.5	19.6	17.4	15.1	13.6		
		MCWB	11.8	11.1	11.1	12.1	14.3	16.4	17.5	17.7	17.1	15.7	13.9	12.8		
	5%	DB	12.1	11.6	12.2	13.6	15.6	18.0	19.7	19.6	18.6	16.6	14.5	13.1		
		MCWB	11.4	10.7	10.7	11.6	13.5	15.7	16.9	17.1	16.4	15.3	13.4	12.4		
	10%	DB	11.6	11.1	11.6	12.8	14.8	17.1	18.8	18.9	17.7	16.0	13.9	12.5		
		MCWB	10.8	10.3	10.3	11.0	12.9	15.1	16.5	16.6	15.9	14.8	12.9	11.8		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.7	12.1	12.4	13.8	16.0	18.0	19.1	19.4	18.7	17.1	15.3	13.7		
		MCDB	12.8	12.4	13.5	15.8	18.0	20.4	21.4	20.9	20.2	17.9	15.5	13.8		
	2%	WB	12.2	11.5	11.7	12.7	14.6	16.8	18.1	18.4	17.7	16.2	14.3	13.2		
		MCDB	12.4	11.8	12.5	14.1	16.1	18.6	19.8	19.6	18.9	16.9	14.7	13.4		
	5%	WB	11.6	11.0	11.2	12.0	13.9	16.1	17.5	17.8	17.0	15.7	13.8	12.6		
		MCDB	12.0	11.4	11.8	13.1	15.1	17.5	19.0	18.8	17.9	16.3	14.3	13.0		
	10%	WB	11.0	10.5	10.7	11.4	13.3	15.4	16.9	17.2	16.4	15.2	13.1	12.0		
		MCDB	11.5	11.0	11.3	12.4	14.5	16.7	18.2	18.2	17.3	15.7	13.8	12.5		
(35) Mean Daily Temperature Range	5% DB	MDBR	2.9	3.3	3.6	4.2	4.3	4.5	4.7	4.7	4.4	3.6	2.9	3.0		
		MCDBR	3.0	3.5	4.2	5.2	5.3	5.9	5.9	5.7	5.5	4.1	3.3	2.8		
	5% WB	MCWBR	3.4	3.3	3.4	3.6	3.7	3.9	3.7	3.7	3.6	3.2	3.2	3.3		
		MCWBR	3.0	3.2	3.7	4.7	4.9	5.4	5.4	5.0	5.0	3.7	3.0	2.8		
(40) Clear-Sky Solar Irradiance	taub		0.340	0.353	0.379	0.384	0.387	0.379	0.382	0.371	0.363	0.360	0.340	0.332		
	taud		2.391	2.385	2.337	2.348	2.384	2.435	2.432	2.484	2.487	2.464	2.424	2.358		
	Ebn at Noon		714	794	831	865	875	883	874	870	843	778	709	665		
	Edh at Noon		69	86	105	115	115	110	109	99	90	79	66	63		
(44) All-Sky Solar Radiation	RadAvg		0.96	1.76	2.95	4.64	5.51	5.95	5.65	4.84	3.86	2.27	1.20	0.80		
	RadStd		0.07	0.18	0.30	0.38	0.48	0.62	0.31	0.40	0.28	0.17	0.09	0.10		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (21 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page