

LANDIVISIAU AP, France

WMO: 071060

Lat: 48.5256N

Lon: 4.1472W

Elev: 106

StdP: 100.06

Time Zone: 1.00 (EUC)

Period: 99-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-0.9	0.3	-4.4	2.7	0.7	-2.7	3.1	1.9	15.0	9.0	13.5	9.4	3.4	70	0.613

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.6	25.4	18.6	23.2	17.6	21.6	16.9	19.4	23.7	18.5	21.6	17.7	20.2	4.5	40

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.1	13.2	20.4	17.3	12.5	19.5	16.7	12.0	18.8	55.8	24.1	52.7	21.7	50.3	20.3	25.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12.3	11.0	9.7	-3.4	29.4	1.8	2.4	-4.7	31.1	-5.7	32.5	-6.8	33.8	-8.1	35.5
			-4.1	21.5	1.9	1.5	-5.4	22.5	-6.5	23.4	-7.6	24.2	-8.9	25.3
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	11.4	6.9	6.7	8.1	9.7	12.3	15.0	16.7	16.3	15.3	12.6	9.4	7.5
	DBStd	4.44	2.78	2.83	2.75	2.68	2.55	2.44	2.21	2.00	2.46	2.68	2.53	2.94
	HDD10.0	442	101	95	71	36	7	0	0	0	1	7	39	86
	HDD18.3	2553	356	324	317	258	187	105	61	68	98	178	267	336
	CDD10.0	957	3	4	12	28	79	149	208	196	158	88	23	9
	CDD18.3	26	0	0	0	0	1	4	9	6	5	1	0	0
	CDH23.3	182	0	0	0	2	9	45	67	33	23	3	0	0
	CDH26.7	34	0	0	0	0	1	11	14	5	2	1	0	0
(14) Wind	WSAvg	4.7	5.4	5.3	5.1	4.8	4.5	4.2	4.2	4.1	4.0	4.4	4.9	5.3
(15) Precipitation	PrecAvg	1037	124	104	66	81	67	54	58	60	62	105	125	131
	PrecMax	1267	251	216	180	189	136	130	123	144	153	185	257	267
	PrecMin	788	26	17	10	18	13	7	14	14	7	20	35	20
	PrecStd	118	58	54	39	44	34	33	30	37	38	35	54	63
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.1	15.4	18.9	22.5	24.4	28.4	28.5	27.1	26.2	21.5	16.9	14.4
		MCWB	12.2	11.1	12.6	14.1	17.5	20.6	20.3	18.9	18.6	17.1	14.4	12.7
	2%	DB	12.4	12.5	15.3	18.5	20.5	23.8	25.0	23.4	23.3	19.1	15.3	13.6
		MCWB	11.6	10.4	11.1	13.1	15.5	17.8	18.5	18.2	17.9	16.0	13.8	12.4
	5%	DB	11.8	11.7	13.2	15.8	18.6	21.5	22.9	21.3	21.0	17.6	14.2	12.7
		MCWB	11.0	10.4	10.7	11.9	14.6	16.8	17.5	17.2	16.8	15.3	12.9	11.9
	10%	DB	11.1	10.9	12.0	13.9	16.8	19.6	21.0	19.9	19.3	16.6	13.3	12.0
		MCWB	10.3	9.9	10.3	10.8	13.5	15.8	16.7	16.4	16.2	14.8	12.2	11.1
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.7	12.2	13.2	15.3	18.0	20.7	20.7	20.4	20.0	17.7	15.5	13.5
		MCDB	12.9	13.6	17.2	20.1	22.6	26.6	26.6	25.1	24.8	19.9	16.2	13.8
	2%	WB	12.0	11.4	12.1	13.5	16.1	18.6	19.2	18.9	18.7	16.8	14.1	12.7
		MCDB	12.3	12.1	13.9	17.5	19.7	22.6	23.6	21.7	21.6	18.3	14.9	13.3
	5%	WB	11.2	10.7	11.3	12.3	15.0	17.3	18.2	18.1	17.7	16.0	13.2	12.1
		MCDB	11.6	11.4	12.7	15.0	17.9	20.6	21.5	20.1	19.8	17.3	14.1	12.7
	10%	WB	10.5	10.0	10.6	11.4	13.9	16.2	17.3	17.3	16.8	15.1	12.3	11.3
		MCDB	11.0	10.9	11.9	13.5	16.1	18.9	20.0	19.1	18.6	16.3	13.2	12.0
(35) Mean Daily Temperature Range	5% DB	MDBR	5.0	5.5	6.3	7.4	7.6	7.7	7.6	7.4	7.7	6.6	5.4	5.0
		MCDBR	5.1	6.3	8.2	10.6	10.4	11.3	11.0	9.8	10.0	7.5	5.9	5.0
		MCWBR	4.8	4.9	5.4	6.2	6.2	6.4	5.6	5.5	5.5	4.8	4.8	4.7
	5% WB	MCDBR	4.7	5.4	7.0	9.2	9.3	10.0	9.4	8.2	8.6	6.4	5.7	4.8
		MCWBR	4.9	4.9	5.1	5.7	5.9	6.1	5.4	5.2	5.3	4.6	5.1	4.9
(40) Clear-Sky Solar Irradiance	taub		0.332	0.347	0.372	0.381	0.385	0.378	0.378	0.367	0.357	0.354	0.334	0.325
	taud		2.396	2.377	2.318	2.312	2.344	2.388	2.391	2.442	2.454	2.454	2.426	2.364
	Ebn at Noon		724	801	837	867	877	883	877	873	847	784	716	674
	Edh at Noon		68	86	107	119	119	115	113	103	93	79	66	62
(44) All-Sky Solar Radiation	RadAvg		0.96	1.75	2.90	4.52	5.36	5.83	5.54	4.74	3.77	2.21	1.19	0.80
	RadStd		0.07	0.19	0.30	0.39	0.46	0.62	0.32	0.39	0.27	0.17	0.10	0.10

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (24 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page