

CHARTRES CHAMPOL AP, France

WMO: 071430

Lat: 48.4603N

Lon: 1.5011E

Elev: 156

StdP: 99.46

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-5.4	-3.5	-8.6	1.8	-3.3	-6.4	2.2	-2.3	10.3	8.8	9.1	8.9	2.4	10	0.513

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.0	31.1	19.7	28.9	19.0	26.8	18.2	21.0	28.5	20.0	26.7	19.0	25.1	3.3	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.6	13.7	23.1	17.6	12.9	22.3	16.7	12.1	21.3	61.2	28.6	57.7	26.8	54.6	25.0	24.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.1	7.1	6.3	-8.9	34.8	3.8	2.5	-11.7	36.6	-13.9	38.1	-16.0	39.4	-18.8	41.2		
(5)			-9.2	22.6	3.8	1.1	-12.0	23.4	-14.2	24.1	-16.3	24.7	-19.1	25.5	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	11.3	4.1	4.8	7.6	10.1	13.6	17.0	19.3	19.1	15.6	12.1	7.5	4.6	(6)	(7)
	DBStd	6.37	4.05	3.75	3.26	3.32	3.17	3.13	3.13	3.00	2.79	3.38	3.36	3.92	(7)	(8)
	HDD10.0	736	183	148	89	37	6	0	0	0	0	18	87	169	(8)	(9)
	HDD18.3	2692	440	379	334	246	149	62	26	25	89	193	324	424	(9)	(10)
	CDD10.0	1224	2	1	13	41	118	211	288	282	169	84	13	3	(10)	(11)
	CDD18.3	138	0	0	0	0	3	22	55	48	8	1	0	0	(11)	(12)
	CDH23.3	1512	0	0	0	9	47	249	579	516	105	7	0	0	(12)	(13)
	CDH26.7	489	0	0	0	0	3	69	201	193	24	1	0	0	(13)	(14)
(14) Wind	WSAvg	3.1	3.5	3.5	3.4	3.2	3.0	2.9	2.9	2.7	2.7	2.9	3.2	3.4	(14)	(15)
(15) Precipitation	PrecAvg	620	51	44	42	48	57	52	54	49	46	61	57	59	(15)	(16)
	PrecMax	856	103	95	122	125	138	103	163	103	118	140	105	142	(16)	(17)
	PrecMin	429	7	3	8	5	11	6	18	9	6	19	19	16	(17)	(18)
	PrecStd	105	23	23	27	30	28	24	32	27	29	30	22	27	(18)	(19)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.2	15.4	20.1	24.7	26.8	31.9	34.2	35.7	29.4	24.0	16.7	13.6	(19)	(20)
		MCWB	11.5	10.3	12.2	15.8	18.9	21.4	20.7	21.0	18.2	17.2	14.7	12.2	(20)	(21)
	2%	DB	12.0	12.5	17.3	21.8	24.7	28.7	31.0	31.3	26.4	21.1	15.0	12.5	(21)	(22)
		MCWB	10.6	9.8	11.5	14.6	17.0	19.6	19.5	19.5	17.5	16.2	13.3	11.2	(22)	(23)
	5%	DB	10.8	11.2	14.9	19.0	22.4	26.1	28.8	28.6	23.8	18.7	13.5	11.4	(23)	(24)
		MCWB	9.5	9.2	10.6	12.8	16.0	18.5	19.0	18.9	16.6	15.0	12.0	10.2	(24)	(25)
	10%	DB	9.5	10.1	13.0	16.5	20.3	24.0	26.7	26.1	21.7	17.0	12.4	10.2	(25)	(26)
		MCWB	8.3	8.5	10.0	11.5	14.8	17.3	18.2	17.9	15.7	14.2	11.0	9.1	(26)	(27)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.1	11.5	13.7	16.8	20.0	22.5	21.7	22.1	19.8	18.1	15.3	12.6	(27)	(28)
		MCDB	13.0	13.4	18.0	23.1	25.0	29.2	30.9	31.8	26.3	21.9	16.3	13.3	(28)	(29)
	2%	WB	10.8	10.4	12.2	14.8	18.1	20.6	20.7	20.8	18.5	16.7	13.5	11.4	(29)	(30)
		MCDB	11.7	12.0	15.4	20.4	22.9	26.7	28.8	28.4	24.2	19.8	14.6	12.3	(30)	(31)
	5%	WB	9.6	9.5	11.3	13.4	16.6	19.3	19.7	19.6	17.4	15.7	12.3	10.4	(31)	(32)
		MCDB	10.6	10.9	14.1	17.9	21.2	24.6	26.9	26.3	22.4	18.2	13.3	11.3	(32)	(33)
	10%	WB	8.5	8.5	10.3	12.1	15.3	18.1	18.8	18.6	16.5	14.7	11.2	9.3	(33)	(34)
		MCDB	9.4	9.9	12.7	15.8	19.4	23.0	25.0	24.5	20.3	16.6	12.2	10.1	(34)	(35)
(35) Mean Daily Temperature Range	5% DB	MDBR	5.0	6.5	8.5	10.2	9.9	10.5	11.0	11.2	10.5	8.2	5.9	5.0	(35)	(36)
		MCDBR	5.6	8.1	12.3	14.4	13.5	14.4	15.3	16.1	14.6	10.5	6.7	5.3	(36)	(37)
	5% WB	MCWBR	4.7	5.9	7.3	7.7	7.1	6.8	5.8	6.1	6.8	6.2	5.1	4.6	(37)	(38)
		MCDWR	5.4	7.3	9.9	12.9	12.0	12.7	13.1	13.2	11.8	9.1	6.0	5.2	(38)	(39)
(39) Clear-Sky Solar Irradiance	taub	taub	0.322	0.342	0.373	0.397	0.403	0.407	0.404	0.394	0.368	0.359	0.333	0.317	(39)	(40)
		taud	2.425	2.379	2.287	2.223	2.246	2.272	2.275	2.323	2.380	2.409	2.432	2.397	(40)	(41)
	Edn at Noon	Edn at Noon	742	807	835	850	859	856	852	845	833	775	719	691	(41)	(42)
		Edh at Noon	66	86	110	130	132	129	127	116	100	83	66	60	(42)	(43)
(43) All-Sky Solar Radiation	RadAvg	RadAvg	0.95	1.74	2.89	4.37	5.15	5.76	5.47	4.77	3.72	2.17	1.16	0.81	(43)	(44)
	RadStd	RadStd	0.10	0.23	0.37	0.49	0.45	0.57	0.41	0.46	0.28	0.19	0.11	0.11	(44)	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (38 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page