

PARIS ONLY AP, France

WMO: 071490

Lat: 48.7167N

Lon: 2.3844E

Elev: 291

StdP: 14.54

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	23.5	26.6	16.1	12.5	28.1	20.1	15.2	29.4	29.5	49.8	26.1	48.6	6.2	30	0.531

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.4	88.6	68.4	84.7	67.0	81.3	65.7	70.4	84.2	68.7	80.9	67.1	78.2	8.0	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.2	97.5	74.9	64.4	91.6	73.3	62.8	86.5	71.9	34.5	84.3	33.0	81.3	31.7	78.1	78.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 22.6	19.7	17.4	DB	18.6	95.6	4.4	3.9	15.4	98.4	12.9	100.6	10.4	102.8	7.2	105.6	(4)
(5)			WB	17.6	73.8	4.5	1.8	14.4	75.1	11.8	76.1	9.3	77.2	6.0	78.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	53.6	40.1	41.4	46.6	51.8	58.4	64.6	68.4	67.8	61.3	54.7	46.2	41.1		
	DBStd	11.86	7.26	6.66	6.01	6.18	6.02	5.92	5.91	5.68	5.12	6.13	6.37	6.92		
	HDD50	1206	313	246	137	49	5	0	0	0	0	26	145	285		
	HDD65	4521	773	662	569	397	219	79	30	31	134	321	564	742		
	CDD50	2523	4	4	33	104	266	438	572	553	339	172	30	8		
	CDD65	363	0	0	0	1	15	67	137	118	23	2	0	0		
	CDH74	3283	0	0	0	29	151	606	1230	1065	187	15	0	0		
	CDH80	1048	0	0	0	1	19	177	415	396	39	1	0	0		
(14) Wind	WSAvg	8.5	9.3	9.5	9.2	8.8	8.5	8.3	8.1	7.3	7.5	7.8	8.2	9.1		
(15) Precipitation	PrecAvg	25.0	1.9	1.8	1.7	1.9	2.4	2.2	2.2	2.2	1.9	2.2	2.2	2.3		
	PrecMax	34.6	4.6	3.4	4.7	4.8	6.5	4.8	6.9	5.0	4.0	5.1	4.2	6.0		
	PrecMin	18.5	0.2	0.2	0.3	0.2	0.1	0.2	0.7	0.2	0.0	0.7	0.4	0.7		
	PrecStd	4.1	0.9	0.9	1.0	1.2	1.3	1.1	1.4	1.1	1.1	1.1	0.9	1.1		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	56.8	60.4	68.9	77.5	82.6	90.2	94.3	96.4	84.6	76.3	63.5	57.4		
		MCWB	53.4	50.4	54.4	60.8	66.1	70.0	70.2	70.8	66.6	63.3	57.9	54.1		
	2%	DB	54.3	55.3	64.0	72.8	78.2	85.0	88.2	88.9	79.3	70.8	60.0	55.2		
		MCWB	51.5	49.6	52.7	57.8	62.9	67.7	68.2	68.3	64.1	61.8	56.2	52.4		
	5%	DB	52.1	53.0	59.9	67.4	74.4	80.7	84.6	84.1	74.7	66.6	57.4	53.2		
		MCWB	49.3	48.9	51.4	55.3	61.0	65.9	66.9	66.8	62.7	59.6	54.2	50.8		
	10%	DB	49.9	51.0	56.6	63.2	70.3	76.8	81.0	79.8	71.2	63.6	55.2	51.1		
		MCWB	47.4	47.6	50.2	53.1	59.3	63.9	65.7	65.0	60.7	58.1	52.3	48.8		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	54.2	52.9	56.6	62.3	67.9	72.9	72.0	72.6	68.3	64.8	59.5	54.9		
		MCDB	56.2	56.6	63.7	75.1	79.7	86.6	88.4	88.4	80.0	72.3	61.7	56.7		
	2%	WB	52.0	51.0	54.5	58.7	64.7	69.6	70.1	70.2	65.9	62.7	56.7	52.9		
		MCDB	54.0	54.1	60.9	69.3	75.3	80.4	84.4	84.0	75.2	69.0	59.4	54.7		
	5%	WB	49.7	49.6	52.8	56.2	62.3	67.2	68.4	68.3	64.1	60.8	54.6	51.1		
		MCDB	51.6	52.3	58.1	65.1	71.3	77.8	81.0	80.0	72.2	65.4	57.0	53.0		
	10%	WB	47.6	47.8	50.9	54.1	60.2	65.2	66.8	66.5	62.4	59.1	52.6	49.0		
		MCDB	49.5	50.7	55.9	61.6	68.6	74.9	78.3	77.0	69.3	63.0	55.0	50.8		
(35) Mean Daily Temperature Range	5% DB	MDBR	9.0	11.4	14.7	16.7	16.9	17.7	18.4	18.8	17.5	14.1	10.3	8.9		
		MCDBR	10.1	14.4	20.7	23.6	23.2	24.2	24.3	25.9	23.3	17.9	11.8	9.2		
	5% WB	MCWBR	8.4	10.0	11.9	11.8	11.0	10.6	9.0	9.8	10.4	10.1	8.5	7.8		
		MCWBR	9.7	12.2	16.5	20.6	20.3	21.1	21.2	22.3	19.2	15.9	10.7	8.9		
(40) Clear-Sky Solar Irradiance	taub		0.336	0.357	0.392	0.411	0.417	0.420	0.419	0.408	0.381	0.375	0.347	0.331		
		taud	2.383	2.333	2.231	2.201	2.222	2.251	2.249	2.301	2.365	2.363	2.388	2.356		
	Ebn at Noon		226	248	257	265	268	267	266	263	259	238	220	210		
		Edn at Noon	22	29	37	42	43	42	42	38	32	27	22	20		
(44) All-Sky Solar Radiation	RadAvg		289	539	917	1386	1635	1823	1724	1502	1156	686	350	242		
	RadStd		34	78	113	157	161	167	144	147	100	54	34	39		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (36 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page