

PARIS LE BOURGET AP, France

WMO: 071500

Lat: 48.9675N

Lon: 2.4275E

Elev: 218

StdP: 14.58

Time Zone: 1.00 (EUC)

Period: 99-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	24.2	27.1	17.1	13.1	27.2	20.9	15.8	30.0	26.0	51.9	22.9	51.0	5.6	30	0.511

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.5	88.4	68.1	84.3	66.8	80.7	65.4	70.2	84.2	68.3	80.7	66.7	77.8	8.4	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
65.6	95.3	74.7	63.9	89.7	72.8	62.4	85.1	71.7	34.2	84.1	32.6	81.1	31.4	78.1	76.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
20.9	18.6	16.4	DB	20.1	96.5	3.7	4.5	17.4	99.7	15.2	102.4	13.1	104.9	10.4	108.2
			WB	19.1	73.5	3.8	2.0	16.4	74.9	14.2	76.0	12.0	77.1	9.3	78.6

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	53.7	40.6	41.6	46.8	52.3	58.1	64.4	67.8	66.9	61.8	55.0	46.7	41.6
	DBStd	11.55	7.29	6.85	6.19	6.08	6.01	6.00	5.87	5.40	5.23	6.22	6.22	6.95
	HDD50	1152	297	241	136	43	6	0	0	0	0	25	134	270
	HDD65	4445	755	654	564	382	226	81	35	38	122	313	550	725
	CDD50	2508	7	6	37	112	258	434	551	524	355	180	34	10
	CDD65	326	0	0	0	1	13	64	121	96	28	3	0	0
	CDH74	3004	0	0	0	36	156	596	1116	861	222	17	0	0
	CDH80	943	0	0	0	1	22	183	391	298	47	1	0	0
(14) Wind	WSAvg	7.8	8.5	8.7	8.5	8.0	7.7	7.4	7.4	6.8	6.8	7.4	7.8	8.5
(15) Precipitation	PrecAvg	25.2	2.0	1.8	1.7	1.9	2.4	2.2	2.3	2.2	1.8	2.3	2.2	2.4
	PrecMax	35.4	4.9	3.7	5.4	5.0	6.2	4.5	7.1	4.6	3.8	5.1	4.5	6.1
	PrecMin	19.0	0.2	0.2	0.4	0.4	0.0	0.2	0.7	0.2	0.0	0.6	0.4	0.9
	PrecStd	4.2	0.9	0.9	1.1	1.2	1.2	1.0	1.5	1.1	1.0	1.1	0.9	1.1
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	57.9	61.0	69.3	78.1	82.8	90.9	94.2	96.4	85.3	76.2	64.2	58.7
		MCWB	53.5	50.7	54.0	61.0	66.4	69.8	69.7	71.2	66.7	62.9	58.9	54.5
	2%	DB	55.3	56.2	64.6	73.6	78.1	85.3	88.3	87.8	80.5	71.2	60.9	56.1
		MCWB	51.9	49.9	53.2	58.2	63.1	67.8	67.9	67.7	64.7	62.2	56.6	52.6
	5%	DB	53.1	53.9	60.6	67.8	74.6	80.6	84.1	82.8	75.9	67.0	58.3	54.0
		MCWB	49.8	49.2	51.7	55.7	61.5	65.6	66.7	66.2	63.1	59.9	54.3	50.9
	10%	DB	50.9	51.8	57.1	63.9	70.2	76.6	80.2	78.5	72.1	64.0	55.8	51.9
		MCWB	47.8	47.7	50.6	53.7	59.5	64.0	65.5	64.1	61.5	58.4	52.4	49.0
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	54.5	53.0	56.5	62.8	68.4	72.9	71.6	72.4	68.7	65.0	60.0	55.3
		MCDB	57.2	57.5	63.6	75.8	80.6	86.7	89.0	90.3	80.4	72.2	62.8	57.7
	2%	WB	52.2	51.3	54.7	59.2	65.0	69.3	69.9	69.8	66.3	62.6	56.9	53.2
		MCDB	54.9	55.1	61.7	70.0	75.2	80.9	84.2	83.8	76.5	69.1	60.4	55.6
	5%	WB	50.1	49.8	52.9	56.6	62.6	67.1	68.0	67.5	64.5	60.9	54.7	51.3
		MCDB	52.7	53.3	59.0	65.9	71.8	78.0	80.6	79.0	73.3	66.0	57.8	53.8
	10%	WB	48.0	48.0	51.0	54.5	60.3	65.1	66.4	65.8	63.0	59.2	52.7	49.2
		MCDB	50.5	51.5	56.6	62.4	68.5	74.9	78.2	75.5	70.6	63.4	55.7	51.7
(35) Mean Daily Temperature Range	5% DB	MDBR	8.9	11.4	14.9	17.1	17.6	18.1	18.5	18.9	17.8	14.0	10.4	9.4
		MCDBR	9.2	14.5	21.7	24.6	24.3	25.4	25.8	26.8	23.9	17.7	12.5	9.8
		MCWBR	7.9	10.1	12.2	12.2	11.9	11.0	9.6	10.7	10.8	9.9	9.1	8.2
	5% WB	MCDBR	9.1	12.1	17.4	21.3	21.7	21.9	22.2	23.4	19.6	15.9	11.4	9.6
		MCWBR	8.0	9.3	10.8	11.5	11.8	10.9	9.2	10.9	10.1	9.7	9.0	8.4
(40) Clear-Sky Solar Irradiance	taub		0.336	0.357	0.392	0.412	0.419	0.420	0.420	0.409	0.382	0.375	0.346	0.330
	taud		2.387	2.341	2.236	2.205	2.224	2.255	2.254	2.304	2.367	2.372	2.393	2.361
	Ebn at Noon		226	248	257	265	267	267	265	263	259	238	219	209
	Edh at Noon		22	28	36	42	43	42	41	37	32	27	21	20
(44) All-Sky Solar Radiation	RadAvg		285	530	906	1381	1626	1807	1711	1484	1144	677	343	237
(45)	RadStd		34	79	112	158	162	167	146	146	97	54	33	37

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (34 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page