

PARIS MONTSOURIS, France

WMO: 071560

Lat: 48.8217N

Lon: 2.3378E

Elev: 253

StdP: 14.56

Time Zone: 1.00 (EUC)

Period: 99-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	26.8	29.0	16.2	12.6	30.5	20.0	15.2	31.9	19.1	47.3	17.5	48.2	6.8	10	0.458

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.3	88.9	68.7	84.9	67.0	81.6	65.7	70.3	85.3	68.5	81.4	67.0	78.6	6.5	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.5	95.2	75.3	63.8	89.5	73.8	62.4	85.0	71.9	34.3	86.0	32.8	81.5	31.6	78.6	79.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
16.2	14.2	12.7	DB	23.4	96.4	3.2	4.2	21.1	99.4	19.2	101.8	17.4	104.1	15.0	107.2
			WB	21.7	74.1	3.7	2.1	19.1	75.6	17.0	76.9	14.9	78.0	12.2	79.6

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	55.1	41.6	42.7	48.1	54.0	60.0	66.1	69.6	68.7	63.3	56.0	47.8	42.8	(6)
	DBStd	11.68	6.63	6.59	6.38	6.34	6.07	5.98	5.95	5.37	5.00	5.89	5.77	6.33	(7)
	HDD50	977	267	213	111	28	2	0	0	0	0	17	106	233	(8)
	HDD65	4060	726	624	523	334	181	56	20	19	90	282	517	688	(9)
	CDD50	2850	6	8	53	150	311	483	606	580	400	204	39	10	(10)
	CDD65	458	0	0	0	5	25	89	161	134	40	4	0	0	(11)
	CDH74	3473	0	0	0	49	190	702	1300	993	226	13	0	0	(12)
	CDH80	1089	0	0	0	3	25	219	449	347	45	1	0	0	(13)
(14) Wind	WSAvg	6.7	7.3	7.6	7.4	7.1	6.7	6.6	6.3	5.8	5.8	6.1	6.8	7.3	(14)
(15) Precipitation	PrecAvg	25.2	2.0	1.8	1.7	1.9	2.4	2.2	2.3	2.2	1.8	2.3	2.2	2.4	(15)
	PrecMax	35.4	4.9	3.7	5.4	5.0	6.2	4.5	7.1	4.6	3.8	5.1	4.5	6.1	(16)
	PrecMin	19.0	0.2	0.2	0.4	0.4	0.0	0.2	0.7	0.2	0.0	0.6	0.4	0.9	(17)
	PrecStd	4.2	0.9	0.9	1.1	1.2	1.2	1.0	1.5	1.1	1.0	1.1	0.9	1.1	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	57.2	60.9	69.8	79.1	83.1	91.7	94.4	96.1	84.9	75.6	63.7	58.2	(19)
		MCWB	53.3	50.9	53.2	60.5	66.8	70.7	70.3	71.3	66.5	63.1	58.5	54.1	(20)
	2%	DB	54.7	56.1	65.0	74.4	79.1	86.0	88.6	88.5	80.2	70.7	60.6	55.8	(21)
		MCWB	51.3	49.6	52.7	58.1	62.9	67.5	68.3	68.3	64.8	61.6	56.5	52.3	(22)
	5%	DB	52.6	53.8	61.1	68.9	75.4	81.5	84.8	83.5	75.9	66.8	58.1	53.9	(23)
		MCWB	49.3	49.0	51.6	55.7	61.3	66.1	67.0	66.6	63.1	59.8	54.2	50.8	(24)
	10%	DB	50.7	51.7	57.7	64.9	71.1	77.4	81.2	79.4	72.4	63.9	55.8	51.9	(25)
		MCWB	47.4	47.7	50.4	53.8	59.4	64.2	65.8	64.8	61.5	58.3	52.3	48.9	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	53.9	52.8	56.3	62.1	68.2	73.3	72.0	72.4	68.2	64.9	59.9	54.9	(27)
		MCDB	56.5	57.0	63.7	76.5	81.3	87.2	88.2	90.5	80.9	71.7	62.4	57.0	(28)
	2%	WB	51.8	51.0	54.4	59.1	64.8	69.7	70.0	69.9	66.2	62.4	56.8	52.9	(29)
		MCDB	54.4	54.8	61.3	71.0	75.7	82.5	85.5	84.4	76.6	68.4	60.0	55.3	(30)
	5%	WB	49.7	49.6	52.9	56.8	62.5	67.4	68.3	67.8	64.5	60.8	54.6	51.1	(31)
		MCDB	52.4	53.0	59.3	66.8	72.4	78.4	81.5	80.0	73.1	66.0	57.7	53.7	(32)
	10%	WB	47.7	47.7	51.1	54.7	60.5	65.5	66.6	66.0	63.0	59.1	52.5	49.1	(33)
		MCDB	50.3	51.3	57.1	63.4	69.3	75.8	78.6	76.8	70.5	63.4	55.5	51.6	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	7.4	9.5	12.3	14.8	15.3	15.9	16.3	16.2	14.8	11.5	8.4	7.6	(35)
		MCDBR	8.6	12.7	17.7	21.0	21.1	22.3	21.9	23.6	20.2	15.0	10.3	8.7	(36)
	5% WB	MCWBR	7.3	8.6	9.2	9.6	9.7	9.9	8.3	9.6	8.6	8.0	7.4	7.3	(37)
		MCWBR	8.7	11.2	14.8	19.1	18.6	19.3	19.7	20.4	17.2	13.7	9.8	8.6	(38)
(40) Clear-Sky Solar Irradiance	taub		0.338	0.358	0.394	0.412	0.419	0.421	0.420	0.409	0.382	0.376	0.348	0.332	(40)
		taud	2.380	2.331	2.227	2.201	2.220	2.252	2.250	2.301	2.364	2.362	2.385	2.353	(41)
	Ebn at Noon		225	247	256	265	267	267	266	263	259	237	219	209	(42)
		Edh at Noon	22	29	37	42	43	42	41	38	32	27	22	20	(43)
(44) All-Sky Solar Radiation	RadAvg		288	535	911	1383	1630	1816	1719	1494	1151	682	347	241	(44)
	RadStd		34	77	113	157	160	168	144	146	97	54	34	38	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (37 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page