

PARIS MONTSOURIS, France

WMO: 071560

Lat: 48.8217N

Lon: 2.3378E

Elev: 77

StdP: 100.40

Time Zone: 1.00 (EUC)

Period: 99-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-2.9	-1.6	-8.8	1.8	-0.8	-6.7	2.2	0.0	8.5	8.5	7.8	9.0	3.1	10	0.458

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.0	31.6	20.4	29.4	19.5	27.5	18.7	21.3	29.6	20.3	27.5	19.4	25.9	2.9	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.6	13.6	24.0	17.7	12.8	23.2	16.9	12.1	22.2	62.0	30.0	58.5	27.5	55.6	25.9	26.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
7.2	6.4	5.7	DB	-4.8	35.8	1.8	2.3	-6.1	37.4	-7.1	38.8	-8.1	40.1	-9.4	41.8	(4)
			WB	-5.7	23.4	2.0	1.2	-7.2	24.2	-8.4	24.9	-9.5	25.6	-11.0	26.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	12.9	5.3	5.9	9.0	12.2	15.5	18.9	20.9	20.4	17.4	13.4	8.8	6.0
	DBStd	6.49	3.68	3.66	3.55	3.52	3.37	3.32	3.31	2.98	2.78	3.27	3.20	3.52
	HDD10.0	543	148	118	62	16	1	0	0	0	0	9	59	129
	HDD18.3	2256	403	347	291	186	101	31	11	11	50	157	287	382
	CDD10.0	1583	3	4	29	83	173	268	337	322	222	113	22	6
	CDD18.3	254	0	0	0	3	14	49	89	74	22	2	0	0
	CDH23.3	1929	0	0	0	27	106	390	722	552	126	7	0	0
	CDH26.7	605	0	0	0	2	14	122	249	193	25	1	0	0
Wind	WSAvg	3.0	3.3	3.4	3.3	3.2	3.0	2.9	2.8	2.6	2.6	2.7	3.0	3.3
Precipitation	PrecAvg	641	50	45	43	49	61	55	58	56	46	58	56	62
	PrecMax	900	125	95	136	127	157	114	180	117	97	130	114	155
	PrecMin	482	5	6	9	9	1	6	17	6	0	15	11	23
	PrecStd	106	24	24	29	30	31	26	37	28	26	28	24	29
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	14.0	16.1	21.0	26.2	28.4	33.2	34.7	35.6	29.4	24.2	17.6	14.5
		MCWB	11.8	10.5	11.8	15.8	19.3	21.5	21.3	21.8	19.1	17.3	14.7	12.3
	2%	DB	12.6	13.4	18.3	23.5	26.2	30.0	31.5	31.4	26.8	21.5	15.9	13.2
		MCWB	10.7	9.8	11.5	14.5	17.2	19.7	20.1	20.2	18.2	16.5	13.6	11.3
	5%	DB	11.5	12.1	16.2	20.5	24.1	27.5	29.3	28.6	24.4	19.3	14.5	12.2
		MCWB	9.6	9.4	10.9	13.2	16.3	18.9	19.4	19.2	17.3	15.4	12.3	10.4
	10%	DB	10.4	11.0	14.3	18.3	21.7	25.2	27.3	26.3	22.4	17.7	13.2	11.0
		MCWB	8.6	8.7	10.2	12.1	15.2	17.9	18.8	18.2	16.4	14.6	11.3	9.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.2	11.6	13.5	16.7	20.1	23.0	22.2	22.5	20.1	18.3	15.5	12.7
		MCDB	13.6	13.9	17.6	24.7	27.4	30.7	31.2	32.5	27.2	22.0	16.9	13.9
	2%	WB	11.0	10.6	12.4	15.1	18.2	21.0	21.1	21.0	19.0	16.9	13.8	11.6
		MCDB	12.4	12.7	16.3	21.6	24.3	28.0	29.7	29.1	24.8	20.2	15.6	12.9
	5%	WB	9.8	9.8	11.6	13.8	17.0	19.7	20.2	19.9	18.1	16.0	12.6	10.6
		MCDB	11.3	11.7	15.2	19.4	22.4	25.8	27.5	26.7	22.9	18.9	14.3	12.1
	10%	WB	8.7	8.7	10.6	12.6	15.8	18.6	19.2	18.9	17.2	15.1	11.4	9.5
		MCDB	10.2	10.7	14.0	17.5	20.7	24.3	25.9	24.9	21.4	17.5	13.1	10.9
Mean Daily Temperature Range	5% DB	MDBR	4.1	5.3	6.8	8.2	8.5	8.8	9.0	9.0	8.2	6.4	4.7	4.2
		MCDBR	4.8	7.1	9.8	11.7	11.7	12.4	12.2	13.1	11.2	8.3	5.7	4.8
		MCWBR	4.1	4.8	5.1	5.4	5.4	5.5	4.6	5.3	4.8	4.4	4.1	4.1
	5% WB	MCDBR	4.8	6.2	8.2	10.6	10.3	10.7	11.0	11.3	9.6	7.6	5.5	4.8
		MCWBR	4.3	4.8	4.9	5.2	5.4	5.4	4.6	5.2	4.6	4.3	4.2	4.2
Clear-Sky Solar Irradiance	taub	0.338	0.358	0.394	0.412	0.419	0.421	0.420	0.409	0.382	0.376	0.348	0.332	
	taud	2.380	2.331	2.227	2.201	2.220	2.252	2.250	2.301	2.364	2.362	2.385	2.353	
	Ebn at Noon	710	780	808	834	843	842	837	829	816	748	689	659	
	Edh at Noon	69	90	117	132	135	132	130	119	101	86	68	62	
All-Sky Solar Radiation	RadAvg	0.91	1.69	2.87	4.36	5.14	5.73	5.42	4.71	3.63	2.15	1.09	0.76	
	RadStd	0.11	0.24	0.35	0.49	0.51	0.53	0.45	0.46	0.31	0.17	0.11	0.12	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (37 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page