

PARIS CHARLES DE GAULLE AP, France

WMO: 071570

Lat: 49.0153N

Lon: 2.5344E

Elev: 392

StdP: 14.49

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	23.2	26.3	15.9	12.5	26.3	19.8	15.1	29.1	31.6	49.4	28.4	49.2	8.1	20	0.559

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.3	88.0	67.8	84.1	66.5	80.6	65.2	69.8	83.4	68.1	80.2	66.5	77.5	9.2	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.4	95.4	74.2	63.8	90.0	72.7	62.4	85.4	71.3	34.0	83.0	32.6	80.5	31.3	78.0	77.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.5	21.3	18.9	19.6	94.7	4.6	3.6	16.3	97.3	13.6	99.4	11.0	101.4	7.7	104.0
			18.3	72.7	4.6	1.9	15.0	74.0	12.3	75.2	9.8	76.2	6.5	77.6
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	53.6	40.1	41.4	46.6	51.8	58.2	64.0	68.0	67.8	61.5	55.0	46.4	41.1	
	DBStd	11.81	7.50	6.91	6.27	6.45	6.16	5.93	5.68	5.53	5.20	6.24	6.43	7.15	
	HDD50	1208	313	245	140	53	7	0	0	0	0	25	140	285	
	HDD65	4518	773	660	570	399	227	88	31	29	130	313	557	741	
	CDD50	2508	5	5	35	106	260	421	559	550	346	180	33	8	
	CDD65	344	0	0	0	2	15	59	125	114	26	3	0	0	
	CDH74	2907	0	0	0	25	135	510	1072	975	176	14	0	0	
	CDH80	902	0	0	0	0	17	147	347	356	34	1	0	0	
Wind	WSAvg	9.7	11.0	10.9	10.5	9.9	9.4	8.8	8.8	8.4	8.7	9.6	9.8	10.7	
Precipitation	PrecAvg	26.7	2.2	1.9	1.8	1.9	2.4	2.3	2.5	2.4	1.9	2.4	2.3	2.7	
	PrecMax	37.9	5.4	3.9	6.2	5.1	6.4	4.7	6.2	4.4	4.1	5.6	4.3	6.6	
	PrecMin	19.8	0.1	0.4	0.2	0.3	0.1	0.3	0.7	0.3	0.1	0.8	0.6	0.9	
	PrecStd	4.5	1.1	1.0	1.3	1.1	1.3	1.1	1.4	1.2	1.1	1.1	1.0	1.3	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	57.1	60.1	68.6	77.3	82.4	89.6	93.1	95.2	84.2	75.6	63.9	57.7	
		MCWB	53.1	50.3	53.0	59.7	65.3	68.4	68.7	69.0	65.5	62.8	57.8	53.8	
	2%	DB	54.6	55.5	63.8	72.5	77.7	84.3	87.7	88.2	79.2	70.6	60.1	55.5	
		MCWB	51.3	49.0	52.5	57.1	62.5	67.1	67.6	67.6	63.9	61.4	55.7	52.2	
	5%	DB	52.1	53.1	59.7	67.0	73.9	79.8	83.8	83.7	74.6	66.6	57.5	53.4	
		MCWB	48.9	48.7	51.1	54.9	60.5	65.1	66.4	66.2	62.1	59.5	53.9	50.5	
	10%	DB	49.9	51.0	56.4	63.0	69.8	75.8	80.1	79.0	71.1	63.8	55.3	51.1	
		MCWB	47.2	47.3	49.8	52.9	58.8	63.3	65.2	64.2	60.5	58.0	52.2	48.6	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	54.0	52.4	55.8	62.0	67.4	72.2	71.7	71.5	67.8	64.6	59.3	54.9
			MCDB	56.1	56.5	63.2	74.4	79.3	85.9	86.7	87.7	79.6	72.1	62.0	57.0
2%		WB	51.8	50.7	54.0	58.2	64.2	68.7	69.7	69.4	65.5	62.1	56.4	52.8	
		MCDB	54.2	54.1	60.4	68.5	74.6	80.1	83.5	83.2	75.1	68.4	59.4	54.9	
5%		WB	49.5	49.3	52.3	55.8	61.9	66.5	68.0	67.6	63.7	60.6	54.5	50.8	
		MCDB	51.7	52.4	58.1	64.8	71.2	77.2	80.1	79.5	72.0	65.6	57.2	53.1	
10%		WB	47.3	47.6	50.5	53.8	59.7	64.6	66.3	65.9	62.0	58.9	52.5	48.7	
		MCDB	49.6	50.8	55.8	61.4	68.0	74.1	77.5	76.4	69.1	63.0	55.2	50.8	
Mean Daily Temperature Range	5% DB	MDBR	8.2	10.4	13.5	15.7	15.9	16.7	17.3	17.2	15.7	12.6	9.2	8.2	
		MCDBR	9.3	12.8	19.2	21.8	21.8	23.1	23.5	24.7	21.1	15.8	10.5	8.8	
		MCWBR	7.8	8.8	10.5	10.6	10.2	10.0	8.7	9.0	9.0	8.7	7.4	7.3	
	5% WB	MCDBR	9.0	10.9	15.3	18.7	19.2	20.1	20.3	20.9	17.2	14.6	9.5	8.5	
		MCWBR	8.0	8.6	9.5	9.9	10.1	10.1	8.5	8.8	8.3	8.6	7.4	7.5	
Clear-Sky Solar Irradiance	taub	0.332	0.352	0.386	0.407	0.414	0.415	0.415	0.405	0.378	0.370	0.342	0.326		
	taud	2.399	2.356	2.252	2.218	2.236	2.265	2.262	2.313	2.375	2.385	2.405	2.372		
	Ebn at Noon	228	250	259	266	269	269	266	264	260	240	221	211		
	Edh at Noon	21	28	36	41	42	41	41	37	32	27	21	19		
All-Sky Solar Radiation	RadAvg	284	528	905	1380	1625	1805	1708	1481	1142	676	341	235		
	RadStd	34	79	112	158	163	166	148	147	98	53	33	37		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (37 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page