

PARIS CHARLES DE GAULLE AP, France

WMO: 071570

Lat: 49.0153N

Lon: 2.5344E

Elev: 120

StdP: 99.90

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-4.9	-3.2	-8.9	1.8	-3.2	-6.8	2.2	-1.6	14.1	9.7	12.7	9.6	3.6	20	0.559

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.6	31.1	19.9	29.0	19.2	27.0	18.4	21.0	28.5	20.1	26.8	19.2	25.3	4.1	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.6	13.6	23.4	17.7	12.9	22.6	16.9	12.2	21.8	61.2	28.3	57.9	27.0	55.0	25.6	25.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
11.0	9.5	8.5	-6.9	34.8	2.5	2.0	-8.7	36.3	-10.2	37.4	-11.6	38.6	-13.5	40.0	
			DB												
			WB	-7.6	22.6	2.5	1.1	-9.5	23.4	-10.9	24.0	-12.4	24.6	-14.2	25.3

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	12.0	4.5	5.2	8.1	11.0	14.5	17.8	20.0	19.9	16.4	12.8	8.0	5.0
	DBStd	6.56	4.17	3.84	3.48	3.59	3.42	3.29	3.16	3.07	2.89	3.47	3.57	3.97
	HDD10.0	671	174	136	78	29	4	0	0	0	0	14	78	158
	HDD18.3	2510	429	367	317	222	126	49	17	16	72	174	309	412
	CDD10.0	1393	3	3	19	59	144	234	311	306	192	100	18	4
	CDD18.3	191	0	0	0	1	8	33	69	63	14	2	0	0
	CDH23.3	1615	0	0	0	14	75	283	596	542	98	8	0	0
	CDH26.7	501	0	0	0	0	9	82	193	198	19	1	0	0
Wind	WSAvg	4.3	4.9	4.9	4.7	4.4	4.2	3.9	3.9	3.8	3.9	4.3	4.4	4.8
Precipitation	PrecAvg	678	56	48	46	49	61	59	63	60	48	61	58	69
	PrecMax	962	136	99	158	130	163	120	158	111	104	143	108	167
	PrecMin	502	3	9	5	7	3	7	18	7	3	20	14	23
	PrecStd	115	27	26	32	29	32	28	35	30	27	28	25	33
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.9	15.6	20.3	25.1	28.0	32.0	34.0	35.1	29.0	24.2	17.7	14.3
		MCWB	11.7	10.2	11.7	15.4	18.5	20.2	20.4	20.6	18.6	17.1	14.3	12.1
	2%	DB	12.5	13.0	17.7	22.5	25.4	29.1	30.9	31.2	26.2	21.5	15.6	13.0
		MCWB	10.7	9.5	11.4	14.0	16.9	19.5	19.8	19.8	17.7	16.3	13.2	11.2
	5%	DB	11.2	11.7	15.4	19.5	23.3	26.5	28.8	28.7	23.7	19.2	14.2	11.9
		MCWB	9.4	9.3	10.6	12.7	15.8	18.4	19.1	19.0	16.7	15.3	12.2	10.3
	10%	DB	9.9	10.6	13.5	17.2	21.0	24.3	26.7	26.1	21.7	17.7	12.9	10.6
		MCWB	8.4	8.5	9.9	11.6	14.9	17.4	18.4	17.9	15.8	14.4	11.2	9.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.2	11.3	13.2	16.7	19.7	22.3	22.1	22.0	19.9	18.1	15.2	12.7
		MCDB	13.4	13.6	17.3	23.6	26.3	30.0	30.4	30.9	26.4	22.3	16.7	13.9
	2%	WB	11.0	10.4	12.2	14.6	17.9	20.4	20.9	20.8	18.6	16.7	13.6	11.5
		MCDB	12.3	12.3	15.8	20.3	23.7	26.7	28.6	28.4	24.0	20.2	15.2	12.7
	5%	WB	9.7	9.6	11.3	13.2	16.6	19.2	20.0	19.8	17.6	15.9	12.5	10.5
		MCDB	10.9	11.4	14.5	18.2	21.8	25.1	26.7	26.4	22.2	18.7	14.0	11.7
	10%	WB	8.5	8.7	10.3	12.1	15.4	18.1	19.1	18.8	16.7	14.9	11.4	9.3
		MCDB	9.8	10.4	13.2	16.3	20.0	23.4	25.3	24.7	20.6	17.2	12.9	10.5
Mean Daily Temperature Range	5% DB	MDBR	4.6	5.8	7.5	8.7	8.8	9.3	9.6	9.6	8.7	7.0	5.1	4.6
		MCDBR	5.2	7.1	10.6	12.1	12.1	12.8	13.0	13.7	11.7	8.8	5.8	4.9
		MCWBR	4.3	4.9	5.8	5.9	5.6	5.6	4.8	5.0	5.0	4.8	4.1	4.1
	5% WB	MCDBR	5.0	6.1	8.5	10.4	10.7	11.2	11.3	11.6	9.6	8.1	5.3	4.7
		MCWBR	4.5	4.8	5.3	5.5	5.6	5.6	4.7	4.9	4.6	4.8	4.1	4.2
Clear-Sky Solar Irradiance	taub	0.332	0.352	0.386	0.407	0.414	0.415	0.415	0.405	0.378	0.370	0.342	0.326	
	taud	2.399	2.356	2.252	2.218	2.236	2.265	2.262	2.313	2.375	2.385	2.405	2.372	
	Ebn at Noon	718	788	816	839	847	847	840	832	819	756	696	665	
	Edh at Noon	67	87	113	130	133	130	129	117	100	84	66	61	
All-Sky Solar Radiation	RadAvg	0.90	1.67	2.85	4.35	5.12	5.69	5.38	4.67	3.60	2.13	1.07	0.74	
	RadStd	0.11	0.25	0.35	0.50	0.52	0.52	0.47	0.46	0.31	0.17	0.10	0.12	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (37 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page