

PARIS VATRY AP, France

WMO: 071660

Lat: 48.7772N

Lon: 4.1647E

Elev: 587

StdP: 14.39

Time Zone: 1.00 (EUC)

Period: 03-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	19.7	23.2	14.4	11.6	21.3	19.1	14.7	24.9	32.0	48.0	29.5	47.2	7.0	30	0.584

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.3	87.7	68.3	84.0	67.0	80.5	66.2	70.5	82.9	68.8	80.5	67.2	77.7	8.4	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
66.4	99.2	74.7	64.7	93.4	72.8	63.1	88.3	71.0	34.7	83.1	33.3	80.8	32.0	77.3	76.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.0	22.9	20.4	14.0	95.0	5.4	4.6	10.2	98.3	7.0	101.0	4.0	103.5	0.1	106.9
			13.3	74.0	5.5	1.5	9.4	75.1	6.2	76.0	3.1	76.9	-0.9	78.0
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	51.5	37.2	38.4	43.9	50.6	56.3	63.0	67.0	65.4	59.8	52.9	44.1	38.7
	DBStd	12.29	7.45	7.05	6.25	6.28	6.09	6.14	5.98	5.59	5.47	6.86	6.74	7.08
	HDD50	1615	400	327	205	66	13	1	0	0	1	50	198	354
	HDD65	5187	863	746	654	433	277	110	48	62	173	378	626	817
	CDD50	2164	2	1	16	84	208	390	526	478	295	139	22	3
	CDD65	262	0	0	0	1	8	49	109	75	18	2	0	0
	CDH74	2718	0	0	0	19	102	533	1132	744	179	9	0	0
	CDH80	857	0	0	0	0	18	157	398	254	30	0	0	0
(14) Wind	WSAvg	9.8	11.3	11.2	11.3	9.5	9.0	8.4	8.6	8.4	8.6	9.5	10.4	11.3
(15) Precipitation	PrecAvg	28.6	2.3	2.2	1.9	2.0	2.5	2.3	2.5	2.6	2.2	2.7	2.5	2.9
	PrecMax	39.6	5.1	4.4	5.1	5.6	5.8	5.8	6.1	5.9	4.9	5.9	5.5	6.7
	PrecMin	21.4	0.4	0.4	0.2	0.2	0.5	0.6	0.5	0.4	0.4	0.9	0.8	0.3
	PrecStd	4.2	1.0	1.1	1.1	1.3	1.1	1.1	1.2	1.5	1.2	1.2	1.3	1.4
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.5	58.6	67.7	76.8	82.4	90.0	94.5	93.1	84.0	75.2	62.6	55.8
		MCWB	52.1	50.9	52.9	61.9	68.1	70.5	70.0	69.6	65.6	63.5	58.0	53.1
	2%	DB	52.1	53.4	62.7	72.0	76.6	84.2	87.9	86.4	79.0	69.9	59.1	53.5
		MCWB	50.2	48.6	52.2	58.7	63.5	68.2	68.2	68.1	64.8	61.8	55.7	51.4
	5%	DB	50.0	50.2	57.6	67.5	73.0	80.3	84.3	82.1	75.0	66.0	56.8	50.8
		MCWB	48.5	47.7	50.0	56.7	61.7	67.0	66.8	66.0	63.5	60.2	53.8	49.0
	10%	DB	47.8	48.2	53.9	62.7	68.5	75.6	80.6	77.2	70.5	62.6	53.7	48.5
		MCWB	46.6	46.1	48.6	53.7	59.3	64.8	66.1	64.3	61.3	57.9	51.5	47.3
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	53.4	51.7	55.8	63.1	70.2	73.1	72.3	71.7	68.5	64.8	59.2	54.2
		MCDB	54.2	56.6	61.7	74.7	80.6	84.0	87.8	87.4	78.0	71.4	61.3	55.3
	2%	WB	51.0	49.8	53.4	59.8	65.6	70.3	70.2	69.4	66.4	62.7	56.0	51.6
		MCDB	52.3	51.8	60.6	69.5	73.0	80.8	83.7	82.2	75.8	68.0	58.7	53.4
	5%	WB	48.6	48.1	51.4	56.9	62.9	67.9	68.5	67.6	64.4	60.8	53.9	49.4
		MCDB	49.6	50.2	56.2	65.4	70.1	77.6	81.1	78.6	72.6	65.2	56.2	50.6
	10%	WB	46.2	46.0	49.5	54.7	60.6	65.7	67.0	65.7	62.7	58.8	51.8	47.3
		MCDB	47.3	47.9	53.7	62.1	67.4	74.1	77.9	74.9	69.6	62.2	53.8	48.5
(35) Mean Daily Temperature Range	5% DB	MDBR	9.2	11.7	15.9	18.6	18.5	19.5	20.3	19.7	18.7	14.7	10.4	9.2
		MCDBR	10.5	15.2	23.2	25.3	24.9	25.8	26.8	27.6	24.8	18.5	12.3	10.7
	5% WB	MCWBR	9.5	11.6	14.2	13.9	14.1	12.4	10.8	11.6	12.2	11.5	9.3	9.2
		MCWBR	9.9	13.7	18.9	22.5	21.4	23.2	23.5	22.7	21.2	16.9	11.6	10.0
(40) Clear-Sky Solar Irradiance	taub		0.316	0.338	0.369	0.398	0.406	0.410	0.407	0.399	0.370	0.359	0.329	0.313
		taud	2.423	2.372	2.291	2.218	2.237	2.259	2.258	2.304	2.365	2.392	2.420	2.391
	Ebn at Noon		236	256	266	269	271	270	269	266	263	245	227	219
		Edh at Noon	21	27	35	41	42	42	41	37	32	26	21	19
(44) All-Sky Solar Radiation	RadAvg		281	527	910	1375	1623	1814	1722	1487	1147	678	334	229
	RadStd		41	85	120	166	179	168	156	155	106	51	33	42

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (38 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page