

SAINT-DIZIER AB, France

WMO: 071690

Lat: 48.6314N

Lon: 4.9036E

Elev: 140

StdP: 99.66

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-6.5	-4.4	-10.6	1.5	-3.8	-8.3	1.9	-2.1	11.3	9.3	10.1	9.2	2.1	100	0.512

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.3	32.1	20.5	29.9	19.7	28.0	19.1	21.6	29.3	20.7	27.8	19.9	26.1	3.3	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.2	14.2	24.2	18.4	13.5	23.1	17.7	12.9	22.2	63.6	29.5	60.3	27.9	57.3	26.2	25.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.0	7.9	7.0	DB	-9.8	35.6	2.9	2.5	-11.9	37.4	-13.6	38.8	-15.2	40.2	-17.3	42.1	(4)
(5)			WB	-10.2	23.4	2.9	0.8	-12.3	24.0	-14.0	24.5	-15.6	24.9	-17.7	25.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	11.4	3.4	4.4	7.4	10.5	14.3	17.8	20.0	19.4	15.6	12.0	7.1	4.3	(6)	
	DBStd	6.87	4.21	3.83	3.57	3.55	3.52	3.62	3.37	3.42	3.11	3.72	3.88	4.08	(7)	
	HDD10.0	807	206	157	96	35	5	0	0	0	1	23	103	182	(8)	
	HDD18.3	2721	462	389	340	234	132	53	20	26	93	198	337	436	(9)	
	CDD10.0	1316	2	2	14	51	139	234	310	292	168	84	16	4	(10)	
	CDD18.3	188	0	0	0	1	7	37	72	60	11	1	0	0	(11)	
	CDH23.3	2102	0	0	0	23	114	427	761	653	114	9	0	0	(12)	
	CDH26.7	721	0	0	0	2	18	138	284	255	23	0	0	0	(13)	
(14) Wind	WSAvg	3.2	3.6	3.6	3.6	3.3	3.1	2.9	2.9	2.6	2.7	3.0	3.2	3.6	(14)	
(15) Precipitation	PrecAvg	882	75	71	63	64	70	65	74	74	72	81	81	92	(15)	
	PrecMax	1183	149	154	144	170	122	166	188	176	163	218	185	225	(16)	
	PrecMin	636	17	13	5	2	15	25	13	12	16	26	19	21	(17)	
	PrecStd	129	33	37	38	40	28	31	34	44	42	39	39	47	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.4	16.3	21.2	25.9	29.0	33.5	35.1	36.5	29.4	24.7	18.4	14.7	(19)	
		MCWB	10.7	9.9	12.1	15.7	18.9	20.6	21.3	21.1	19.1	17.6	13.7	11.0	(20)	
	2%	DB	12.2	13.6	18.4	23.1	26.2	30.3	31.7	32.1	26.6	21.9	16.0	12.9	(21)	
		MCWB	10.3	8.9	11.3	14.1	17.2	20.4	20.3	20.7	18.4	16.7	13.0	10.6	(22)	
	5%	DB	10.8	11.5	15.9	20.4	24.2	27.9	29.8	29.5	24.1	19.8	14.2	11.6	(23)	
		MCWB	9.2	8.7	10.3	13.0	16.2	19.5	19.5	19.6	17.5	15.6	11.8	9.9	(24)	
	10%	DB	9.4	10.1	13.6	17.8	22.0	25.8	27.7	27.1	21.9	17.7	12.8	10.2	(25)	
		MCWB	7.9	7.9	9.4	11.8	15.4	18.2	19.0	18.8	16.3	14.6	10.9	8.7	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.9	11.2	13.6	16.9	20.1	22.6	22.7	22.7	20.7	18.5	14.8	12.3	(27)	
		MCDB	12.7	13.8	18.3	24.5	27.1	30.4	31.1	31.0	26.2	22.6	16.8	13.3	(28)	
	2%	WB	10.6	10.1	12.2	14.9	18.4	21.2	21.5	21.5	19.3	17.2	13.3	11.1	(29)	
		MCDB	11.9	12.1	16.4	20.9	24.2	28.1	29.2	29.6	24.9	21.0	15.4	12.3	(30)	
	5%	WB	9.2	9.1	11.2	13.5	17.1	20.0	20.6	20.5	18.1	16.1	12.2	10.0	(31)	
		MCDB	10.6	11.1	14.7	18.9	22.3	26.5	27.7	27.5	22.7	19.0	13.9	11.5	(32)	
	10%	WB	8.0	8.1	10.1	12.3	16.0	18.9	19.6	19.5	17.1	15.0	11.1	8.9	(33)	
		MCDB	9.3	9.9	13.1	16.8	20.8	24.4	25.9	25.4	21.0	17.2	12.7	10.2	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	5.5	7.2	9.2	10.8	10.8	11.4	11.3	11.6	10.4	8.8	6.3	5.4	(35)	
		MCDBR	6.3	10.2	14.0	15.7	15.2	15.3	15.3	16.5	14.2	11.4	8.3	6.7	(36)	
	5% WB	MCWBR	4.8	6.7	8.1	8.0	7.3	6.9	5.8	6.4	6.9	6.6	5.6	5.1	(37)	
		MCWBR	5.8	8.2	11.0	13.8	13.2	13.9	13.4	13.9	12.2	10.2	7.2	5.8	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.315	0.339	0.367	0.397	0.405	0.411	0.407	0.400	0.373	0.361	0.330	0.312	(40)	
		taud	2.436	2.380	2.309	2.239	2.255	2.273	2.279	2.319	2.373	2.400	2.431	2.409	(41)	
	Edn at Noon		749	810	841	850	856	852	849	838	826	771	720	697	(42)	
			65	86	108	127	131	129	127	117	100	83	65	59	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.89	1.67	2.88	4.33	5.11	5.73	5.45	4.69	3.63	2.15	1.05	0.72	(44)	
	RadStd		0.14	0.28	0.39	0.54	0.59	0.54	0.51	0.50	0.34	0.16	0.10	0.14	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (35 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page