

LORIENT BRETAGNE SUD AP, France

WMO: 072050

Lat: 47.7628N

Lon: 3.4356W

Elev: 160

StdP: 14.61

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	28.0	30.3	21.9	16.5	31.4	25.1	19.2	33.1	33.0	52.1	30.0	52.2	7.7	60	0.585

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.7	82.2	67.2	78.5	65.5	75.2	64.4	69.0	78.4	67.2	75.1	65.7	72.1	9.9	60

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
65.9	96.2	71.8	64.5	91.5	69.8	63.3	87.5	68.4	33.1	78.5	31.7	75.4	30.6	72.2	78.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
26.2	23.0	20.5	DB	23.8	88.1	3.8	4.3	21.0	91.2	18.7	93.7	16.6	96.2	13.8	99.3
			WB	22.4	72.2	3.9	2.5	19.6	74.0	17.4	75.5	15.2	76.9	12.3	78.7

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	53.6	44.1	44.5	47.5	50.6	56.1	61.1	64.3	63.9	60.6	55.8	49.3	45.2	(6)
	DBStd	8.95	6.07	5.37	4.76	4.85	5.15	5.13	4.70	4.61	4.48	4.89	5.24	6.35	(7)
	HDD50	769	193	161	103	49	7	0	0	0	0	11	74	171	(8)
	HDD65	4279	648	573	542	431	282	140	71	75	145	287	471	614	(9)
	CDD50	2095	10	8	26	68	195	334	442	430	318	189	53	22	(10)
	CDD65	131	0	0	0	0	5	23	48	41	13	1	0	0	(11)
	CDH74	969	0	0	0	1	48	200	377	258	83	2	0	0	(12)
	CDH80	209	0	0	0	0	4	45	84	67	9	0	0	0	(13)
(14) Wind	WSAvg	10.0	11.1	10.7	10.5	10.3	9.8	9.5	9.4	8.7	9.0	9.6	10.0	11.0	(14)
(15) Precipitation	PrecAvg	37.3	4.5	3.4	2.5	2.8	2.5	2.0	2.2	2.2	2.4	4.2	4.4	4.3	(15)
	PrecMax	46.6	9.3	8.6	7.5	6.8	5.4	4.4	4.6	5.5	6.0	7.8	9.0	8.5	(16)
	PrecMin	28.2	0.6	0.6	0.2	0.8	0.5	0.3	0.2	0.4	0.0	0.6	1.0	0.9	(17)
	PrecStd	5.0	2.4	2.0	1.7	1.7	1.2	1.2	1.0	1.3	1.7	1.7	2.0	2.1	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.8	57.8	66.2	72.3	79.1	85.6	87.3	86.5	81.2	71.3	62.1	58.0	(19)
		MCWB	53.9	52.2	53.6	59.9	63.6	70.1	68.2	70.2	66.5	63.3	58.8	55.2	(20)
	2%	DB	54.7	54.7	60.5	66.6	74.3	79.2	82.0	80.9	76.1	67.0	60.2	56.7	(21)
		MCWB	53.1	51.1	52.1	56.1	62.4	66.1	66.8	67.1	63.9	61.4	57.4	54.7	(22)
	5%	DB	53.7	53.4	57.0	62.7	69.5	75.2	78.3	75.9	72.2	64.7	58.9	55.6	(23)
		MCWB	52.0	50.8	51.1	54.3	59.8	64.2	65.6	65.6	62.4	60.5	56.4	53.9	(24)
	10%	DB	52.7	52.2	54.8	59.1	65.3	71.2	74.4	72.6	68.9	63.0	57.5	54.6	(25)
		MCWB	51.0	50.0	50.6	52.6	58.0	62.0	64.3	64.2	61.5	59.6	55.1	52.8	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	54.9	53.8	55.8	61.2	66.4	71.6	70.2	71.9	68.5	64.8	60.1	56.5	(27)
		MCDB	55.3	55.4	62.1	68.9	76.2	82.5	81.9	83.7	77.0	68.0	61.0	57.0	(28)
	2%	WB	53.8	52.6	53.9	57.6	63.1	67.7	68.2	69.0	66.1	63.1	58.4	55.5	(29)
		MCDB	54.4	53.8	57.6	64.3	70.9	77.1	78.7	77.1	71.5	65.5	59.5	56.2	(30)
	5%	WB	52.6	51.7	52.8	55.5	60.9	65.2	66.6	67.1	64.6	61.8	57.2	54.4	(31)
		MCDB	53.5	52.8	55.6	60.6	67.9	73.0	75.0	73.3	68.9	63.8	58.5	55.4	(32)
	10%	WB	51.4	50.7	51.8	53.8	58.8	62.9	65.1	65.4	63.1	60.5	55.6	53.2	(33)
		MCDB	52.5	52.0	53.8	57.8	64.1	69.4	72.1	70.6	67.1	62.4	57.2	54.4	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	10.1	11.5	13.3	15.1	15.1	15.9	15.7	16.1	16.2	13.0	11.7	10.2	(35)
		MCDBR	8.7	11.3	17.0	20.5	21.4	22.4	23.1	21.2	20.5	14.0	10.9	8.2	(36)
	5% WB	MCWBR	8.2	8.9	10.9	12.1	11.9	11.9	10.9	10.2	10.3	9.4	8.9	7.9	(37)
		MCWBR	8.3	9.7	12.8	16.6	18.6	20.1	19.5	17.8	15.7	11.5	9.2	8.0	(38)
(40) Clear-Sky Solar Irradiance	taub		0.333	0.346	0.372	0.384	0.389	0.386	0.383	0.373	0.360	0.359	0.338	0.326	(40)
		taud	2.417	2.396	2.337	2.317	2.349	2.384	2.393	2.441	2.458	2.455	2.438	2.395	(41)
	Ebn at Noon		233	257	267	275	278	278	277	276	269	249	230	219	(42)
		Edh at Noon	22	27	34	38	38	37	36	33	30	25	21	20	(43)
(44) All-Sky Solar Radiation	RadAvg		331	616	989	1487	1761	1935	1848	1604	1276	728	416	287	(44)
	RadStd		31	62	100	146	121	182	88	110	89	60	36	32	(45)

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (25 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page