

BEAUCOUZE, France

WMO: 072300

Lat: 47.4789N

Lon: 0.6144W

Elev: 164

StdP: 14.61

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	24.6	27.5	18.3	13.9	28.0	22.3	16.9	30.0	24.2	52.4	21.2	51.8	4.6	30	0.487

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.4	88.7	68.8	84.7	67.2	81.1	65.9	70.9	84.0	69.0	81.0	67.4	78.0	6.5	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
66.6	98.6	75.3	64.9	92.7	73.3	63.4	87.9	71.7	34.7	84.4	33.2	81.2	31.9	77.9	78.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
18.6	16.2	14.2	DB	20.4	95.3	4.6	3.9	17.1	98.1	14.4	100.3	11.8	102.5	8.4	105.3
			WB	19.8	74.1	4.8	2.2	16.4	75.7	13.6	77.0	10.9	78.3	7.4	79.9

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	54.4	42.4	43.3	47.6	51.8	58.0	64.6	67.8	67.6	61.8	56.1	48.3	43.2	(6)
	DBStd	10.96	7.20	6.61	5.78	5.74	5.55	5.67	5.10	5.11	4.99	5.87	6.19	7.34	(7)
	HDD50	951	245	197	114	45	4	0	0	0	0	16	101	229	(8)
	HDD65	4177	701	607	539	398	227	75	27	26	122	277	501	677	(9)
	CDD50	2573	9	10	40	98	252	438	553	545	354	207	50	17	(10)
	CDD65	324	0	0	0	1	10	63	115	107	25	3	0	0	(11)
	CDH74	3116	0	0	0	21	132	661	1052	992	246	12	0	0	(12)
	CDH80	1007	0	0	0	0	20	219	353	359	56	0	0	0	(13)
(14) Wind	WSAvg	6.7	7.8	7.6	7.6	6.9	6.7	6.3	6.4	5.9	5.5	5.8	6.6	7.3	(14)
(15) Precipitation	PrecAvg	24.4	2.4	2.1	2.2	1.7	2.1	1.6	1.6	1.7	1.8	2.4	2.6	2.3	(15)
	PrecMax	33.7	5.5	4.5	4.4	5.2	5.6	4.1	3.9	5.3	4.4	6.7	5.5	5.7	(16)
	PrecMin	18.1	0.6	0.2	0.1	0.2	0.4	0.1	0.1	0.2	0.4	0.1	0.4	0.4	(17)
	PrecStd	4.1	1.2	1.1	1.0	1.1	1.3	1.0	1.0	1.3	1.1	1.7	1.3	1.5	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	57.2	61.4	69.9	77.1	82.7	93.2	93.2	94.2	86.0	75.7	64.4	58.5	(19)
		MCWB	54.1	52.3	55.8	61.0	65.6	71.2	69.6	71.9	66.8	64.0	59.0	54.8	(20)
	2%	DB	55.6	56.7	63.7	72.2	77.8	85.8	87.8	88.6	80.6	71.1	61.1	56.7	(21)
		MCWB	53.1	51.3	53.6	58.9	63.7	67.6	68.2	69.5	65.2	62.3	57.4	54.0	(22)
	5%	DB	53.9	54.3	59.7	67.2	73.6	81.3	84.0	83.8	76.1	67.6	59.0	55.1	(23)
		MCWB	51.5	50.5	52.2	56.4	61.1	65.9	66.9	67.3	63.2	60.7	55.8	52.7	(24)
	10%	DB	52.1	52.6	56.8	62.8	69.4	76.9	80.0	79.4	72.3	64.9	57.0	53.4	(25)
		MCWB	49.8	49.5	51.1	53.7	59.2	64.5	65.6	65.5	61.4	59.6	54.1	51.3	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	55.2	54.4	57.6	63.4	68.0	73.0	72.8	74.7	69.3	65.9	60.5	56.3	(27)
		MCDB	56.3	58.0	66.4	73.8	79.7	86.2	87.7	89.8	79.7	71.7	62.4	57.4	(28)
	2%	WB	53.7	52.7	55.2	59.7	64.8	69.3	70.2	71.1	66.7	63.6	58.2	54.6	(29)
		MCDB	55.2	55.2	60.7	69.5	74.6	81.9	84.1	84.4	76.0	68.2	60.4	56.2	(30)
	5%	WB	51.9	51.3	53.6	57.1	62.4	67.4	68.4	69.0	64.7	62.0	56.3	53.1	(31)
		MCDB	53.5	53.7	58.1	65.6	71.1	78.9	80.5	80.3	74.0	66.2	58.6	54.8	(32)
	10%	WB	50.0	49.9	52.1	54.6	60.2	65.4	66.6	67.1	62.9	60.4	54.4	51.5	(33)
		MCDB	51.9	52.3	56.0	61.4	67.8	75.3	77.3	76.4	69.8	64.2	56.7	53.4	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	9.7	12.3	14.8	17.6	17.6	19.1	19.4	19.9	19.0	14.5	11.0	9.9	(35)
		MCDBR	9.3	14.1	19.6	24.6	24.5	26.8	26.9	27.9	25.4	17.5	11.9	9.8	(36)
	5% WB	MCWBR	7.9	10.0	11.6	13.0	12.1	11.4	10.2	10.8	11.5	9.7	8.5	8.2	(37)
		MCWBR	9.2	12.1	16.4	22.7	22.0	23.6	23.2	23.7	21.5	15.2	11.0	9.3	(38)
(40) Clear-Sky Solar Irradiance	taub		0.327	0.345	0.374	0.396	0.399	0.408	0.401	0.390	0.368	0.363	0.336	0.321	(40)
		taud	2.432	2.379	2.294	2.234	2.274	2.284	2.303	2.354	2.395	2.414	2.431	2.408	(41)
	Ebn at Noon		238	258	266	271	274	272	271	266	247	231	223	223	(42)
		Edh at Noon	22	28	35	41	41	41	39	36	31	27	22	20	(43)
(44) All-Sky Solar Radiation	RadAvg		338	617	972	1423	1685	1876	1787	1586	1253	726	422	295	(44)
	RadStd		31	70	109	160	129	175	105	137	93	55	38	35	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (27 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page