

BEAUCOUZE, France

WMO: 072300

Lat: 47.4789N

Lon: 0.6144W

Elev: 50

StdP: 100.73

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-4.1	-2.5	-7.6	2.0	-2.2	-5.4	2.4	-1.1	10.8	11.4	9.5	11.0	2.1	30	0.487

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.8	31.5	20.5	29.3	19.6	27.3	18.8	21.6	28.9	20.6	27.2	19.7	25.5	2.9	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.2	14.1	24.0	18.3	13.2	23.0	17.4	12.6	22.0	62.8	29.1	59.3	27.3	56.2	25.5	26.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
8.3	7.3	6.4	-6.4	35.1	2.6	2.2	-8.3	36.7	-9.8	38.0	-11.2	39.2	-13.1	40.7		
			-6.8	23.4	2.7	1.2	-8.7	24.3	-10.2	25.0	-11.7	25.7	-13.7	26.6		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	12.5	5.8	6.3	8.7	11.0	14.4	18.1	19.9	19.8	16.5	13.4	9.1	6.2
	DBStd	6.09	4.00	3.67	3.21	3.19	3.08	3.15	2.84	2.84	2.77	3.26	3.44	4.08
	HDD10.0	528	136	109	63	25	2	0	0	0	0	9	56	127
	HDD18.3	2321	389	337	299	221	126	42	15	14	68	154	278	376
	CDD10.0	1429	5	6	22	54	140	243	307	303	197	115	28	9
	CDD18.3	180	0	0	0	1	6	35	64	59	14	2	0	0
	CDH23.3	1731	0	0	0	12	73	367	584	551	137	7	0	0
	CDH26.7	559	0	0	0	0	11	122	196	199	31	0	0	0
Wind	WSAvg	3.0	3.5	3.4	3.4	3.1	3.0	2.8	2.9	2.6	2.5	2.6	2.9	3.3
Precipitation	PrecAvg	619	61	53	55	42	54	40	41	42	46	60	66	58
	PrecMax	857	139	114	112	131	142	104	100	135	112	169	140	144
	PrecMin	459	16	5	3	4	11	2	3	4	10	3	9	9
	PrecStd	105	31	27	25	28	34	26	26	32	28	43	32	37
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	14.0	16.4	21.0	25.0	28.2	34.0	34.0	34.6	30.0	24.3	18.0	14.7
		MCWB	12.3	11.3	13.2	16.1	18.7	21.8	20.9	22.2	19.3	17.8	15.0	12.7
	2%	DB	13.1	13.7	17.6	22.3	25.4	29.9	31.0	31.4	27.0	21.7	16.2	13.7
		MCWB	11.7	10.7	12.0	15.0	17.6	19.8	20.1	20.8	18.5	16.8	14.1	12.2
	5%	DB	12.2	12.4	15.4	19.6	23.1	27.4	28.9	28.8	24.5	19.8	15.0	12.8
		MCWB	10.9	10.3	11.2	13.5	16.2	18.8	19.4	19.6	17.3	15.9	13.2	11.5
	10%	DB	11.2	11.4	13.8	17.1	20.8	25.0	26.7	26.3	22.4	18.3	13.9	11.9
		MCWB	9.9	9.7	10.6	12.1	15.1	18.1	18.6	18.6	16.3	15.3	12.3	10.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.9	12.4	14.2	17.5	20.0	22.8	22.7	23.7	20.7	18.8	15.9	13.5
		MCDB	13.5	14.4	19.1	23.2	26.5	30.1	30.9	32.1	26.5	22.1	16.9	14.1
	2%	WB	12.1	11.5	12.9	15.4	18.2	20.7	21.2	21.7	19.3	17.6	14.5	12.6
		MCDB	12.9	12.9	16.0	20.8	23.7	27.7	28.9	29.1	24.4	20.1	15.8	13.5
	5%	WB	11.0	10.7	12.0	13.9	16.9	19.7	20.2	20.6	18.2	16.7	13.5	11.7
		MCDB	12.0	12.1	14.5	18.6	21.7	26.1	27.0	26.8	23.3	19.0	14.8	12.7
	10%	WB	10.0	10.0	11.2	12.6	15.7	18.5	19.2	19.5	17.2	15.8	12.4	10.8
		MCDB	11.1	11.3	13.3	16.3	19.9	24.0	25.2	24.7	21.0	17.9	13.7	11.9
Mean Daily Temperature Range	5% DB	MDBR	5.4	6.8	8.2	9.8	9.8	10.6	10.8	11.1	10.6	8.0	6.1	5.5
		MCDBR	5.2	7.8	10.9	13.6	13.6	14.9	14.9	15.5	14.1	9.7	6.6	5.4
		MCWBR	4.4	5.5	6.5	7.2	6.7	6.3	5.7	6.0	6.4	5.4	4.7	4.6
	5% WB	MCDBR	5.1	6.7	9.1	12.6	12.2	13.1	12.9	13.2	11.9	8.4	6.1	5.2
		MCWBR	4.6	5.2	5.7	6.9	6.4	6.3	5.3	5.6	6.0	5.2	4.8	4.7
Clear-Sky Solar Irradiance	taub	0.327	0.345	0.374	0.396	0.399	0.408	0.401	0.390	0.368	0.363	0.336	0.321	
	taud	2.432	2.379	2.294	2.234	2.274	2.284	2.303	2.354	2.395	2.414	2.431	2.408	
	Ebn at Noon	749	813	840	855	865	856	857	853	839	780	728	704	
	Edh at Noon	68	88	111	129	129	128	124	113	99	84	68	62	
All-Sky Solar Radiation	RadAvg	1.06	1.95	3.06	4.49	5.31	5.92	5.63	5.00	3.95	2.29	1.33	0.93	
	RadStd	0.10	0.22	0.34	0.51	0.41	0.55	0.33	0.43	0.29	0.17	0.12	0.11	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (27 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page