

BLOIS LE BREUIL AP, France

WMO: 072450

Lat: 47.6794N

Lon: 1.2125E

Elev: 398

StdP: 14.49

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	23.4	26.5	17.0	13.2	25.8	21.2	16.2	28.5	35.7	48.1	30.3	50.1	6.7	40	0.550

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	22.6	90.3	68.7	86.0	67.2	82.3	66.0	70.7	85.5	68.9	82.1	67.2	79.0	7.8	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.1	97.6	75.1	64.4	92.0	73.3	62.9	87.1	71.5	34.7	86.6	33.2	82.0	31.9	79.0	77.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.8	22.3	19.0	DB	19.0	96.7	5.6	4.4	15.0	99.9	11.7	102.5	8.5	105.0	4.4	108.2
			WB	18.3	73.9	5.6	1.8	14.2	75.2	10.9	76.3	7.8	77.3	3.7	78.6

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	53.1	40.0	40.2	46.1	51.2	56.9	64.1	67.8	67.0	61.5	54.9	46.3	40.9
	DBStd	11.79	6.90	7.27	6.35	5.79	5.76	5.90	5.78	5.68	5.26	6.41	6.48	6.74
	HDD50	1269	313	279	154	52	8	0	0	0	0	29	146	288
	HDD65	4648	775	696	587	415	258	86	35	41	132	314	562	747
	CDD50	2418	4	3	32	88	222	424	552	527	344	182	34	6
	CDD65	321	0	0	0	1	7	60	121	103	27	2	0	0
	CDH74	3688	0	0	0	25	114	672	1420	1133	300	24	0	0
	CDH80	1309	0	0	0	1	13	218	555	445	75	2	0	0
Wind	WSAvg	8.7	10.0	10.0	9.9	8.5	8.1	7.7	7.9	7.6	7.6	8.2	9.3	9.6
Precipitation	PrecAvg	25.9	2.3	2.0	1.9	1.8	2.6	2.1	2.1	1.8	1.6	2.7	2.6	2.5
	PrecMax	32.0	4.9	3.5	3.8	3.9	6.7	4.6	3.9	3.9	3.3	6.7	4.9	4.6
	PrecMin	18.4	1.4	0.4	0.6	0.4	0.0	0.4	0.0	0.2	0.6	0.5	1.2	0.8
	PrecStd	3.6	0.9	1.0	0.9	1.0	1.4	1.2	1.0	1.2	0.8	1.5	1.1	1.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	56.1	60.7	69.8	77.4	81.5	92.6	96.2	97.2	86.6	77.2	63.8	56.8
		MCWB	53.4	51.3	54.4	61.0	66.6	70.5	69.6	71.1	65.2	63.8	58.6	54.0
	2%	DB	54.0	55.6	64.7	72.4	77.2	85.8	90.3	90.3	81.8	71.8	60.3	54.8
		MCWB	51.9	50.0	53.1	59.1	63.4	68.3	68.7	68.6	64.7	61.5	57.0	52.3
	5%	DB	52.1	52.8	60.3	67.7	73.2	81.5	86.1	85.0	77.1	67.4	58.0	53.0
		MCWB	50.1	49.1	51.8	56.6	61.9	66.7	67.3	66.5	63.4	60.2	55.0	50.8
	10%	DB	50.0	50.5	56.5	63.3	69.3	77.2	82.1	80.1	73.1	64.2	55.5	51.0
		MCWB	48.0	47.6	50.5	53.9	59.5	64.9	66.1	64.6	61.5	58.6	53.0	49.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	54.1	53.1	57.2	63.8	69.2	72.8	72.4	72.3	68.9	65.5	59.9	54.9
		MCDB	55.3	57.4	66.1	74.1	78.9	85.1	90.7	90.5	80.3	72.7	61.5	55.9
	2%	WB	52.2	51.1	54.7	60.1	65.5	70.2	70.3	70.0	66.5	63.2	57.3	52.8
		MCDB	53.5	54.2	61.1	70.5	74.1	82.5	86.0	85.9	77.4	68.6	60.0	54.4
	5%	WB	50.3	49.5	53.0	57.2	62.9	68.1	68.5	67.8	64.6	61.2	55.2	51.1
		MCDB	51.9	52.3	58.5	66.3	70.9	78.6	82.5	80.8	74.0	66.3	57.5	52.9
	10%	WB	48.0	47.8	51.2	54.6	60.5	65.9	66.8	66.1	62.8	59.5	53.2	49.1
		MCDB	49.6	50.4	56.0	61.9	67.8	75.2	79.5	77.5	70.6	63.7	55.3	50.9
Mean Daily Temperature Range	5% DB	MDBR	9.4	12.5	16.5	19.5	19.6	20.7	22.6	22.0	20.4	15.5	11.4	9.9
		MCDBR	10.2	16.1	23.2	26.5	25.8	27.8	29.8	30.4	26.7	19.7	13.1	10.9
		MCWBR	8.7	11.5	13.6	14.8	14.4	12.6	11.2	12.0	12.1	11.1	9.6	9.0
	5% WB	MCDBR	9.9	14.3	19.1	24.8	23.2	24.9	26.2	24.6	21.4	17.3	12.1	9.8
		MCWBR	8.9	10.8	12.2	14.4	13.8	12.4	10.7	11.0	11.1	10.4	9.3	8.6
Clear-Sky Solar Irradiance	taub	0.322	0.342	0.370	0.398	0.400	0.411	0.406	0.394	0.366	0.361	0.334	0.318	
	taud	2.441	2.383	2.304	2.230	2.267	2.273	2.284	2.333	2.394	2.418	2.441	2.417	
	Ebn at Noon	239	258	267	271	274	271	271	269	266	248	232	224	
	Edh at Noon	21	28	35	41	41	41	40	37	31	26	21	19	
All-Sky Solar Radiation	RadAvg	323	583	965	1407	1657	1857	1793	1575	1220	725	390	277	
	RadStd	31	79	120	168	149	181	116	147	88	62	40	39	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	Regional (30 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page