

BLOIS LE BREUIL AP, France

WMO: 072450

Lat: 47.6794N

Lon: 1.2125E

Elev: 121

StdP: 99.88

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-4.8	-3.1	-8.3	1.9	-3.5	-6.0	2.3	-1.9	16.0	9.0	13.5	10.1	3.0	40	0.550

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.5	32.4	20.4	30.0	19.5	27.9	18.9	21.5	29.7	20.5	27.8	19.6	26.1	3.5	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.9	13.9	24.0	18.0	13.1	23.0	17.2	12.4	21.9	62.9	30.3	59.4	27.8	56.3	26.1	25.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
12.0	10.0	8.5	-7.2	36.0	3.1	2.5	-9.5	37.7	-11.3	39.2	-13.1	40.5	-15.3	42.3		
			DB	WB	DB	WB	DB	WB	DB	WB	DB	WB	DB	WB		
			-7.6	23.3	3.1	1.0	-9.9	24.0	-11.7	24.6	-13.5	25.1	-15.7	25.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	11.7	4.5	4.5	7.8	10.7	13.8	17.9	19.9	19.4	16.4	12.7	7.9	5.0
	DBStd	6.55	3.84	4.04	3.53	3.22	3.20	3.28	3.21	3.16	2.92	3.56	3.60	3.75
	HDD10.0	705	174	155	86	29	4	0	0	0	0	16	81	160
	HDD18.3	2582	431	387	326	231	143	48	19	23	73	174	312	415
	CDD10.0	1343	2	2	18	49	123	236	307	293	191	101	19	3
	CDD18.3	178	0	0	0	1	4	33	67	57	15	1	0	0
	CDH23.3	2049	0	0	0	14	63	373	789	629	167	13	0	0
	CDH26.7	727	0	0	0	1	7	121	308	247	42	1	0	0
Wind	WSAvg	3.9	4.5	4.5	4.4	3.8	3.6	3.4	3.5	3.4	3.4	3.7	4.2	4.3
Precipitation	PrecAvg	659	59	50	48	46	67	53	53	46	40	68	65	64
	PrecMax	813	124	89	96	99	171	117	99	100	85	171	125	116
	PrecMin	468	36	11	15	11	0	9	1	6	16	12	31	20
	PrecStd	92	24	25	24	26	36	31	26	31	20	39	27	29
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.4	15.9	21.0	25.2	27.5	33.7	35.7	36.2	30.3	25.1	17.7	13.8
		MCWB	11.9	10.7	12.4	16.1	19.2	21.4	20.9	21.7	18.4	17.7	14.8	12.2
	2%	DB	12.2	13.1	18.2	22.5	25.1	29.9	32.4	32.4	27.7	22.1	15.7	12.7
		MCWB	11.1	10.0	11.7	15.0	17.5	20.2	20.4	20.3	18.2	16.4	13.9	11.3
	5%	DB	11.2	11.6	15.7	19.8	22.9	27.5	30.1	29.4	25.1	19.7	14.4	11.7
		MCWB	10.1	9.5	11.0	13.6	16.6	19.3	19.6	19.2	17.5	15.7	12.8	10.4
	10%	DB	10.0	10.3	13.6	17.4	20.7	25.1	27.8	26.7	22.8	17.9	13.1	10.6
		MCWB	8.9	8.7	10.3	12.1	15.3	18.3	19.0	18.1	16.4	14.8	11.7	9.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.3	11.7	14.0	17.7	20.6	22.7	22.4	22.4	20.5	18.6	15.5	12.7
		MCDB	13.0	14.1	18.9	23.4	26.1	29.5	32.6	32.5	26.8	22.6	16.4	13.3
	2%	WB	11.2	10.6	12.6	15.6	18.6	21.2	21.3	21.1	19.2	17.3	14.1	11.6
		MCDB	12.0	12.3	16.1	21.4	23.4	28.0	30.0	30.0	25.2	20.3	15.5	12.4
	5%	WB	10.1	9.7	11.7	14.0	17.2	20.1	20.3	19.9	18.1	16.2	12.9	10.6
		MCDB	11.0	11.3	14.7	19.0	21.6	25.9	28.1	27.1	23.3	19.1	14.2	11.6
	10%	WB	8.9	8.8	10.7	12.6	15.8	18.8	19.3	18.9	17.1	15.3	11.8	9.5
		MCDB	9.8	10.2	13.3	16.6	19.9	24.0	26.4	25.3	21.5	17.6	12.9	10.5
Mean Daily Temperature Range	5% DB	MDBR	5.2	6.9	9.2	10.8	10.9	11.5	12.5	12.2	11.3	8.6	6.3	5.5
		MCDBR	5.7	8.9	12.9	14.7	14.3	15.4	16.5	16.9	14.8	11.0	7.3	6.1
		MCWBR	4.8	6.4	7.6	8.2	8.0	7.0	6.2	6.7	6.7	6.2	5.3	5.0
	5% WB	MCDBR	5.5	7.9	10.6	13.8	12.9	13.8	14.6	13.7	11.9	9.6	6.7	5.5
		MCWBR	4.9	6.0	6.8	8.0	7.7	6.9	5.9	6.1	6.1	5.8	5.2	4.8
Clear-Sky Solar Irradiance	taub	0.322	0.342	0.370	0.398	0.400	0.411	0.406	0.394	0.366	0.361	0.334	0.318	
	taud	2.441	2.383	2.304	2.230	2.267	2.273	2.284	2.333	2.394	2.418	2.441	2.417	
	Ebn at Noon	755	814	843	853	863	854	853	847	840	781	730	707	
	Edh at Noon	67	87	109	130	130	130	127	116	99	83	67	61	
All-Sky Solar Radiation	RadAvg	1.02	1.84	3.04	4.44	5.22	5.86	5.65	4.96	3.85	2.29	1.23	0.87	
	RadStd	0.10	0.25	0.38	0.53	0.47	0.57	0.37	0.46	0.28	0.20	0.13	0.12	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (30 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page