

ORLEANS BRICY AB, France

WMO: 072490

Lat: 47.9908N

Lon: 1.7783E

Elev: 412

StdP: 14.48

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	21.5	25.1	16.0	12.6	24.0	20.3	15.4	27.3	29.6	51.3	26.8	49.8	7.0	50	0.563

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.5	88.4	68.4	84.6	66.9	81.1	65.6	70.4	83.8	68.6	80.9	67.0	78.0	8.0	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
66.2	97.9	74.7	64.5	92.1	73.3	62.9	87.0	71.4	34.5	84.0	33.0	80.9	31.7	77.9	79.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
24.4	21.4	19.0	DB	16.0	94.6	5.8	4.1	11.8	97.6	8.4	100.0	5.1	102.3	0.9	105.2
			WB	15.6	74.0	5.7	2.3	11.5	75.7	8.1	77.0	4.9	78.3	0.8	80.0

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	52.6	39.3	40.7	45.5	50.6	56.9	63.0	66.9	66.3	60.3	54.2	45.6	40.5	(6)
	DBStd	11.67	7.45	7.26	6.30	6.12	6.00	6.10	5.56	5.59	5.27	6.38	6.76	7.19	(7)
	HDD50	1336	334	263	167	64	10	1	0	0	1	32	163	301	(8)
	HDD65	4807	796	679	604	433	258	108	43	49	158	337	583	759	(9)
	CDD50	2270	3	4	28	82	225	391	524	504	310	162	30	7	(10)
	CDD65	267	0	0	0	0	9	48	102	88	18	2	0	0	(11)
	CDH74	3068	0	0	0	23	120	571	1161	959	213	21	0	0	(12)
	CDH80	984	0	0	0	1	13	179	402	342	46	1	0	0	(13)
(14) Wind	WSAvg	9.1	10.3	10.2	10.3	9.3	8.7	8.3	8.3	7.9	8.2	8.7	9.3	10.3	(14)
(15) Precipitation	PrecAvg	25.2	2.2	1.9	2.0	1.9	2.6	1.9	2.1	1.7	2.0	2.4	2.4	2.1	(15)
	PrecMax	34.4	4.3	4.1	4.3	4.8	5.8	4.1	4.7	4.4	5.7	7.1	5.4	4.4	(16)
	PrecMin	16.3	0.4	0.3	0.1	0.4	0.4	0.0	0.4	0.2	0.3	0.3	0.6	0.1	(17)
	PrecStd	4.9	1.1	1.0	1.0	1.0	1.4	0.9	0.9	1.1	1.4	1.7	1.1	1.1	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.7	61.2	69.3	76.9	81.7	90.8	93.9	93.3	85.1	76.9	63.7	57.1	(19)
		MCWB	52.8	51.0	54.8	60.6	66.4	71.5	69.3	69.0	64.9	63.0	58.1	54.3	(20)
	2%	DB	53.8	55.6	63.8	72.1	77.4	84.9	88.3	88.1	80.1	71.2	59.8	54.9	(21)
		MCWB	51.3	49.4	53.1	58.3	63.3	67.9	68.2	67.9	63.8	61.7	56.2	52.2	(22)
	5%	DB	51.8	52.7	59.5	67.0	73.6	80.4	84.5	83.9	75.5	66.8	57.4	53.0	(23)
		MCWB	49.5	48.9	51.4	55.6	61.7	66.5	66.6	66.8	62.4	59.9	54.3	50.8	(24)
	10%	DB	49.5	50.6	56.1	62.4	69.6	76.2	80.7	79.4	71.6	63.7	54.9	51.1	(25)
		MCWB	47.5	47.7	50.2	53.2	59.8	64.3	65.6	64.8	60.7	58.3	52.5	49.1	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	53.9	53.1	56.8	63.0	68.5	73.2	72.1	71.8	68.3	65.1	59.3	54.9	(27)
		MCDB	55.1	56.8	64.6	74.4	78.6	85.9	87.2	86.3	77.7	72.1	61.9	56.3	(28)
	2%	WB	51.8	51.1	54.6	59.2	65.2	70.0	70.0	69.7	65.7	62.8	56.8	52.9	(29)
		MCDB	53.3	54.2	60.8	69.3	74.8	81.1	84.8	83.4	75.1	68.4	59.2	54.4	(30)
	5%	WB	49.8	49.5	52.7	56.6	62.7	67.8	68.3	67.8	63.9	61.0	54.7	51.1	(31)
		MCDB	51.6	52.3	57.9	64.9	71.3	77.9	81.4	80.1	73.4	65.8	57.0	52.8	(32)
	10%	WB	47.6	47.7	50.9	54.1	60.4	65.5	66.6	66.1	62.0	59.2	52.7	49.2	(33)
		MCDB	49.2	50.5	55.6	61.1	67.9	74.7	77.8	76.6	69.4	63.1	54.7	50.9	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	9.3	12.5	16.3	19.1	19.0	20.2	21.5	21.3	19.4	15.4	11.1	9.7	(35)
		MCDBR	10.3	15.8	22.4	26.4	25.1	27.6	29.2	28.6	26.4	19.7	12.6	10.7	(36)
		MCWBR	8.7	11.0	13.3	14.2	13.3	13.0	11.6	11.4	12.5	11.3	9.2	8.7	(37)
	5% WB	MCDBR	9.7	13.9	18.3	23.3	22.8	24.7	25.4	25.0	21.4	17.1	11.8	9.6	(38)
		MCWBR	8.7	10.5	11.8	13.2	13.2	13.0	11.2	11.7	11.5	10.6	9.2	8.5	(39)
(40) Clear-Sky Solar Irradiance	taub		0.323	0.342	0.371	0.399	0.403	0.412	0.408	0.397	0.368	0.361	0.334	0.319	(40)
	taud		2.438	2.386	2.302	2.226	2.255	2.269	2.272	2.323	2.389	2.416	2.442	2.412	(41)
	Ebn at Noon		238	257	266	270	273	271	270	267	265	247	230	222	(42)
	Edh at Noon		21	27	35	41	42	41	41	37	31	26	21	19	(43)
(44) All-Sky Solar Radiation	RadAvg		311	567	947	1397	1646	1848	1769	1549	1200	713	378	266	(44)
	RadStd		33	78	118	163	152	178	127	147	91	60	38	39	(45)

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (32 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page