

POINTE DE CHASSIRON, France

WMO: **073140**Lat: **46.0469N**Lon: **1.4117W**Elev: **72**StdP: **14.66**Time Zone: **1.00 (EUC)**Period: **94-19**WBAN: **99999**

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	30.8	33.3	22.4	16.9	32.3	25.9	19.9	35.1	38.9	52.2	35.3	51.0	14.0	50	0.584

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.9	79.1	69.3	76.2	68.3	73.8	67.0	71.0	76.7	69.5	74.4	68.1	72.5	7.6	40

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
69.1	107.2	73.8	67.6	101.6	72.4	66.3	97.1	71.2	34.9	77.0	33.6	74.6	32.4	72.7	79.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 32.1	28.3	25.3	DB	27.8	88.0	4.0	4.1	24.9	90.9	22.6	93.3	20.3	95.6	17.4	98.5	(4)
(5)			WB	25.8	73.7	4.0	2.2	22.9	75.3	20.6	76.6	18.3	77.8	15.4	79.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	56.6	45.7	46.1	50.0	53.6	59.0	64.5	67.4	68.0	64.6	59.8	52.5	47.5	(6)	
	DBStd	9.23	5.88	5.37	4.32	4.05	3.98	4.14	3.68	3.54	3.63	4.47	5.08	6.17	(7)	
	HDD50	490	151	121	52	12	0	0	0	0	0	2	33	119	(8)	
	HDD65	3341	600	529	465	341	192	58	15	8	49	167	374	543	(9)	
	CDD50	2904	16	12	51	121	279	434	540	557	438	306	109	41	(10)	
	CDD65	280	0	0	0	0	5	42	90	100	37	6	0	0	(11)	
	CDH74	546	0	0	0	1	10	113	165	191	60	6	0	0	(12)	
	CDH80	79	0	0	0	0	1	23	24	25	6	0	0	0	(13)	
(14) Wind	WSAvg	12.5	14.0	14.0	13.0	12.6	11.9	11.0	10.9	10.7	11.2	12.1	14.7	14.3	(14)	
(15) Precipitation	PrecAvg	27.6	2.8	2.2	1.9	2.3	1.8	1.4	1.6	1.7	2.2	3.1	3.7	3.1	(15)	
	PrecMax	40.0	6.3	4.6	6.1	8.7	3.2	2.9	4.5	4.6	7.6	6.3	9.8	5.6	(16)	
	PrecMin	20.4	0.4	0.1	0.2	0.6	0.6	0.2	0.2	0.3	0.0	0.3	0.8	0.6	(17)	
	PrecStd	5.1	1.5	1.2	1.3	1.6	0.7	0.7	0.8	1.2	1.8	1.6	1.9	1.5	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	56.6	57.6	64.7	68.7	75.0	83.2	83.2	83.2	79.7	73.6	64.8	59.2	(19)	
		MCWB	53.4	51.5	56.3	60.2	65.0	69.8	70.6	71.4	68.6	65.0	60.2	55.9	(20)	
	2%	DB	55.0	54.8	60.2	64.5	71.2	76.8	78.0	78.5	75.1	69.5	62.3	57.4	(21)	
		MCWB	52.4	51.2	53.8	57.2	63.1	67.6	68.8	70.2	66.8	63.7	58.7	54.3	(22)	
	5%	DB	53.9	53.4	57.4	61.9	67.7	73.2	75.1	75.6	72.3	67.3	60.6	56.3	(23)	
		MCWB	51.5	50.7	52.5	56.2	61.4	65.7	68.0	69.0	65.5	63.0	57.5	53.6	(24)	
	10%	DB	52.9	52.2	55.3	59.6	64.9	70.4	72.6	73.0	70.1	65.5	59.3	55.2	(25)	
		MCWB	50.6	49.9	51.7	54.9	59.9	64.7	67.0	67.7	64.5	61.8	56.2	52.9	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	54.5	53.6	56.8	61.1	66.6	71.7	72.4	74.8	70.4	66.6	61.2	56.9	(27)	
		MCDB	55.5	55.6	62.9	66.5	73.2	80.8	79.5	79.1	76.2	70.4	63.4	58.2	(28)	
	2%	WB	53.1	52.2	54.8	58.6	63.9	69.0	70.2	71.7	68.3	65.0	59.6	55.3	(29)	
		MCDB	54.3	53.8	58.4	62.9	69.3	75.0	75.6	76.5	72.9	68.0	61.8	56.5	(30)	
	5%	WB	52.1	51.3	53.5	56.9	62.0	66.9	68.8	69.9	66.9	63.7	58.2	54.2	(31)	
		MCDB	53.5	52.8	56.1	60.9	66.5	71.6	73.6	74.1	70.9	66.4	60.3	55.7	(32)	
	10%	WB	51.0	50.5	52.4	55.4	60.5	65.3	67.5	68.3	65.5	62.4	56.6	53.2	(33)	
		MCDB	52.6	52.1	54.8	58.8	64.4	69.6	71.9	72.3	69.3	65.1	58.9	55.0	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	6.6	6.8	8.0	8.2	8.0	8.4	7.7	7.9	8.7	7.9	7.1	6.8	(35)	
		MCDBR	6.1	7.7	11.7	12.7	13.3	14.3	12.7	12.8	12.7	10.6	7.9	6.5	(36)	
	5% WB	MCWBR	5.5	6.2	7.8	8.2	8.2	7.9	7.2	7.4	7.5	7.0	6.5	5.9	(37)	
		MCWBR	5.6	6.5	9.5	11.1	11.5	12.5	10.8	10.5	10.8	9.2	7.1	5.9	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.331	0.345	0.373	0.393	0.398	0.408	0.400	0.391	0.370	0.369	0.343	0.327	(40)	
		taud	2.470	2.428	2.358	2.310	2.351	2.352	2.375	2.416	2.451	2.456	2.460	2.452	(41)	
	Ebn at Noon		243	263	270	274	276	273	273	272	268	250	235	230	(42)	
		Edh at Noon	22	27	34	38	38	38	37	34	30	26	22	20	(43)	
(44) All-Sky Solar Radiation	RadAvg		386	691	1068	1509	1766	1976	1912	1694	1345	811	467	343	(44)	
	RadStd		38	71	120	142	135	148	93	118	88	69	51	42	(45)	

Historical Trends