

POITIERS-BIARD AP, France

WMO: 073350

Lat: 46.5939N

Lon: 0.3144E

Elev: 129

StdP: 99.79

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-5.4	-3.4	-8.3	1.9	-3.5	-6.2	2.3	-1.9	12.5	9.9	11.2	9.3	2.8	30	0.532

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.1	32.0	20.6	29.9	19.6	27.9	18.9	21.6	29.2	20.7	27.7	19.8	26.1	3.5	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.2	14.2	24.1	18.3	13.4	23.0	17.5	12.7	22.2	63.3	29.4	60.1	27.7	57.0	26.2	26.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
10.1	8.8	7.8	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
			-8.0	35.4	2.8	1.8	-10.0	36.7	-11.6	37.7	-13.2	38.7	-15.2	40.1
			-8.3	23.4	2.8	0.9	-10.4	24.1	-12.0	24.6	-13.6	25.1	-15.6	25.8
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	12.0	5.0	5.6	8.3	10.6	14.1	17.8	19.7	19.5	16.3	13.1	8.1	5.5
	DBStd	6.36	4.02	3.88	3.32	3.24	3.28	3.56	3.17	3.22	3.00	3.61	3.64	4.10
	HDD10.0	629	158	127	74	29	4	0	0	0	0	14	77	146
	HDD18.3	2493	413	357	312	231	137	53	21	22	76	166	307	399
	CDD10.0	1357	3	3	19	49	131	233	302	296	188	109	20	6
	CDD18.3	180	0	0	0	1	5	36	64	59	14	2	0	0
	CDH23.3	2098	0	0	0	14	88	412	708	678	181	16	0	0
	CDH26.7	712	0	0	0	1	14	133	250	269	43	2	0	0
Wind	WSAvg	3.7	4.1	4.2	4.1	3.9	3.6	3.4	3.5	3.2	3.2	3.4	3.8	4.1
Precipitation	PrecAvg	712	67	57	55	52	70	49	46	52	54	66	77	66
	PrecMax	991	147	150	113	150	153	134	103	169	139	188	169	144
	PrecMin	470	11	6	2	4	12	0	10	10	7	5	10	7
	PrecStd	118	34	34	29	32	35	27	25	39	32	44	43	39
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.9	17.0	21.4	25.1	28.6	33.8	34.4	36.0	30.5	25.3	18.8	14.6
		MCWB	11.7	10.7	12.9	15.9	19.0	21.5	20.7	21.1	18.7	17.7	14.6	12.2
	2%	DB	12.7	14.2	18.7	22.3	25.8	30.1	31.7	32.2	27.7	22.7	16.4	13.4
		MCWB	11.2	10.1	11.9	14.4	17.3	19.8	20.3	20.7	18.0	16.8	13.7	11.7
	5%	DB	11.7	12.3	16.3	19.8	23.5	27.8	29.3	29.7	25.4	20.5	14.9	12.4
		MCWB	10.3	9.6	11.1	13.3	16.4	19.1	19.4	19.8	17.6	16.1	12.9	11.0
	10%	DB	10.6	11.0	14.2	17.3	21.3	25.4	27.3	27.2	23.0	18.7	13.5	11.3
		MCWB	9.3	9.2	10.3	11.9	15.5	18.2	18.7	18.9	16.5	15.3	11.9	10.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.6	12.2	14.0	16.8	20.0	22.8	22.3	22.9	20.7	18.8	15.6	13.1
		MCDB	13.1	14.7	19.4	23.2	26.6	30.0	30.8	31.3	26.6	22.6	17.1	13.8
	2%	WB	11.5	11.0	12.8	15.1	18.4	21.0	21.3	21.6	19.4	17.6	14.3	12.1
		MCDB	12.4	12.8	16.7	21.0	24.1	28.1	29.1	29.2	25.2	20.9	15.8	13.1
	5%	WB	10.4	10.2	11.9	13.7	17.1	19.9	20.3	20.7	18.2	16.6	13.1	11.2
		MCDB	11.4	11.9	15.2	18.7	22.2	26.3	27.4	27.8	23.6	19.7	14.6	12.2
	10%	WB	9.4	9.4	10.9	12.4	15.8	18.7	19.4	19.6	17.2	15.7	12.0	10.2
		MCDB	10.4	10.9	13.7	16.5	20.4	24.2	25.8	25.5	21.7	18.3	13.4	11.3
Mean Daily Temperature Range	5% DB	MDBR	6.0	7.8	9.7	10.5	10.9	11.6	12.1	12.3	11.7	9.2	7.2	6.3
		MCDBR	6.5	9.9	13.5	14.8	14.7	15.0	15.8	16.9	15.7	11.6	8.5	6.8
		MCWBR	5.2	6.7	8.0	8.1	7.6	6.6	6.2	6.4	7.2	6.5	5.9	5.3
	5% WB	MCDBR	5.8	8.1	11.0	13.1	13.2	13.1	13.5	14.0	12.6	9.7	7.6	6.0
		MCWBR	5.0	6.0	7.1	7.6	7.4	6.4	5.9	6.1	6.6	5.8	5.7	5.1
Clear-Sky Solar Irradiance	taub	0.321	0.339	0.367	0.393	0.397	0.411	0.400	0.391	0.363	0.360	0.334	0.317	
	taud	2.451	2.393	2.313	2.241	2.283	2.280	2.305	2.350	2.407	2.425	2.444	2.440	
	Ebn at Noon	771	828	853	861	869	856	860	854	849	791	744	729	
	Edh at Noon	69	88	110	129	128	129	125	115	99	84	69	62	
All-Sky Solar Radiation	RadAvg	1.13	2.01	3.20	4.50	5.26	6.00	5.85	5.16	4.05	2.45	1.37	0.99	
	RadStd	0.12	0.25	0.38	0.54	0.46	0.57	0.36	0.44	0.25	0.20	0.15	0.15	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (24 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page