

DOLE-JURA AP, France

WMO: 073860

Lat: 47.0439N

Lon: 5.4272E

Elev: 195

StdP: 99.00

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-6.8	-4.8	-10.7	1.5	-5.0	-7.7	2.0	-3.4	14.0	10.0	12.2	7.8	3.1	20	0.518

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.0	32.5	20.8	30.5	20.3	28.7	19.8	22.0	29.5	21.1	28.6	20.4	27.1	3.5	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.6	14.7	24.7	18.8	13.9	23.4	18.1	13.3	22.7	64.9	29.4	61.9	28.7	59.3	27.1	25.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.6	9.6	8.2	-9.9	35.4	3.2	2.0	-12.3	36.8	-14.2	38.0	-16.0	39.1	-18.3	40.6		
(5)			-10.3	23.5	3.3	0.7	-12.7	24.1	-14.6	24.5	-16.4	24.9	-18.8	25.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	11.6	3.0	3.7	7.5	11.2	14.4	19.0	20.7	20.0	16.6	12.5	6.9	3.6		
	DBStd	7.31	4.23	3.91	3.84	3.37	3.31	3.40	3.23	3.19	3.08	3.82	3.82	4.32		
	HDD10.0	848	220	176	94	26	3	0	0	0	0	21	107	201		
	HDD18.3	2681	477	408	334	214	128	32	13	18	69	184	344	457		
	CDD10.0	1445	2	1	18	62	140	272	332	309	197	97	13	2		
	CDD18.3	233	0	0	0	0	7	53	87	68	17	2	0	0		
	CDH23.3	2517	0	0	0	22	102	561	955	702	165	10	0	0		
	CDH26.7	876	0	0	0	1	14	177	384	269	32	0	0	0		
(14) Wind	WSAvg	3.4	3.8	4.0	4.1	3.5	3.3	3.0	2.8	2.7	2.9	3.1	3.5	3.8		
(15) Precipitation	PrecAvg	875	62	57	55	68	84	74	78	74	71	90	93	68		
	PrecMax	1107	144	108	215	160	167	144	154	132	147	198	256	127		
	PrecMin	665	16	3	5	1	16	13	23	16	3	17	31	6		
	PrecStd	116	32	30	43	40	38	34	35	33	42	42	54	32		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.6	15.5	20.8	26.0	28.7	33.1	35.5	36.2	29.6	24.8	18.2	14.5		
		MCWB	10.8	9.9	12.2	16.3	18.9	21.0	20.7	21.1	19.3	17.0	14.2	11.2		
	2%	DB	12.1	13.3	18.8	23.3	26.0	30.8	32.7	32.2	27.4	22.4	16.1	12.6		
		MCWB	10.0	9.0	11.6	14.9	17.6	21.1	20.8	20.9	19.0	16.6	13.0	10.3		
	5%	DB	10.8	11.4	16.6	21.0	24.1	28.7	30.8	29.8	25.2	20.4	14.3	11.2		
		MCWB	9.0	8.3	10.6	13.7	16.9	20.3	20.2	20.3	18.2	15.9	12.1	9.6		
	10%	DB	9.1	9.9	14.5	18.7	21.8	26.8	28.8	27.4	23.1	18.6	12.7	9.9		
		MCWB	7.7	7.6	9.9	12.4	15.6	19.1	19.5	19.4	17.2	15.1	11.1	8.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.6	10.8	13.2	17.1	20.3	23.1	22.6	23.1	20.9	18.5	14.5	11.8		
		MCDB	12.9	13.9	18.5	24.6	26.4	29.9	30.9	30.5	26.9	22.6	17.0	13.5		
	2%	WB	10.2	9.7	12.1	15.3	18.7	22.0	21.7	21.6	19.8	17.3	13.3	10.6		
		MCDB	11.6	12.5	17.0	21.8	24.4	28.6	29.8	29.5	25.6	21.1	15.3	12.1		
	5%	WB	9.1	8.7	11.2	14.1	17.4	20.9	20.9	20.8	18.7	16.3	12.3	9.7		
		MCDB	10.7	11.0	15.5	20.2	22.4	27.4	28.9	28.1	24.0	19.4	14.1	11.1		
	10%	WB	7.8	7.7	10.3	12.9	16.2	19.8	20.1	20.0	17.7	15.3	11.1	8.6		
		MCDB	9.0	9.8	14.1	17.8	20.6	25.6	27.2	25.8	22.1	18.1	12.7	9.8		
(35) Mean Daily Temperature Range	5% DB	MDBR	5.4	7.6	10.1	11.2	10.8	11.6	12.0	11.5	10.8	9.1	6.5	5.5		
		MCDBR	6.5	11.2	14.6	16.0	14.9	14.9	15.9	15.9	14.2	12.0	8.8	7.3		
	5% WB	MCWBR	4.8	7.7	8.4	8.5	7.8	6.5	5.6	6.2	6.8	6.9	6.2	5.6		
		MCWBR	6.1	9.9	12.4	14.9	13.2	14.0	14.3	13.7	12.3	10.2	7.9	7.0		
(40) Clear-Sky Solar Irradiance	taub	taub	0.312	0.333	0.361	0.396	0.402	0.409	0.405	0.399	0.377	0.363	0.330	0.309		
		taud	2.455	2.399	2.338	2.251	2.280	2.297	2.304	2.335	2.376	2.410	2.452	2.455		
	Ebn at Noon	Ebn at Noon	778	832	857	857	863	857	855	844	831	784	745	734		
		Edh at Noon	67	86	106	127	128	127	125	116	102	85	67	60		
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1.07	1.90	3.17	4.43	5.18	6.05	5.79	5.01	3.87	2.38	1.26	0.88		
	RadStd	RadStd	0.14	0.30	0.42	0.61	0.55	0.56	0.50	0.43	0.31	0.19	0.12	0.14		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (63 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page