

BRIVE-LA-GAILLARDE, France

WMO: 074380

Lat: 45.1468N

Lon: 1.4733E

Elev: 379

StdP: 14.50

Time Zone: 1.00 (EUC)

Period: 99-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	20.8	23.8	15.3	12.1	27.6	18.7	14.3	28.4	17.3	47.6	15.3	47.5	1.5	130	0.442

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	23.8	93.4	70.1	89.6	69.3	86.2	68.0	72.7	87.2	71.0	85.4	69.4	83.0	6.1	310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
68.0	104.3	79.1	66.4	98.4	76.7	64.8	93.2	74.5	36.5	87.0	34.9	85.7	33.6	83.2	79.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
15.3	12.9	11.1	DB	16.1	99.0	4.5	3.6	12.8	101.6	10.2	103.7	7.6	105.8	4.3	108.4
			WB	15.3	76.1	4.5	1.6	12.1	77.2	9.5	78.2	7.0	79.1	3.7	80.3

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	55.1	41.0	42.2	48.2	53.3	59.9	67.0	70.0	69.1	63.4	57.0	47.5	42.2
	DBStd	12.12	6.84	7.11	6.07	5.58	5.78	6.07	5.65	5.68	5.57	6.80	6.87	7.05
	HDD50	1048	286	226	106	28	2	0	0	0	0	20	127	253
	HDD65	4103	743	637	522	351	179	48	17	22	95	257	526	706
	CDD50	2924	8	8	50	128	309	509	619	591	402	237	51	12
	CDD65	503	0	0	0	1	20	107	171	149	46	9	0	0
	CDH74	6618	0	0	6	88	394	1421	2107	1829	681	91	1	0
	CDH80	2631	0	0	0	10	96	562	924	820	208	11	0	0
(14) Wind	WSAvg	3.9	3.7	4.5	4.7	4.5	4.3	4.2	4.1	3.6	3.4	3.4	3.6	3.5
(15) Precipitation	PrecAvg	36.5	3.3	2.8	2.7	3.6	3.3	2.8	2.6	2.8	2.6	3.2	3.8	3.0
	PrecMax	42.9	7.4	6.1	6.7	7.8	5.7	7.2	7.2	6.7	6.6	7.2	8.7	6.3
	PrecMin	27.0	0.7	0.4	0.4	0.6	1.5	0.8	0.4	0.6	1.0	1.1	1.1	0.6
	PrecStd	4.1	1.7	1.5	1.6	2.1	1.3	1.3	1.4	1.5	1.3	1.5	1.7	1.5
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	59.7	66.4	74.8	81.5	87.3	96.2	98.1	99.5	90.4	81.4	69.4	62.1
		MCWB	52.2	51.3	55.7	60.6	67.3	71.5	69.4	70.4	67.3	65.5	59.3	53.6
	2%	DB	56.5	60.8	69.9	76.2	82.7	90.1	92.6	93.7	85.6	76.3	65.0	58.5
		MCWB	51.9	50.6	54.3	59.1	64.9	69.9	70.3	69.9	66.6	63.9	56.9	52.6
	5%	DB	54.2	57.2	65.4	72.0	78.5	86.7	88.9	89.1	81.7	72.7	61.8	55.6
		MCWB	50.4	49.2	52.6	56.7	63.1	68.3	69.5	68.9	65.4	62.2	55.7	51.5
	10%	DB	51.7	53.7	61.2	67.3	74.2	82.6	85.3	84.2	77.7	69.3	58.5	53.1
		MCWB	48.4	48.3	50.6	55.0	60.9	66.8	68.0	68.0	64.0	60.7	54.2	49.8
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	54.9	54.0	58.1	62.7	69.4	74.9	74.3	74.9	71.8	67.6	60.5	55.6
		MCDB	56.7	61.1	69.1	76.8	82.5	88.4	88.9	90.4	84.4	76.7	66.3	58.8
	2%	WB	53.1	52.1	55.7	60.2	66.6	71.9	72.4	72.2	68.5	65.2	58.4	53.7
		MCDB	55.6	57.8	65.5	73.9	79.3	86.2	87.5	86.4	79.9	73.0	63.1	57.3
	5%	WB	50.8	50.5	54.0	57.9	64.3	69.9	70.7	70.2	66.7	63.4	56.4	52.0
		MCDB	53.5	55.2	62.3	69.3	75.4	83.6	85.6	84.7	77.8	70.4	60.7	55.4
	10%	WB	48.7	48.8	52.2	55.9	62.2	68.0	68.9	68.7	65.0	61.6	54.4	50.0
		MCDB	51.4	53.5	59.4	65.3	71.9	79.3	82.6	82.0	75.2	68.0	58.2	52.7
(35) Mean Daily Temperature Range	5% DB	MDBR	14.5	18.7	21.7	22.4	22.0	23.4	23.8	24.6	24.6	20.9	16.2	15.2
		MCDBR	17.0	26.0	32.4	33.3	31.2	31.9	32.2	35.1	32.3	26.1	21.4	18.7
		MCWBR	12.1	16.6	18.3	17.4	15.4	13.7	12.5	13.6	15.0	14.5	14.0	13.3
	5% WB	MCDBR	12.8	19.8	25.8	28.7	26.8	27.6	28.2	28.2	26.6	21.2	18.1	15.2
		MCWBR	9.8	13.4	15.3	15.4	13.8	12.5	12.0	12.3	13.5	12.2	12.4	11.3
(40) Clear-Sky Solar Irradiance	taub		0.313	0.328	0.362	0.395	0.399	0.411	0.403	0.400	0.369	0.362	0.332	0.311
	taud		2.491	2.439	2.361	2.264	2.304	2.307	2.326	2.345	2.410	2.443	2.477	2.491
	Ebn at Noon		255	271	275	274	276	272	273	270	270	255	244	243
	Edh at Noon		22	27	34	40	40	40	39	37	32	27	22	20
(44) All-Sky Solar Radiation	RadAvg		410	700	1065	1428	1674	1942	1905	1681	1337	853	480	374
	RadStd		51	88	129	185	146	170	139	125	89	71	61	56

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (23 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page