

BRIVE-LA-GAILLARDE, France

WMO: 074380

Lat: 45.1468N

Lon: 1.4733E

Elev: 116

StdP: 99.95

Time Zone: 1.00 (EUC)

Period: 99-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-6.2	-4.6	-9.3	1.7	-2.4	-7.4	2.0	-2.0	7.7	8.6	6.9	8.6	0.7	130	0.442

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.2	34.1	21.2	32.0	20.7	30.1	20.0	22.6	30.7	21.7	29.6	20.8	28.3	2.7	310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.0	14.9	26.2	19.1	14.1	24.8	18.2	13.3	23.6	67.0	30.6	63.4	29.8	60.3	28.4	26.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
6.8	5.8	5.0		-8.9	37.2	2.5	2.0	-10.7	38.7	-12.1	39.8	-13.5	41.0	-15.4	42.4	
			DB	-9.3	24.5	2.5	0.9	-11.0	25.1	-12.5	25.6	-13.9	26.2	-15.7	26.8	
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	12.9	5.0	5.7	9.0	11.9	15.5	19.4	21.1	20.6	17.4	13.9	8.6	5.7
	DBStd	6.73	3.80	3.95	3.37	3.10	3.21	3.37	3.14	3.16	3.10	3.78	3.82	3.92
	HDD10.0	582	159	126	59	16	1	0	0	0	0	11	71	141
	HDD18.3	2279	413	354	290	195	99	27	9	12	53	143	292	392
	CDD10.0	1624	4	4	28	71	172	283	344	328	223	132	28	7
	CDD18.3	279	0	0	0	1	11	59	95	83	26	5	0	0
	CDH23.3	3677	0	0	3	49	219	789	1171	1016	378	51	1	0
	CDH26.7	1462	0	0	0	6	53	312	513	456	116	6	0	0
(14) Wind	WSAvg	1.8	1.7	2.0	2.1	2.0	1.9	1.9	1.8	1.6	1.5	1.5	1.6	1.5
(15) Precipitation	PrecAvg	926	84	71	68	92	83	71	67	71	66	82	96	76
	PrecMax	1089	188	154	169	197	146	184	184	171	167	183	220	159
	PrecMin	685	18	11	9	16	37	20	11	14	26	27	27	14
	PrecStd	105	43	39	41	54	34	34	36	39	34	37	44	38
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	15.4	19.1	23.8	27.5	30.7	35.7	36.7	37.5	32.4	27.4	20.8	16.7
		MCWB	11.2	10.7	13.2	15.9	19.6	22.0	20.8	21.3	19.6	18.6	15.2	12.0
	2%	DB	13.6	16.0	21.1	24.6	28.1	32.3	33.6	34.3	29.8	24.6	18.3	14.7
		MCWB	11.1	10.3	12.4	15.1	18.3	21.1	21.3	21.0	19.2	17.7	13.8	11.5
	5%	DB	12.3	14.0	18.5	22.2	25.8	30.4	31.6	31.7	27.6	22.6	16.5	13.1
		MCWB	10.2	9.5	11.4	13.7	17.3	20.2	20.8	20.5	18.5	16.8	13.1	10.9
	10%	DB	10.9	12.1	16.2	19.6	23.4	28.1	29.6	29.0	25.4	20.7	14.7	11.7
		MCWB	9.1	9.0	10.3	12.8	16.1	19.3	20.0	20.0	17.8	16.0	12.3	9.9
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.7	12.2	14.5	17.1	20.8	23.9	23.5	23.8	22.1	19.8	15.8	13.1
		MCDB	13.7	16.2	20.6	24.9	28.1	31.3	31.6	32.4	29.1	24.8	19.1	14.9
	2%	WB	11.7	11.1	13.2	15.7	19.2	22.1	22.4	22.3	20.3	18.4	14.7	12.1
		MCDB	13.1	14.3	18.6	23.3	26.3	30.1	30.8	30.2	26.6	22.8	17.3	14.1
	5%	WB	10.5	10.3	12.2	14.4	18.0	21.1	21.5	21.2	19.3	17.5	13.6	11.1
		MCDB	11.9	12.9	16.8	20.7	24.1	28.7	29.8	29.3	25.4	21.3	15.9	13.0
	10%	WB	9.3	9.3	11.2	13.3	16.8	20.0	20.5	20.4	18.3	16.4	12.4	10.0
		MCDB	10.8	12.0	15.2	18.5	22.1	26.3	28.1	27.8	24.0	20.0	14.6	11.5
(35) Mean Daily Temperature Range	5% DB	MDBR	8.0	10.4	12.1	12.4	12.2	13.0	13.2	13.7	13.7	11.6	9.0	8.5
		MCDBR	9.5	14.4	18.0	18.5	17.3	17.7	17.9	19.5	18.0	14.5	11.9	10.4
		MCWBR	6.7	9.2	10.2	9.7	8.6	7.6	6.9	7.6	8.3	8.0	7.8	7.4
	5% WB	MCDBR	7.1	11.0	14.3	15.9	14.9	15.3	15.7	15.7	14.8	11.8	10.0	8.4
		MCWBR	5.4	7.4	8.5	8.6	7.7	6.9	6.7	6.8	7.5	6.8	6.9	6.3
(40) Clear-Sky Solar Irradiance	taub		0.313	0.328	0.362	0.395	0.399	0.411	0.403	0.400	0.369	0.362	0.332	0.311
	taud		2.491	2.439	2.361	2.264	2.304	2.307	2.326	2.345	2.410	2.443	2.477	2.491
	Ebn at Noon		804	855	868	864	870	859	861	850	850	803	769	765
	Edh at Noon		68	86	106	127	127	127	123	116	100	85	69	62
(44) All-Sky Solar Radiation	RadAvg		1.29	2.21	3.36	4.50	5.28	6.12	6.00	5.30	4.21	2.69	1.51	1.18
	RadStd		0.16	0.28	0.41	0.58	0.46	0.54	0.44	0.39	0.28	0.23	0.19	0.18

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (23 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page