

ANNECY MONT BLANC AP, France

WMO: 074900

Lat: 45.9298N

Lon: 6.1047E

Elev: 464

StdP: 95.88

Time Zone: 1.00 (EUC)

Period: 07-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-7.1	-5.2	-11.0	1.5	-4.8	-8.8	1.9	-3.3	7.5	2.5	6.2	2.5	1.9	30	0.472

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.9	31.8	20.5	29.9	20.0	28.1	19.3	21.4	29.5	20.6	28.1	19.8	26.8	3.0	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.7	14.3	25.4	17.9	13.6	24.1	17.1	12.9	23.2	64.2	30.0	61.3	28.3	58.5	26.8	27.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
7.2	5.9	5.0	-9.4	34.5	2.8	1.9	-11.5	35.8	-13.1	37.0	-14.7	38.0	-16.7	39.4		
			-10.1	23.2	2.7	1.3	-12.1	24.2	-13.7	24.9	-15.2	25.6	-17.2	26.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	11.0	2.0	2.8	7.0	11.0	14.0	18.2	20.2	19.7	15.8	11.7	6.3	2.7
	DBStd	7.32	3.27	3.86	3.40	3.31	3.60	3.65	3.62	3.45	3.08	3.46	3.41	3.38
	HDD10.0	956	248	202	104	28	6	0	0	0	1	24	116	227
	HDD18.3	2891	507	435	353	220	142	47	23	26	87	206	360	486
	CDD10.0	1314	0	0	10	58	128	245	315	301	174	76	6	0
	CDD18.3	208	0	0	0	0	7	42	80	68	11	0	0	0
	CDH23.3	2238	0	0	0	13	83	471	877	687	103	3	0	0
	CDH26.7	706	0	0	0	1	12	137	311	230	16	0	0	0
Wind	WSAvg	1.9	1.6	1.9	2.1	2.2	2.2	2.1	2.1	2.0	1.8	1.6	1.5	1.5
Precipitation	PrecAvg	1139	102	79	84	84	107	84	94	109	80	104	109	102
	PrecMax	1451	200	187	225	200	182	164	246	197	192	225	286	234
	PrecMin	884	25	0	14	12	42	33	32	28	18	15	8	0
	PrecStd	181	49	53	51	53	48	43	57	46	48	60	75	65
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.2	15.6	20.2	25.1	28.1	32.7	34.2	33.7	28.8	23.7	17.9	13.2
		MCWB	8.1	8.8	11.2	14.8	19.1	22.7	20.9	20.9	18.5	16.0	12.0	9.2
	2%	DB	10.1	13.0	18.1	22.5	25.8	30.0	32.0	31.2	26.1	21.8	15.1	10.9
		MCWB	7.2	7.8	10.4	13.7	16.9	20.7	20.3	20.3	18.1	15.5	11.1	8.0
	5%	DB	8.1	10.8	16.0	20.7	23.4	28.1	30.0	29.2	24.1	19.6	13.2	9.1
		MCWB	6.4	7.0	9.7	12.7	15.6	19.5	19.7	19.9	17.1	14.9	10.4	7.2
	10%	DB	6.9	8.8	13.8	18.6	21.2	26.1	28.1	27.2	22.2	17.5	11.5	7.7
		MCWB	5.3	6.0	8.6	11.9	14.7	18.3	19.2	19.3	16.5	13.8	9.5	6.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.1	9.6	12.1	15.6	19.1	23.7	22.2	22.2	19.7	17.2	13.2	9.9
		MCDB	11.4	13.5	18.0	23.5	26.9	31.6	31.2	30.2	25.0	21.6	17.0	12.6
	2%	WB	7.7	8.5	11.0	14.2	17.7	21.2	21.3	21.2	18.7	16.2	11.8	8.6
		MCDB	9.3	12.1	16.9	21.2	24.2	28.8	29.5	29.1	24.5	20.1	14.4	10.2
	5%	WB	6.5	7.2	10.0	13.1	16.4	20.1	20.4	20.3	17.9	15.2	10.7	7.4
		MCDB	8.0	10.4	15.3	19.6	22.0	27.0	28.2	27.7	23.3	18.6	12.8	8.9
	10%	WB	5.4	5.9	8.9	12.1	15.2	19.0	19.6	19.6	17.0	14.3	9.6	6.0
		MCDB	6.5	8.5	13.1	17.8	20.1	25.1	26.9	26.3	21.4	17.1	11.4	7.3
Mean Daily Temperature Range	5% DB	MDBR	6.5	8.3	10.1	11.2	11.2	12.3	12.9	12.4	11.0	9.7	7.7	7.1
		MCDBR	8.9	12.9	14.8	15.2	14.4	15.0	16.0	15.7	13.9	13.2	10.7	9.9
		MCWBR	6.3	8.5	8.5	7.9	7.1	7.2	6.4	6.6	6.8	7.7	7.2	7.1
	5% WB	MCDBR	8.1	11.8	13.5	14.2	13.0	14.1	14.1	13.9	12.4	11.4	9.9	8.8
		MCWBR	6.0	8.0	7.9	7.6	6.9	7.3	6.4	6.6	6.4	6.9	6.9	6.5
Clear-Sky Solar Irradiance	taub	0.285	0.308	0.346	0.382	0.392	0.393	0.389	0.380	0.363	0.345	0.313	0.285	
	taud	2.445	2.396	2.358	2.295	2.315	2.350	2.355	2.388	2.422	2.467	2.498	2.468	
	Ebn at Noon	827	870	881	875	875	874	873	867	852	817	786	787	
	Edh at Noon	68	88	105	123	125	121	119	111	98	82	66	61	
All-Sky Solar Radiation	RadAvg	1.41	2.27	3.44	4.44	5.12	6.10	6.06	5.27	4.08	2.60	1.49	1.17	
	RadStd	0.16	0.31	0.45	0.58	0.46	0.51	0.49	0.40	0.32	0.27	0.20	0.17	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (59 neighbors)	N/A	N/A	N/A	N/A	+0.33	+0.23	N/A	N/A	N/A	N/A

Nomenclature: See separate page