

CHAMBERY SAVOIE MONT BLANC AP, France

WMO: 074910

Lat: 45.6414N

Lon: 5.8781E

Elev: 779

StdP: 14.29

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	21.7	24.4	14.9	12.0	27.0	18.3	14.2	28.8	23.1	41.8	20.7	41.7	4.4	150	0.468

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	23.0	89.5	70.3	86.2	69.5	83.3	68.2	72.0	85.6	70.5	83.4	69.0	81.1	5.6	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
67.3	103.4	79.1	65.9	98.3	76.8	64.6	93.7	75.0	36.1	86.0	34.8	84.0	33.6	81.2	80.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
19.0	16.4	14.2	DB	17.1	94.2	4.2	3.9	14.1	97.0	11.6	99.3	9.3	101.6	6.3	104.4	
			WB	16.4	75.3	4.2	1.9	13.3	76.7	10.9	77.8	8.5	78.9	5.4	80.3	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	53.3	37.0	39.3	46.2	52.5	59.8	66.6	70.0	68.8	61.7	54.3	44.2	38.0
	DBStd	13.04	5.76	6.03	5.73	5.72	5.80	6.20	5.67	5.36	5.28	5.52	5.99	5.88
	HDD50	1474	404	302	142	38	4	0	0	0	0	24	188	372
	HDD65	4741	868	721	581	374	179	54	21	24	124	334	625	836
	CDD50	2675	1	2	25	114	307	499	620	584	352	156	14	1
	CDD65	465	0	0	0	0	17	103	175	143	26	1	0	0
	CDH74	4583	0	0	0	28	208	1043	1759	1315	224	6	0	0
	CDH80	1466	0	0	0	1	30	314	632	453	36	0	0	0
Wind	WSAvg	5.2	5.5	6.0	5.9	5.5	5.1	5.2	4.9	4.4	4.7	4.5	5.1	5.5
Precipitation	PrecAvg	48.3	3.9	3.3	3.3	3.8	4.3	3.9	3.9	3.8	4.3	4.7	4.8	4.2
	PrecMax	60.9	10.0	10.8	11.6	7.6	8.1	7.6	10.8	9.1	11.9	9.6	11.5	10.1
	PrecMin	36.1	0.6	0.0	0.5	0.4	1.1	0.6	1.2	0.8	0.9	0.9	0.8	0.0
	PrecStd	7.0	2.3	2.7	2.3	2.0	1.9	1.8	2.1	1.7	2.9	2.2	2.8	2.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.8	61.2	69.1	77.7	83.4	91.4	94.2	94.1	84.3	74.3	64.6	57.9
		MCWB	49.0	49.2	54.1	60.1	66.3	72.0	70.5	71.3	68.3	62.9	53.9	50.4
	2%	DB	50.9	55.5	64.6	72.7	79.4	86.8	89.8	88.6	79.9	69.9	59.4	52.0
		MCWB	46.0	47.1	52.4	57.7	64.1	69.9	70.1	69.9	66.4	61.0	53.1	47.7
	5%	DB	48.0	52.1	61.0	68.8	75.8	83.6	86.5	85.0	76.4	66.8	55.8	49.2
		MCWB	44.4	45.3	50.3	55.7	62.4	68.3	69.4	69.4	65.0	59.4	51.2	45.9
	10%	DB	45.7	49.0	57.3	65.0	72.3	80.3	83.3	81.4	72.9	63.8	53.2	46.7
		MCWB	42.5	43.6	48.7	53.9	60.5	66.6	68.2	68.1	63.0	57.8	49.5	43.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	50.0	50.6	55.4	61.1	67.9	74.4	73.9	73.7	69.9	64.3	56.1	51.0
		MCDB	54.0	57.8	66.0	74.7	81.3	87.8	88.7	87.5	80.1	71.6	60.5	56.5
	2%	WB	46.8	48.0	53.1	58.7	65.4	71.2	71.8	71.7	67.5	62.2	53.7	48.4
		MCDB	49.9	53.8	62.0	70.7	77.1	84.0	85.9	85.2	77.7	68.1	58.1	51.3
	5%	WB	44.8	46.1	51.4	56.7	63.3	69.3	70.3	70.1	65.7	60.4	51.8	46.3
		MCDB	47.6	51.3	58.8	66.9	73.7	81.3	83.8	82.6	74.5	65.5	55.5	48.7
	10%	WB	42.7	44.1	49.6	54.8	61.4	67.5	68.8	68.5	63.9	58.5	49.9	44.1
		MCDB	45.2	48.4	56.2	63.6	70.2	78.4	81.4	79.7	71.3	62.8	52.9	46.4
Mean Daily Temperature Range	5% DB	MDBR	11.9	15.1	18.9	20.3	20.2	21.9	23.0	22.2	19.9	17.2	13.5	12.0
		MCDBR	15.3	21.9	26.6	28.6	26.9	27.3	28.6	28.9	26.0	21.6	17.8	15.1
	5% WB	MCWBR	10.6	14.1	15.1	15.0	13.4	12.7	12.0	12.9	13.5	13.0	12.0	10.8
		MCWBR	13.7	19.6	23.6	26.4	24.7	25.7	26.5	26.2	23.7	20.1	16.0	13.2
Clear-Sky Solar Irradiance	taub		0.298	0.322	0.362	0.402	0.412	0.412	0.406	0.398	0.381	0.362	0.327	0.298
	taud		2.435	2.372	2.315	2.240	2.265	2.308	2.321	2.354	2.386	2.433	2.471	2.459
	Ebn at Noon		258	271	274	272	272	272	270	265	253	244	245	
	Edh at Noon		22	29	35	41	42	40	39	36	32	27	22	20
All-Sky Solar Radiation	RadAvg		442	712	1099	1422	1648	1966	1957	1696	1302	826	472	370
	RadStd		51	95	136	179	149	154	158	121	101	88	61	56

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
Station Only	N/A	N/A	N/A	N/A	+1.06	+1.04	N/A	N/A	N/A	N/A
Regional (53 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page