

CHAMBERY SAVOIE MONT BLANC AP, France

WMO: 074910

Lat: 45.6414N

Lon: 5.8781E

Elev: 237

StdP: 98.51

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-5.7	-4.2	-9.5	1.7	-2.8	-7.6	2.0	-1.8	10.3	5.5	9.3	5.4	2.0	150	0.468

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.8	31.9	21.3	30.1	20.8	28.5	20.1	22.2	29.8	21.4	28.6	20.6	27.3	2.5	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.6	14.8	26.2	18.8	14.0	24.9	18.1	13.4	23.9	66.2	30.0	63.1	28.9	60.2	27.3	26.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
8.5	7.3	6.3	-8.3	34.6	2.3	2.2	-9.9	36.1	-11.3	37.4	-12.6	38.6	-14.3	40.2		
			-8.7	24.0	2.3	1.1	-10.4	24.8	-11.7	25.4	-13.1	26.0	-14.8	26.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	11.8	2.8	4.0	7.9	11.4	15.4	19.2	21.1	20.5	16.5	12.4	6.8	3.4
	DBStd	7.24	3.20	3.35	3.18	3.18	3.22	3.45	3.15	2.98	2.93	3.07	3.33	3.27
	HDD10.0	819	224	168	79	21	2	0	0	0	0	13	104	207
	HDD18.3	2634	482	401	323	208	99	30	12	13	69	186	347	464
	CDD10.0	1486	1	1	14	63	171	277	344	324	196	87	8	1
	CDD18.3	258	0	0	0	0	9	57	97	79	14	1	0	0
	CDH23.3	2546	0	0	0	16	116	579	977	731	124	3	0	0
	CDH26.7	814	0	0	0	1	17	174	351	252	20	0	0	0
Wind	WSAvg	2.3	2.4	2.7	2.7	2.4	2.3	2.3	2.2	2.0	2.1	2.0	2.3	2.5
Precipitation	PrecAvg	1227	98	85	84	96	108	99	100	97	110	120	123	106
	PrecMax	1546	255	274	295	194	207	192	274	230	301	244	293	257
	PrecMin	917	14	0	13	9	28	14	31	20	20	22	20	0
	PrecStd	178	58	68	59	51	47	45	54	44	73	55	71	60
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.2	16.2	20.6	25.4	28.6	33.0	34.5	34.5	29.1	23.5	18.1	14.4
		MCWB	9.4	9.5	12.3	15.6	19.1	22.2	21.4	21.8	20.2	17.2	12.2	10.2
	2%	DB	10.5	13.0	18.1	22.6	26.3	30.4	32.1	31.5	26.6	21.1	15.2	11.1
		MCWB	7.8	8.4	11.3	14.3	17.8	21.1	21.2	21.1	19.1	16.1	11.7	8.7
	5%	DB	8.9	11.2	16.1	20.4	24.3	28.7	30.3	29.4	24.6	19.3	13.2	9.6
		MCWB	6.9	7.4	10.2	13.2	16.9	20.2	20.8	20.8	18.3	15.2	10.7	7.7
	10%	DB	7.6	9.5	14.0	18.3	22.4	26.9	28.5	27.5	22.7	17.7	11.8	8.2
		MCWB	5.8	6.4	9.3	12.2	15.9	19.2	20.1	20.1	17.2	14.3	9.7	6.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.0	10.3	13.0	16.1	19.9	23.5	23.3	23.2	21.0	17.9	13.4	10.6
		MCDB	12.2	14.4	18.9	23.7	27.4	31.0	31.5	30.9	26.7	22.0	15.9	13.6
	2%	WB	8.2	8.9	11.7	14.9	18.6	21.8	22.1	22.1	19.7	16.8	12.1	9.1
		MCDB	10.0	12.1	16.7	21.5	25.1	28.9	29.9	29.5	25.4	20.1	14.5	10.7
	5%	WB	7.1	7.8	10.8	13.7	17.4	20.7	21.3	21.2	18.7	15.8	11.0	8.0
		MCDB	8.7	10.7	14.9	19.4	23.2	27.4	28.8	28.1	23.6	18.6	13.0	9.3
	10%	WB	6.0	6.7	9.8	12.7	16.3	19.7	20.4	20.3	17.7	14.7	10.0	6.7
		MCDB	7.3	9.1	13.4	17.6	21.2	25.8	27.4	26.5	21.8	17.1	11.6	8.0
Mean Daily Temperature Range	5% DB	MDBR	6.6	8.4	10.5	11.3	11.2	12.2	12.8	12.3	11.1	9.5	7.5	6.7
		MCDBR	8.5	12.2	14.8	15.9	15.0	15.2	15.9	16.1	14.5	12.0	9.9	8.4
		MCWBR	5.9	7.8	8.4	8.3	7.4	7.0	6.7	7.1	7.5	7.2	6.6	6.0
	5% WB	MCDBR	7.6	10.9	13.1	14.7	13.7	14.3	14.7	14.6	13.2	11.1	8.9	7.3
MCWBR		5.5	7.3	7.6	7.8	7.0	7.0	6.8	6.9	7.2	6.9	6.2	5.5	
Clear-Sky Solar Irradiance	taub	0.298	0.322	0.362	0.402	0.412	0.412	0.406	0.398	0.381	0.362	0.327	0.298	
	taud	2.435	2.372	2.315	2.240	2.265	2.308	2.321	2.354	2.386	2.433	2.471	2.459	
	Ebn at Noon	812	854	863	856	857	857	857	851	834	798	769	771	
	Edh at Noon	70	90	111	130	131	126	123	115	102	85	68	62	
All-Sky Solar Radiation	RadAvg	1.39	2.25	3.46	4.48	5.20	6.20	6.17	5.35	4.11	2.60	1.49	1.17	
	RadStd	0.16	0.30	0.43	0.56	0.47	0.49	0.50	0.38	0.32	0.28	0.19	0.18	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (53 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page