

CAZAUX AB, France

WMO: 075020

Lat: 44.5347N

Lon: 1.1319W

Elev: 84

StdP: 14.65

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	25.8	28.4	19.5	14.7	31.4	23.1	17.5	33.2	25.1	50.4	22.4	51.0	3.8	0	0.477

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.3	90.6	70.0	86.4	68.5	82.9	67.1	72.7	84.5	70.9	81.8	69.3	78.7	8.7	60

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
69.3	107.9	76.5	67.6	101.7	74.6	66.1	96.6	73.3	36.3	84.4	34.7	82.0	33.4	78.7	79.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.5	17.8	15.5	DB	20.7	97.6	2.9	3.5	18.6	100.1	16.9	102.2	15.3	104.2	13.2	106.7	(4)
(5)			WB	20.0	75.4	2.8	1.7	18.0	76.7	16.4	77.7	14.8	78.7	12.8	79.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	56.3	44.5	45.4	49.9	53.8	59.8	65.5	69.0	69.0	64.1	58.7	50.1	45.6		
	DBStd	10.66	6.71	6.22	5.39	5.37	5.67	5.82	5.32	5.34	5.39	6.26	6.24	6.92		
	HDD50	681	190	148	69	21	2	0	0	0	0	10	75	166		
	HDD65	3605	637	549	467	338	181	62	19	19	79	207	447	600		
	CDD50	2998	18	19	66	135	305	465	590	588	423	280	78	31		
	CDD65	448	0	0	0	2	19	77	144	142	52	12	0	0		
	CDH74	4237	0	1	5	67	265	798	1269	1196	546	89	1	0		
	CDH80	1475	0	0	0	13	66	305	475	441	165	10	0	0		
(14) Wind	WSAvg	6.9	7.0	7.2	7.8	7.7	7.4	7.2	7.0	6.4	6.1	6.0	6.7	6.6		
(15) Precipitation	PrecAvg	33.9	3.5	2.7	2.2	2.7	2.3	2.4	1.7	2.2	2.9	3.2	4.7	3.5		
	PrecMax	42.4	8.1	5.6	5.6	7.1	5.0	7.2	3.4	6.9	6.4	5.8	10.5	7.4		
	PrecMin	23.7	0.4	0.3	0.5	0.6	0.6	0.3	0.2	0.4	0.2	0.6	1.5	0.4		
	PrecStd	4.8	2.2	1.5	1.4	1.7	1.2	1.5	0.7	1.5	1.6	1.6	2.4	1.8		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	61.0	67.6	73.8	81.6	86.6	94.6	95.9	95.9	89.8	81.2	69.7	62.5		
		MCWB	54.6	54.4	56.1	61.1	66.2	71.5	71.0	70.7	68.4	65.4	59.8	55.1		
	2%	DB	58.1	62.0	68.8	74.2	81.0	87.6	89.7	89.7	84.6	76.2	64.9	59.4		
		MCWB	53.6	52.4	54.9	57.8	64.1	68.0	70.3	70.4	67.0	64.5	58.4	54.3		
	5%	DB	56.1	58.0	64.7	69.5	76.2	82.8	85.4	84.5	80.5	72.6	62.0	57.5		
		MCWB	52.7	51.5	53.5	56.7	62.3	66.7	68.8	69.1	65.4	63.2	57.4	53.9		
	10%	DB	54.4	55.2	60.5	64.8	71.8	77.8	80.9	80.3	76.1	69.0	59.7	55.8		
		MCWB	51.6	50.9	51.9	54.7	60.7	65.2	67.5	67.6	64.5	62.0	56.0	52.9		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	56.5	56.3	58.5	62.6	69.0	72.9	74.4	75.4	71.9	68.2	62.5	57.3		
		MCDB	58.7	63.1	68.5	74.8	82.3	88.7	87.4	86.4	83.6	75.1	66.3	58.8		
	2%	WB	54.9	54.3	56.6	59.8	65.8	70.4	72.1	73.1	69.3	66.2	59.8	55.9		
		MCDB	57.0	58.5	65.5	70.7	76.6	83.2	84.8	83.4	78.6	73.5	63.3	57.9		
	5%	WB	53.5	53.0	54.9	57.9	63.8	68.3	70.5	71.1	67.5	64.6	58.1	54.7		
		MCDB	55.6	56.5	61.3	66.8	72.8	78.7	81.4	80.2	76.2	70.1	61.3	57.0		
	10%	WB	51.9	51.6	53.4	56.1	61.8	66.5	68.9	69.2	65.7	62.9	56.4	53.2		
		MCDB	54.1	55.0	58.5	62.9	69.8	75.3	78.2	77.5	73.7	68.0	59.5	55.7		
(35) Mean Daily Temperature Range	5% DB	MDBR	14.0	17.0	18.5	18.6	18.3	19.2	19.3	20.2	21.2	18.7	15.3	14.2		
		MCDBR	15.7	23.1	27.9	28.3	28.3	30.0	28.4	28.5	29.5	23.5	18.0	15.7		
	5% WB	MCWBR	11.6	14.7	15.6	14.2	13.6	12.8	11.6	11.9	13.7	13.0	12.1	11.4		
		MCWBR	13.3	18.4	21.6	23.4	23.7	24.7	23.6	22.9	23.7	19.3	15.9	13.1		
(40) Clear-Sky Solar Irradiance	taub	taub	0.330	0.343	0.373	0.392	0.398	0.411	0.402	0.399	0.375	0.369	0.344	0.327		
		taud	2.499	2.450	2.377	2.336	2.370	2.365	2.388	2.407	2.455	2.471	2.480	2.492		
	Ebn at Noon	Ebn at Noon	251	267	272	276	277	273	274	271	269	254	241	239		
		Edh at Noon	22	28	34	38	38	38	37	35	31	27	23	20		
(44) All-Sky Solar Radiation	RadAvg	RadAvg	426	734	1129	1522	1800	1998	1960	1739	1387	876	511	391		
	RadStd	RadStd	40	84	138	148	138	133	125	95	84	71	64	49		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (20 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page