

BORDEAUX MERIGNAC, FranceWMO: **075100**Lat: **44.8308N**Lon: **0.6914W**Elev: **49**StdP: **100.73**Time Zone: **1.00 (EUC)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -3.2	(c) -1.7	(d) -6.9	(e) 2.1	(f) 0.1	(g) -5.1	(h) 2.5	(i) 1.0	(j) 12.3	(k) 12.3	(l) 10.7	(m) 11.8	(n) 2.2	(o) 20	(p) 0.482

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 10.9	(c) 33.1	(d) 21.4	(e) 31.0	(f) 20.4	(g) 29.1	(h) 19.7	(i) 22.6	(j) 30.3	(k) 21.7	(l) 28.6	(m) 20.8	(n) 26.8	(o) 3.6	(p) 110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) 20.2	(b) 15.0	(c) 25.1	(d) 19.4	(e) 14.2	(f) 24.1	(g) 18.7	(h) 13.6	(i) 23.4	(j) 66.6	(k) 30.4	(l) 63.2	(m) 29.0	(n) 60.0	(o) 26.8	(p) 27.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9.7	8.3	7.2	-5.5	36.5	1.9	1.6	-6.9	37.7	-8.0	38.6	-9.1	39.5	-10.5	40.6
			-6.0	24.4	2.0	0.9	-7.5	25.0	-8.6	25.6	-9.7	26.1	-11.1	26.8
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	14.0	6.9	7.5	10.4	12.7	16.2	19.6	21.3	21.5	18.4	15.2	10.0	7.4	(6)
(7)		DBStd	6.30	3.78	3.66	3.26	3.20	3.48	3.55	3.22	3.17	3.08	3.47	3.49	4.00	(7)
(8)		HDD10.0	376	106	82	34	9	1	0	0	0	0	4	42	97	(8)
(9)		HDD18.3	1931	353	302	244	172	86	27	9	6	36	107	251	339	(9)
(10)		CDD10.0	1827	11	13	48	90	192	287	351	358	253	165	42	17	(10)
(11)		CDD18.3	339	0	0	0	2	19	63	102	106	39	9	0	0	(11)
(12)		CDH23.3	3051	0	0	3	36	196	608	927	903	329	48	1	0	(12)
(13)		CDH26.7	1081	0	0	0	4	47	222	353	359	90	6	0	0	(13)
(14)	Wind	WSAvg	3.4	3.6	3.7	3.8	3.8	3.5	3.3	3.2	3.0	2.9	3.1	3.3	3.4	(14)
(15)	Precipitation	PrecAvg	920	93	77	68	71	74	61	49	57	80	86	103	97	(15)
(16)		PrecMax	1223	234	155	190	204	158	167	113	248	249	222	322	306	(16)
(17)		PrecMin	588	10	3	0	3	8	3	5	4	3	6	10	2	(17)
(18)		PrecStd	176	56	39	40	45	37	38	26	46	57	56	66	62	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	16.1	19.0	23.5	27.1	30.9	35.0	35.2	36.2	31.9	27.3	20.6	16.7	(19)
(20)			MCWB	12.3	12.3	13.9	16.6	19.1	22.5	21.7	22.3	19.9	18.4	15.7	12.6	(20)
(21)		2%	DB	14.4	16.2	20.8	23.8	27.8	31.5	32.6	33.2	29.2	24.6	18.0	14.9	(21)
(22)			MCWB	11.8	11.2	12.9	14.4	17.8	20.5	21.2	21.8	19.2	18.2	14.7	12.4	(22)
(23)		5%	DB	13.3	14.3	18.4	21.6	25.4	29.1	30.5	30.6	27.1	22.4	16.4	13.8	(23)
(24)			MCWB	11.3	10.6	12.0	13.8	17.1	19.8	20.4	20.6	18.6	17.1	13.8	12.0	(24)
(25)		10%	DB	12.2	12.8	16.3	19.1	23.1	26.9	28.3	28.1	25.0	20.6	15.1	12.9	(25)
(26)			MCWB	10.6	10.3	11.1	12.8	16.1	18.8	19.6	19.8	17.9	16.4	13.1	11.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	13.5	13.2	14.9	17.3	20.5	23.3	23.5	24.3	21.9	20.0	16.7	14.0	(27)
(28)			MCDWB	14.7	16.3	21.1	24.7	28.0	31.5	32.1	32.1	28.5	23.9	18.9	15.0	(28)
(29)		2%	WB	12.6	12.2	13.7	15.8	19.0	21.8	22.3	22.7	20.6	18.8	15.2	13.1	(29)
(30)			MCDWB	13.9	14.7	18.7	21.8	26.1	29.6	30.2	30.1	26.3	22.8	17.0	14.2	(30)
(31)		5%	WB	11.7	11.5	12.8	14.5	17.8	20.7	21.3	21.7	19.6	17.9	14.3	12.3	(31)
(32)			MCDWB	12.9	13.6	16.8	19.8	23.5	27.1	28.2	28.3	24.7	21.1	16.0	13.5	(32)
(33)		10%	WB	10.7	10.6	11.9	13.3	16.7	19.5	20.4	20.7	18.6	17.0	13.3	11.4	(33)
(34)			MCDWB	12.1	12.6	15.1	17.8	21.8	25.2	26.5	26.2	23.4	20.1	15.0	12.8	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	6.7	8.2	9.6	10.0	10.2	10.8	10.9	11.2	10.9	9.2	7.5	6.7	(35)
(36)			MCDBR	7.3	10.5	13.6	14.1	13.9	15.0	14.7	15.0	14.2	11.3	8.5	7.0	(36)
(37)			MCWBR	5.2	6.3	6.9	6.5	6.0	6.0	5.5	5.4	5.8	5.7	5.4	4.9	(37)
(38)		5% WB	MCDWB	6.3	8.9	11.0	12.1	12.4	12.9	13.0	12.8	11.9	9.7	7.5	6.4	(38)
(39)			MCWBR	4.9	6.0	6.1	6.0	5.9	5.8	5.5	5.2	5.5	5.3	5.1	5.0	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.328	0.341	0.373	0.394	0.400	0.413	0.403	0.400	0.373	0.368	0.343	0.325	(40)	
(41)		taud	2.481	2.429	2.345	2.292	2.329	2.325	2.348	2.371	2.428	2.448	2.463	2.477	(41)	
(42)		Ebn at Noon	787	842	857	866	871	858	862	852	848	799	757	749	(42)	
(43)		Edh at Noon	70	88	109	124	124	125	120	114	99	85	71	64	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.32	2.29	3.48	4.69	5.49	6.16	6.04	5.38	4.31	2.71	1.59	1.21	(44)	
(45)		RadStd	0.13	0.26	0.42	0.47	0.42	0.43	0.38	0.34	0.27	0.22	0.19	0.15	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (22 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page