

AGEN LA GARENNE AP, France

WMO: 075240

Lat: 44.1722N

Lon: 0.5947E

Elev: 204

StdP: 14.59

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	24.1	27.1	19.4	14.7	27.7	22.9	17.3	30.9	21.0	48.4	18.5	48.9	3.1	290	0.450

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.6	92.0	71.1	88.5	69.7	85.4	68.6	73.4	87.4	71.8	85.0	70.2	82.2	6.8	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
68.9	106.9	79.5	67.4	101.5	77.6	66.0	96.7	75.8	37.0	87.7	35.5	85.2	34.2	82.5	80.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
18.1	15.5	13.5	19.6	97.9	4.3	3.8	16.5	100.6	14.0	102.9	11.6	105.0	8.5	107.8		
			19.0	76.3	4.3	1.4	15.9	77.3	13.4	78.1	10.9	78.9	7.8	79.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
Temperatures, Degree-Days and Degree-Hours	DBAvg	56.6	42.7	44.1	49.9	54.3	60.6	67.8	71.1	71.0	65.0	59.1	48.8	43.4		
	DBStd	11.97	6.76	6.65	5.75	5.35	5.74	6.12	5.27	5.46	5.71	6.73	6.66	7.19		
	HDD50	838	237	178	72	19	2	0	0	0	0	12	99	219		
	HDD65	3710	690	584	468	322	159	41	9	10	70	202	487	668		
	CDD50	3233	12	14	70	148	331	533	654	650	450	293	62	16		
	CDD65	629	0	0	0	1	24	123	198	195	70	18	0	0		
	CDH74	6283	0	0	3	46	326	1265	1973	1859	694	117	0	0		
	CDH80	2306	0	0	0	4	71	463	786	758	208	16	0	0		
	WSAvg	5.9	6.2	6.6	6.8	6.5	6.0	5.7	5.7	5.3	5.1	5.4	5.7	5.8		
	PrecAvg	28.3	2.5	1.9	1.9	2.9	2.8	2.4	2.0	2.0	2.4	2.4	2.9	2.2		
Precipitation	PrecMax	36.5	5.8	4.2	4.3	6.3	5.3	8.9	4.3	4.7	5.2	5.9	7.2	5.2		
	PrecMin	20.5	0.2	0.0	0.3	0.5	0.9	0.5	0.4	0.5	0.6	0.4	0.5	0.3		
	PrecStd	3.8	1.6	1.2	1.1	1.6	1.2	1.6	1.1	1.1	1.3	1.4	1.5	1.3		
	PrecStd	3.8	1.6	1.2	1.1	1.6	1.2	1.6	1.1	1.1	1.3	1.4	1.5	1.3		
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	60.8	65.0	73.2	79.4	85.9	95.2	96.3	98.0	90.1	82.1	69.2	61.1		
		MCWB	54.7	54.2	56.7	62.3	66.9	72.9	71.6	71.9	68.5	66.4	60.3	55.6		
	2%	DB	57.4	60.5	68.0	74.3	81.6	88.8	91.4	92.1	85.6	77.1	64.6	58.0		
		MCWB	53.5	52.4	55.5	59.4	65.4	69.9	71.1	71.6	66.8	65.3	58.3	53.8		
	5%	DB	54.9	57.3	64.5	70.3	77.6	85.2	88.0	87.8	81.8	73.3	61.1	55.7		
		MCWB	51.5	50.9	54.1	57.5	63.8	68.8	69.7	70.0	65.8	63.3	56.7	52.4		
	10%	DB	52.6	54.4	61.1	66.3	73.5	81.5	84.5	84.0	77.7	69.9	58.2	53.5		
		MCWB	49.9	49.9	52.2	55.4	61.7	67.1	68.6	68.5	64.3	62.0	54.9	51.0		
	0.4%	WB	56.4	55.7	59.3	63.7	69.4	74.8	74.8	75.8	71.8	68.7	61.8	56.6		
		MCDB	59.1	61.5	68.3	76.5	81.0	89.0	90.5	89.9	84.9	78.0	67.6	59.5		
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	54.0	53.5	56.7	61.0	67.0	72.2	72.9	73.5	69.3	66.4	59.2	54.7		
		MCDB	56.7	58.4	65.2	72.1	79.1	86.0	87.3	87.0	81.0	74.0	63.1	57.2		
	5%	WB	52.0	52.0	55.1	58.6	64.8	70.0	71.4	71.7	67.4	64.6	57.2	52.9		
		MCDB	54.2	56.2	62.6	67.5	74.9	82.5	84.7	84.4	77.6	71.2	60.5	55.3		
	10%	WB	50.0	50.3	53.3	56.6	62.6	68.1	69.8	70.0	65.6	62.9	55.2	51.1		
		MCDB	52.4	54.0	59.7	64.5	71.5	79.1	81.9	81.2	74.6	68.7	58.0	53.3		
Mean Daily Temperature Range	5% DB	MDBR	12.7	16.5	19.5	20.0	20.4	21.0	21.6	22.1	22.3	18.9	14.2	12.4		
		MCDBR	14.8	21.3	26.3	27.9	28.3	28.0	28.9	29.4	28.4	22.7	17.3	14.8		
		MCWBR	10.9	14.0	15.2	14.8	14.0	12.0	11.5	11.5	11.9	11.9	11.6	10.9		
	5% WB	MCDBR	13.2	18.6	22.2	24.6	25.2	25.0	24.8	25.0	23.6	19.2	16.0	13.5		
		MCWBR	10.2	12.9	13.4	13.4	13.4	11.6	10.8	10.5	10.8	10.6	11.2	10.5		
Clear-Sky Solar Irradiance	taub	0.323	0.337	0.372	0.402	0.408	0.421	0.412	0.410	0.380	0.366	0.340	0.321			
	taud	2.480	2.416	2.321	2.239	2.279	2.277	2.301	2.319	2.388	2.440	2.463	2.480			
	Ebn at Noon	254	270	273	273	274	270	271	267	267	256	244	242			
	Edh at Noon	23	28	36	42	41	42	40	38	33	28	23	21			
All-Sky Solar Radiation	RadAvg	439	742	1120	1464	1690	1928	1911	1700	1372	891	523	405			
	RadStd	44	82	120	161	130	150	140	108	79	72	59	54			

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	+1.60	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (25 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page