

AGEN LA GARENNE AP, France

WMO: 075240

Lat: 44.1722N

Lon: 0.5947E

Elev: 62

StdP: 100.58

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-4.4	-2.7	-7.0	2.1	-2.4	-5.1	2.5	-0.6	9.4	9.1	8.3	9.4	1.4	290	0.450

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.0	33.3	21.7	31.4	21.0	29.7	20.3	23.0	30.8	22.1	29.5	21.2	27.9	3.0	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.5	15.3	26.4	19.7	14.5	25.3	18.9	13.8	24.3	68.1	31.0	64.8	29.6	61.7	28.0	26.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
8.1	6.9	6.0	-6.9	36.6	2.4	2.1	-8.6	38.1	-10.0	39.4	-11.3	40.6	-13.0	42.1		
			-7.2	24.6	2.4	0.8	-9.0	25.2	-10.4	25.6	-11.7	26.1	-13.4	26.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	13.6	6.0	6.7	10.0	12.4	15.9	19.9	21.7	21.7	18.3	15.0	9.3	6.4
	DBStd	6.65	3.75	3.69	3.19	2.97	3.19	3.40	2.93	3.03	3.17	3.74	3.70	3.99
	HDD10.0	466	132	99	40	11	1	0	0	0	0	7	55	122
	HDD18.3	2061	383	324	260	179	88	23	5	6	39	112	271	371
	CDD10.0	1796	7	8	39	82	184	296	363	361	250	163	34	9
	CDD18.3	349	0	0	0	1	13	68	110	108	39	10	0	0
	CDH23.3	3491	0	0	2	26	181	703	1096	1033	386	65	0	0
	CDH26.7	1281	0	0	0	2	39	257	437	421	116	9	0	0
Wind	WSAvg	2.6	2.8	2.9	3.0	2.9	2.7	2.5	2.5	2.4	2.3	2.4	2.5	2.6
Precipitation	PrecAvg	719	64	47	47	73	72	62	50	62	62	74	57	
	PrecMax	926	148	107	110	159	135	227	109	120	131	150	183	133
	PrecMin	520	4	0	8	12	23	13	10	12	14	11	13	8
	PrecStd	96	40	31	27	40	30	41	27	28	34	36	39	32
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	16.0	18.4	22.9	26.3	30.0	35.1	35.7	36.7	32.3	27.8	20.7	16.2
		MCWB	12.6	12.3	13.7	16.8	19.4	22.7	22.0	22.1	20.3	19.1	15.7	13.1
	2%	DB	14.1	15.8	20.0	23.5	27.5	31.6	33.0	33.4	29.8	25.1	18.1	14.4
		MCWB	11.9	11.3	13.1	15.2	18.6	21.1	21.7	22.0	19.3	18.5	14.6	12.1
	5%	DB	12.7	14.1	18.1	21.3	25.4	29.6	31.1	31.0	27.7	23.0	16.2	13.2
		MCWB	10.8	10.5	12.3	14.1	17.6	20.4	20.9	21.1	18.8	17.4	13.7	11.3
	10%	DB	11.4	12.4	16.1	19.0	23.0	27.5	29.1	28.9	25.4	21.1	14.6	11.9
		MCWB	9.9	10.0	11.2	13.0	16.5	19.5	20.3	20.3	18.0	16.7	12.7	10.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	13.5	13.2	15.2	17.6	20.8	23.8	23.8	24.3	22.1	20.4	16.5	13.7
		MCDB	15.0	16.4	20.1	24.7	27.2	31.7	32.5	32.2	29.4	25.5	19.8	15.3
	2%	WB	12.2	12.0	13.7	16.1	19.5	22.3	22.7	23.0	20.7	19.1	15.1	12.6
		MCDB	13.7	14.7	18.5	22.3	26.2	30.0	30.7	30.5	27.2	23.3	17.3	14.0
	5%	WB	11.1	11.1	12.9	14.8	18.2	21.1	21.9	22.1	19.7	18.1	14.0	11.6
		MCDB	12.4	13.5	17.0	19.7	23.8	28.0	29.3	29.1	25.3	21.8	15.9	13.0
	10%	WB	10.0	10.1	11.9	13.7	17.0	20.0	21.0	21.1	18.7	17.1	12.9	10.6
		MCDB	11.3	12.2	15.4	18.0	22.0	26.2	27.7	27.3	23.6	20.4	14.4	11.9
Mean Daily Temperature Range	5% DB	MDBR	7.1	9.2	10.8	11.1	11.3	11.7	12.0	12.3	12.4	10.5	7.9	6.9
		MCDBR	8.2	11.8	14.6	15.5	15.7	15.6	16.0	16.3	15.8	12.6	9.6	8.2
		MCWBR	6.0	7.8	8.4	8.2	7.8	6.7	6.4	6.4	6.6	6.6	6.5	6.1
	5% WB	MCDBR	7.3	10.4	12.3	13.7	14.0	13.9	13.8	13.9	13.1	10.7	8.9	7.5
		MCWBR	5.7	7.2	7.4	7.5	7.4	6.4	6.0	5.8	6.0	5.9	6.2	5.8
Clear-Sky Solar Irradiance	taub	0.323	0.337	0.372	0.402	0.408	0.421	0.412	0.410	0.380	0.366	0.340	0.321	
	taud	2.480	2.416	2.321	2.239	2.279	2.277	2.301	2.319	2.388	2.440	2.463	2.480	
	Ebn at Noon	800	850	860	860	864	851	854	843	843	806	768	764	
	Edh at Noon	71	89	112	131	130	131	127	120	104	87	72	65	
All-Sky Solar Radiation	RadAvg	1.38	2.34	3.53	4.62	5.33	6.08	6.03	5.36	4.33	2.81	1.65	1.28	
	RadStd	0.14	0.26	0.38	0.51	0.41	0.47	0.44	0.34	0.25	0.23	0.19	0.17	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	+0.89	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (25 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page