

GOURDON, France

WMO: 075350

Lat: 44.7450N

Lon: 1.3967E

Elev: 856

StdP: 14.25

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 22.1	(c) 25.4	(d) 15.7	(e) 12.5	(f) 28.8	(g) 19.3	(h) 14.9	(i) 31.6	(j) 20.5	(k) 48.0	(l) 17.2	(m) 45.8	(n) 3.1	(o) 130	(p) 0.447

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 22.6	(c) 91.9	(d) 69.6	(e) 88.0	(f) 68.3	(g) 84.6	(h) 67.2	(i) 72.0	(j) 86.2	(k) 70.4	(l) 83.9	(m) 68.8	(n) 81.4	(o) 5.9	(p) 170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
67.7	104.9	77.4	65.9	98.7	75.5	64.4	93.6	73.9	36.1	86.2	34.8	84.3	33.4	81.5	82.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 17.6	(b) 13.9	(c) 11.7	(e) 16.8	(f) 99.0	(g) 3.9	(h) 3.6	(i) 14.0	(j) 101.5	(k) 11.7	(l) 103.6	(m) 9.6	(n) 105.6	(o) 6.8	(p) 108.2		
			DB	WB	DB	WB	DB	WB	DB	WB	DB	WB	DB	WB		
			16.2	75.3	3.9	2.0	13.3	76.7	11.0	77.8	8.8	78.9	6.0	80.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	55.2	41.5	42.8	48.7	53.3	59.6	66.2	69.8	69.2	63.2	57.4	47.5	42.6
	DBStd	12.17	7.02	7.37	6.54	6.43	6.44	6.75	6.01	6.19	6.30	7.17	7.19	7.70
	HDD50	1026	272	213	103	36	5	0	0	0	0	21	130	246
	HDD65	4086	729	620	505	354	192	65	21	24	108	247	526	695
	CDD50	2936	8	13	63	135	302	487	614	596	397	252	54	15
	CDD65	521	0	0	0	3	25	102	170	155	54	12	0	0
	CDH74	5415	0	0	3	59	295	1106	1781	1586	520	65	0	0
	CDH80	2016	0	0	0	5	59	407	731	662	146	6	0	0
(14) Wind	WSAvg	5.1	5.5	5.9	6.1	5.8	4.9	4.5	4.2	4.1	4.3	5.2	5.3	5.4
(15) Precipitation	PrecAvg	34.2	3.0	2.4	2.4	3.3	3.2	2.9	2.3	2.6	3.0	2.9	3.3	2.9
	PrecMax	44.2	7.0	5.0	5.9	7.9	5.6	6.8	6.7	5.8	7.0	6.4	7.3	6.6
	PrecMin	25.6	0.4	0.2	0.2	0.1	1.0	0.7	0.6	0.4	0.9	0.9	0.9	0.7
	PrecStd	5.1	1.7	1.4	1.4	2.0	1.3	1.7	1.3	1.4	1.7	1.3	1.5	1.5
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	59.4	66.2	73.5	80.0	85.5	95.5	97.1	97.0	88.9	79.9	68.3	61.0
		MCWB	51.3	50.8	55.1	60.4	65.6	70.9	69.5	69.8	66.0	64.4	58.1	53.3
	2%	DB	55.9	60.3	68.2	74.9	81.1	88.5	91.6	91.8	84.3	75.3	63.6	57.5
		MCWB	50.2	50.3	53.2	58.0	63.9	68.6	69.7	69.5	65.3	62.8	56.1	51.8
	5%	DB	53.6	56.5	64.4	70.7	77.1	84.5	87.5	87.3	80.2	71.7	60.5	55.0
		MCWB	49.7	48.6	51.8	55.6	62.1	67.5	68.6	68.4	64.6	61.5	54.6	50.7
	10%	DB	51.3	53.1	60.3	66.0	72.8	80.8	83.7	83.0	75.8	68.3	57.6	52.7
		MCWB	48.1	47.6	49.7	53.6	60.3	66.0	67.4	67.2	62.8	60.2	53.5	49.5
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	53.8	53.8	56.9	61.7	68.7	74.3	73.8	73.7	70.5	66.5	59.7	54.8
		MCDB	56.1	61.7	68.2	76.6	81.2	87.5	87.6	87.6	82.5	75.7	65.2	58.0
	2%	WB	52.0	51.7	54.7	59.2	65.7	71.1	71.7	71.8	67.8	64.5	57.5	53.0
		MCDB	54.7	57.3	64.6	72.6	78.2	84.7	86.3	86.3	79.6	71.9	61.7	55.9
	5%	WB	50.1	50.1	53.0	56.9	63.4	68.9	70.1	70.1	65.7	62.7	55.6	51.6
		MCDB	52.8	54.3	61.4	67.1	73.9	81.6	83.9	83.2	75.7	69.7	59.3	54.7
	10%	WB	48.3	48.5	51.2	54.8	61.2	66.9	68.4	68.3	63.9	61.1	53.9	49.9
		MCDB	50.7	52.5	58.3	63.7	70.5	78.2	81.2	80.0	73.2	67.0	57.2	52.4
(35) Mean Daily Temperature Range	MDBR		12.0	15.3	18.3	19.4	20.2	21.5	22.6	22.7	21.5	17.5	13.1	12.0
	5% DB	MCDBR	14.4	20.2	25.8	27.4	26.6	27.6	29.3	29.5	27.2	20.8	15.9	13.1
		MCWBR	9.6	12.0	13.6	13.6	13.3	12.3	11.5	11.4	11.9	10.7	9.9	8.7
	5% WB	MCDBR	11.2	16.4	21.2	23.6	23.7	24.9	25.2	25.0	22.3	17.7	13.2	11.1
		MCWBR	8.2	10.7	11.9	12.3	12.8	11.8	11.0	10.6	10.8	9.7	9.0	8.2
(40) Clear-Sky Solar Irradiance	taub		0.308	0.322	0.354	0.386	0.391	0.402	0.394	0.393	0.363	0.354	0.327	0.306
	taud		2.502	2.453	2.378	2.286	2.322	2.325	2.342	2.359	2.421	2.460	2.489	2.503
	Ebn at Noon		259	275	279	278	279	275	276	272	272	259	248	247
	Edh at Noon		22	27	33	40	39	40	38	36	32	27	22	20
(44) All-Sky Solar Radiation	RadAvg		423	720	1086	1443	1693	1964	1936	1707	1359	875	493	388
	RadStd		52	87	125	182	138	167	144	115	89	72	60	57

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (23 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page