

WMO: 075490

WBAN: 99999

(1)	1	-8.4	-6.1	-12.2	1.4	-4.6	-9.7	1.8	-3.0	10.8	7.3	9.4	7.1	1.7	100	0.534	(1)
-----	---	------	------	-------	-----	------	------	-----	------	------	-----	-----	-----	-----	-----	-------	-----

(2)	7	11.7	30.5	19.0	28.5	18.6	26.7	17.9	20.4	27.2	19.5	26.2	18.7	25.1	3.3	150	(2)
-----	---	------	------	------	------	------	------	------	------	------	------	------	------	------	-----	-----	-----

(3)	18.1	14.0	23.2	17.1	13.2	22.3	16.3	12.5	21.3	61.3	27.3	58.2	26.2	55.4	25.3	25.6	(3)
-----	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	-----

(4)	9.3	7.7	6.6	DB	-11.4	33.1	3.2	1.8	-13.7	34.4	-15.6	35.5	-17.4	36.5	-19.7	37.8	(4)
(5)				WB	-11.8	22.4	3.1	1.0	-14.0	23.1	-15.8	23.7	-17.6	24.3	-19.8	25.0	(5)

(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	10.3	2.9	3.4	6.6	9.0	12.6	16.3	18.3	18.0	14.4	11.6	6.3	3.8	(6)
(7)		DBStd	6.62	3.78	4.23	3.57	3.47	3.61	3.97	3.51	3.60	3.38	3.78	3.92	3.99	(7)
(8)		HDD10.0	943	219	186	115	59	16	1	0	0	4	29	122	193	(8)
(9)		HDD18.3	3048	477	418	364	279	181	85	45	52	124	210	362	451	(9)
(10)		CDD10.0	1056	0	1	9	30	96	191	258	247	137	77	9	1	(10)
(11)		CDD18.3	119	0	0	0	0	3	25	44	41	7	1	0	0	(11)
(12)		CDH23.3	1439	0	0	0	4	43	299	519	483	88	3	0	0	(12)
(13)		CDH26.7	408	0	0	0	0	2	77	151	165	13	0	0	0	(13)
(14)	Wind	WSAvg	2.9	3.0	3.1	3.3	3.4	3.1	2.8	2.7	2.5	2.5	2.9	2.9	2.9	(14)
(15)	Precipitation	PrecAvg	1292	111	103	89	126	117	89	81	90	112	118	142	117	(15)
(16)		PrecMax	1636	264	225	259	287	209	202	166	165	246	241	320	301	(16)
(17)		PrecMin	1001	18	4	3	16	34	28	33	17	33	34	35	18	(17)
(18)		PrecStd	161	62	64	60	70	51	48	37	37	51	51	67	65	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.2	17.6	20.7	23.5	26.7	32.0	32.7	34.0	28.4	23.5	17.9	13.9	(19)
(20)			MCWB	7.9	8.7	10.9	13.7	16.9	19.0	18.4	18.7	17.4	15.4	12.1	9.2	(20)
(21)		2%	DB	11.1	14.0	17.9	20.8	24.5	28.7	30.1	30.6	25.8	21.1	15.5	12.1	(21)
(22)			MCWB	8.2	7.9	9.9	12.6	15.7	18.8	18.9	19.0	16.7	15.1	11.7	8.7	(22)
(23)		5%	DB	9.7	11.2	15.7	18.5	22.3	26.6	28.2	28.4	23.7	19.4	13.9	10.8	(23)
(24)			MCWB	7.5	7.1	9.1	11.2	14.6	17.8	18.6	18.5	16.1	14.4	10.8	8.3	(24)
(25)		10%	DB	8.3	9.2	13.2	16.3	20.1	24.7	26.4	26.1	21.6	17.8	12.4	9.5	(25)
(26)			MCWB	6.5	6.5	7.8	10.2	13.5	17.1	18.0	18.1	15.4	13.9	10.0	7.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.0	10.1	12.1	14.6	18.1	21.2	21.6	21.4	19.4	17.2	13.5	10.7	(27)
(28)			MCDB	11.3	14.7	17.4	21.5	25.1	28.4	27.8	28.0	25.2	20.9	16.4	12.4	(28)
(29)		2%	WB	8.9	8.8	10.7	13.2	16.6	19.7	20.3	20.2	18.1	16.1	12.3	9.7	(29)
(30)			MCDB	10.3	12.2	16.0	19.7	22.7	26.4	27.1	27.2	23.4	19.3	14.8	11.0	(30)
(31)		5%	WB	7.8	7.8	9.7	11.8	15.4	18.7	19.4	19.3	17.0	15.1	11.2	8.9	(31)
(32)			MCDB	9.3	10.0	14.1	17.2	21.1	25.3	26.1	26.1	22.3	18.2	13.2	10.4	(32)
(33)		10%	WB	6.8	6.8	8.7	10.7	14.2	17.6	18.5	18.4	15.9	14.2	10.2	7.7	(33)
(34)			MCDB	8.1	9.0	12.4	15.2	18.8	23.6	25.0	25.0	20.3	17.3	12.0	9.1	(34)
(35)	Mean Daily Temperature Range		MDBR	7.0	8.3	9.9	10.2	10.5	11.6	11.7	11.9	11.1	9.4	7.7	7.3	(35)
(36)		5% DB	MCDBR	8.9	12.7	15.2	14.8	14.4</								

[illegible]

Nomenclature: See separate page