

RODEZ-AVEYRON AP, France

WMO: 075520

Lat: 44.4103N

Lon: 2.4825E

Elev: 1910

StdP: 13.71

Time Zone: 1.00 (EUC)

Period: 99-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 18.2	(c) 22.0	(d) 10.9	(e) 10.3	(f) 23.4	(g) 15.5	(h) 12.9	(i) 26.4	(j) 27.4	(k) 44.3	(l) 24.6	(m) 45.0	(n) 4.8	(o) 330	(p) 0.556

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	22.1	89.3	66.5	85.5	65.6	82.1	64.8	69.1	82.4	67.6	80.5	66.2	78.5	9.2	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.8	98.6	74.1	63.4	93.7	72.6	61.9	88.9	71.0	34.4	82.3	33.0	80.5	31.9	78.7	77.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 25.4	(b) 21.9	(c) 19.0	(e) 12.8	(f) 94.8	(g) 5.8	(h) 3.4	(i) 8.6	(j) 97.2	(k) 5.2	(l) 99.2	(m) 2.0	(n) 101.1	(o) -2.2	(p) 103.6		
			DB													
			WB													
				11.8	72.7	5.4	1.9	8.0	74.1	4.8	75.2	1.8	76.3	-2.1	77.7	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	51.6	37.4	38.2	44.3	49.3	55.3	63.0	66.7	66.0	60.2	54.1	44.1	39.2
	DBStd	12.41	6.82	7.45	6.33	5.82	6.43	7.11	6.37	6.63	6.09	6.87	7.21	7.05
	HDD50	1603	392	331	193	82	21	1	0	0	3	41	201	338
	HDD65	5205	856	750	641	470	305	122	58	68	167	341	626	801
	CDD50	2178	1	1	17	63	187	391	517	497	310	167	25	2
	CDD65	303	0	0	0	0	6	61	110	100	24	2	0	0
	CDH74	3601	0	0	0	8	97	737	1284	1192	271	12	0	0
	CDH80	1180	0	0	0	0	7	227	445	456	45	0	0	0
(14) Wind	WSAvg	8.2	8.3	8.9	9.5	9.4	8.5	7.5	7.6	6.8	6.7	8.2	8.5	8.3
(15) Precipitation	PrecAvg	35.3	2.9	2.6	2.5	3.6	3.6	2.8	2.2	2.5	2.9	3.1	3.5	3.1
	PrecMax	46.1	6.7	5.4	5.5	7.3	6.3	8.2	4.6	5.5	6.7	7.5	6.4	6.9
	PrecMin	28.0	0.2	0.2	0.3	0.4	1.3	0.9	0.6	0.7	0.7	1.3	0.8	0.6
	PrecStd	4.9	1.6	1.5	1.4	2.0	1.5	1.5	1.1	1.2	1.5	1.3	1.6	1.5
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	56.6	63.1	69.5	74.9	80.8	91.7	93.0	95.2	84.5	75.8	64.8	57.6
		MCWB	48.8	48.1	51.9	57.6	63.0	67.2	66.6	66.4	64.8	61.4	55.7	49.8
	2%	DB	52.2	56.6	64.1	69.8	76.8	85.9	88.7	89.6	80.7	71.3	60.7	54.4
		MCWB	48.0	47.0	50.2	55.2	61.3	66.1	66.3	66.3	62.7	60.3	53.8	48.7
	5%	DB	49.8	52.2	59.6	65.8	72.8	81.8	85.1	85.4	77.2	68.0	57.8	52.0
		MCWB	46.7	45.3	48.4	53.0	59.5	64.6	65.6	65.6	61.9	59.3	52.5	47.7
	10%	DB	47.4	48.8	55.5	61.7	68.5	78.1	81.5	81.1	73.4	65.1	55.2	49.5
		MCWB	44.7	44.3	46.7	51.5	57.1	63.6	64.7	64.7	61.0	58.0	51.4	46.4
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	51.1	50.7	54.4	59.1	65.3	70.8	70.8	71.2	68.2	63.8	57.1	52.1
		MCDB	53.4	58.3	63.3	71.5	77.6	83.9	84.6	85.4	79.5	71.9	62.4	55.2
	2%	WB	49.2	48.3	51.8	56.3	62.6	68.1	68.9	68.9	65.6	61.8	55.1	50.2
		MCDB	51.4	53.6	59.8	67.1	73.8	81.4	82.4	82.1	75.6	68.2	59.2	52.8
	5%	WB	47.1	46.6	50.0	54.2	60.5	66.3	67.4	67.2	63.7	60.2	53.2	48.6
		MCDB	49.3	50.7	57.2	63.6	70.4	79.1	80.6	79.9	73.4	66.0	56.7	51.2
	10%	WB	45.1	44.9	48.3	52.2	58.3	64.6	65.8	65.6	62.0	58.7	51.5	46.6
		MCDB	47.0	48.5	54.0	60.1	66.6	75.6	78.3	77.9	70.4	64.1	54.7	48.8
(35) Mean Daily Temperature Range	5% DB	MDBR	12.7	15.2	17.3	18.1	19.2	21.1	22.1	22.3	20.5	16.7	13.4	13.5
		MCDBR	16.7	22.6	27.0	26.2	26.3	27.9	29.0	29.0	26.6	21.4	17.7	18.8
		MCWBR	12.0	14.4	15.4	14.4	14.0	13.0	11.5	11.4	12.4	12.1	11.7	13.2
	5% WB	MCDBR	13.2	18.0	21.1	23.3	22.9	25.4	24.6	24.7	21.6	16.3	14.4	13.4
		MCWBR	10.4	12.7	13.0	13.6	13.3	13.0	11.3	12.0	11.5	9.8	10.2	10.2
(40) Clear-Sky Solar Irradiance	taub		0.289	0.305	0.339	0.370	0.377	0.383	0.377	0.376	0.349	0.339	0.310	0.288
	taud		2.511	2.470	2.394	2.305	2.333	2.346	2.360	2.374	2.431	2.470	2.503	2.516
	Ebn at Noon		268	283	285	283	283	281	281	278	277	265	256	257
	Edh at Noon		21	27	33	39	39	39	38	36	31	26	22	19
(44) All-Sky Solar Radiation	RadAvg		455	741	1100	1449	1696	2011	1994	1747	1374	885	512	408
	RadStd		56	100	116	193	161	165	159	122	95	81	64	63

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (29 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page