

RODEZ-AVEYRON AP, France

WMO: 075520

Lat: 44.4103N

Lon: 2.4825E

Elev: 582

StdP: 94.52

Time Zone: 1.00 (EUC)

Period: 99-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-7.7	-5.6	-11.7	1.5	-4.8	-9.2	1.8	-3.1	12.2	6.8	11.0	7.2	2.1	330	0.556

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.3	31.8	19.2	29.7	18.7	27.8	18.2	20.6	28.0	19.8	26.9	19.0	25.8	4.1	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.2	14.1	23.4	17.4	13.4	22.5	16.6	12.7	21.7	62.1	28.0	59.0	26.9	56.2	25.9	25.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11.4	9.8	8.5	-10.7	34.9	3.2	1.9	-13.0	36.2	-14.9	37.3	-16.7	38.4	-19.0	39.8
			-11.2	22.6	3.0	1.1	-13.3	23.4	-15.1	24.0	-16.8	24.6	-18.9	25.4
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	10.9	3.0	3.4	6.8	9.6	13.0	17.2	19.3	18.9	15.7	12.3	6.7	4.0
	DBStd	6.89	3.79	4.14	3.52	3.23	3.57	3.95	3.54	3.68	3.38	3.82	4.00	3.92
	HDD10.0	891	218	184	107	46	12	1	0	0	2	23	112	188
	HDD18.3	2892	476	417	356	261	169	68	32	38	93	189	348	445
	CDD10.0	1210	1	1	9	35	104	217	287	276	172	93	14	1
	CDD18.3	168	0	0	0	0	3	34	61	56	13	1	0	0
	CDH23.3	2001	0	0	0	4	54	409	713	662	151	7	0	0
CDH26.7	656	0	0	0	0	4	126	247	253	25	0	0	0	
Wind	WSAvg	3.7	3.7	4.0	4.3	4.2	3.8	3.4	3.4	3.1	3.0	3.7	3.8	3.7
Precipitation	PrecAvg	896	74	65	63	92	91	70	55	64	73	80	89	78
	PrecMax	1172	170	136	139	186	159	209	117	139	170	190	162	174
	PrecMin	711	6	6	8	11	32	24	15	18	19	34	20	15
	PrecStd	125	40	39	35	51	39	39	28	30	37	33	40	39
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.7	17.3	20.8	23.9	27.1	33.2	33.9	35.1	29.2	24.3	18.2	14.2
		MCWB	9.3	9.0	11.1	14.2	17.2	19.5	19.2	19.1	18.2	16.4	13.2	9.9
	2%	DB	11.2	13.7	17.8	21.0	24.9	29.9	31.5	32.0	27.1	21.8	15.9	12.5
		MCWB	8.9	8.3	10.1	12.9	16.3	18.9	19.1	19.1	17.0	15.7	12.1	9.3
	5%	DB	9.9	11.2	15.3	18.8	22.7	27.6	29.5	29.7	25.1	20.0	14.3	11.1
		MCWB	8.2	7.4	9.1	11.7	15.3	18.1	18.6	18.6	16.6	15.2	11.4	8.7
	10%	DB	8.5	9.3	13.0	16.5	20.3	25.6	27.5	27.3	23.0	18.4	12.9	9.7
		MCWB	7.1	6.8	8.2	10.8	13.9	17.5	18.2	18.2	16.1	14.4	10.8	8.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.6	10.4	12.5	15.0	18.5	21.6	21.6	21.8	20.1	17.7	13.9	11.2
		MCDB	11.9	14.6	17.4	21.9	25.3	28.8	29.2	29.7	26.4	22.1	16.9	12.9
	2%	WB	9.5	9.1	11.0	13.5	17.0	20.1	20.5	20.5	18.7	16.6	12.8	10.1
		MCDB	10.8	12.0	15.4	19.5	23.2	27.4	28.0	27.9	24.2	20.1	15.1	11.6
	5%	WB	8.4	8.1	10.0	12.3	15.8	19.1	19.7	19.6	17.6	15.7	11.8	9.2
		MCDB	9.6	10.4	14.0	17.5	21.4	26.1	27.0	26.6	23.0	18.9	13.7	10.7
	10%	WB	7.3	7.2	9.1	11.2	14.6	18.1	18.8	18.7	16.6	14.8	10.8	8.1
		MCDB	8.3	9.2	12.2	15.6	19.2	24.2	25.7	25.5	21.3	17.8	12.6	9.4
Mean Daily Temperature Range	5% DB	MDBR	7.0	8.5	9.6	10.0	10.7	11.7	12.3	12.4	11.4	9.3	7.4	7.5
		MCDBR	9.3	12.6	15.0	14.6	14.6	15.5	16.1	16.1	14.8	11.9	9.8	10.4
		MCWBR	6.7	8.0	8.6	8.0	7.8	7.2	6.4	6.3	6.9	6.7	6.5	7.3
	5% WB	MCDBR	7.4	10.0	11.7	12.9	12.7	14.1	13.7	13.7	12.0	9.0	8.0	7.5
		MCWBR	5.8	7.1	7.2	7.6	7.4	7.2	6.3	6.7	6.4	5.5	5.7	5.7
Clear-Sky Solar Irradiance	taub	0.289	0.305	0.339	0.370	0.377	0.383	0.377	0.376	0.349	0.339	0.310	0.288	
	taud	2.511	2.470	2.394	2.305	2.333	2.346	2.360	2.374	2.431	2.470	2.503	2.516	
	Ebn at Noon	845	891	897	891	893	886	886	876	874	836	808	810	
	Edh at Noon	67	84	103	123	123	122	119	113	99	83	68	61	
All-Sky Solar Radiation	RadAvg	1.43	2.33	3.47	4.57	5.35	6.34	6.29	5.51	4.33	2.79	1.61	1.29	
	RadStd	0.18	0.32	0.36	0.61	0.51	0.52	0.50	0.39	0.30	0.26	0.20	0.20	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (29 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page