

MONT AIGOUAL, France

WMO: 075600

Lat: 44.1214N

Lon: 3.5814E

Elev: 5135

StdP: 12.17

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	11.0	14.7	-10.9	3.7	35.5	-3.7	5.4	34.7	66.7	21.5	62.6	19.5	37.0	0	1.035

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	11.6	72.5	58.4	69.9	57.3	67.4	56.2	61.2	67.9	59.6	66.1	58.2	64.7	10.9	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
58.9	90.2	63.6	57.2	84.7	62.3	55.6	79.6	60.9	29.8	67.8	28.6	66.4	27.5	64.8	66.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 56.6	51.3	46.8	DB	8.8	76.0	4.8	2.8	5.3	78.0	2.5	79.6	-0.2	81.2	-3.7	83.2	(4)
(5)			WB	7.8	64.0	4.6	1.6	4.6	65.2	1.9	66.2	-0.7	67.1	-4.0	68.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	42.2	29.7	29.4	33.9	37.9	45.1	52.9	57.0	57.1	50.1	44.6	35.6	32.2	(6)
(7)		DBStd	12.29	7.10	8.41	7.54	7.17	7.12	7.44	6.73	6.97	6.72	6.76	7.65	7.62	(7)
(8)		HDD50	3601	628	577	499	368	186	55	19	16	80	188	433	552	(8)
(9)		HDD65	8344	1093	997	963	812	617	367	258	261	447	632	881	1016	(9)
(10)		CDD50	759	0	0	1	6	34	141	235	235	83	21	2	1	(10)
(11)		CDD65	26	0	0	0	0	0	3	8	15	0	0	0	0	(11)
(12)		CDH74	39	0	0	0	0	0	4	8	27	0	0	0	0	(12)
(13)		CDH80	1	0	0	0	0	0	0	0	1	0	0	0	0	(13)
(14)	Wind	WSAvg	22.9	27.3	27.0	24.7	22.8	21.7	19.4	19.4	18.6	19.2	22.4	25.9	26.4	(14)
(15)	Precipitation	PrecAvg	52.2	4.4	3.2	3.2	4.4	4.1	2.6	1.9	2.3	6.0	7.8	7.2	5.0	(15)
(16)		PrecMax	92.8	28.2	8.8	12.7	11.3	10.4	9.1	6.0	5.2	15.0	15.3	19.0	14.2	(16)
(17)		PrecMin	34.0	0.0	0.0	0.0	0.6	0.6	0.5	0.2	0.7	0.1	1.3	1.0	0.3	(17)
(18)		PrecStd	12.7	5.3	2.7	3.5	3.0	2.6	1.7	1.2	1.3	4.1	3.2	5.2	4.2	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	51.9	52.5	55.0	59.4	65.5	74.2	75.1	77.5	69.2	62.6	56.1	54.7	(19)
(20)			MCWB	35.3	38.6	43.0	48.5	53.9	58.8	60.1	60.0	56.1	48.8	43.8	36.6	(20)
(21)		2%	DB	46.4	48.4	51.0	55.4	61.8	69.6	71.7	73.4	65.0	58.9	51.6	48.9	(21)
(22)			MCWB	34.7	36.4	39.5	45.4	52.1	58.5	58.4	58.2	54.2	47.6	41.2	35.4	(22)
(23)		5%	DB	41.7	44.4	47.6	52.0	58.5	66.6	69.3	70.4	62.4	55.7	48.3	44.5	(23)
(24)			MCWB	35.0	34.8	38.1	43.6	49.9	56.1	57.1	56.9	52.9	47.3	41.8	34.6	(24)
(25)		10%	DB	38.7	40.1	44.3	48.4	55.5	63.9	66.9	67.4	59.4	53.0	45.5	41.6	(25)
(26)			MCWB	34.6	33.8	37.1	41.5	47.8	54.6	56.3	55.9	51.4	48.3	42.3	36.3	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	41.7	42.2	45.4	50.2	56.8	62.9	63.4	62.9	59.6	54.3	48.8	43.1	(27)
(28)			MCDWB	43.8	47.5	50.6	57.1	63.4	70.2	70.7	70.3	65.1	56.0	50.4	44.5	(28)
(29)		2%	WB	39.5	39.1	42.3	46.8	53.7	60.1	61.0	60.9	56.8	52.6	46.5	41.3	(29)
(30)			MCDWB	41.0	43.8	47.5	53.1	59.8	66.5	67.8	67.6	61.3	53.9	48.0	42.4	(30)
(31)		5%	WB	37.5	37.3	40.3	44.7	51.2	57.9	59.4	59.4	55.2	51.3	44.9	39.7	(31)
(32)			MCDWB	38.9	40.5	44.8	50.1	56.6	64.0	66.3	65.8	59.1	52.7	46.3	40.8	(32)
(33)		10%	WB	36.0	35.6	38.5	42.7	49.2	56.1	57.9	58.0	53.5	49.9	43.2	38.0	(33)
(34)			MCDWB	37.5	38.4	42.1	46.9	53.9	62.2	64.7	64.6	57.6	51.6	44.4	39.4	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	7.5	8.2	9.0	9.4	10.2	11.3	12.2	11.6	9.9	8.1	7.4	7.8	(35)
(36)			MCDBR	10.9	12.0	12.6	13.4	13.2	13.1	14.1	13.8	12.2	11.2	10.3	10.6	(36)
(37)			MCWBR	7.2	8.1	8.9	9.3	10.0	10.2	9.9	9.4	9.4	9.0	8.0	6.3	(37)
(38)		5% WB	MCDWB	8.4	9.6	10.7	11.7	12.0	11.8	12.2	11.2	9.8	7.6	7.7	7.5	(38)
(39)			MCWBR	7.4	7.8	8.3	8.9	9.6	10.0	9.7	9.2	8.6	7.2	7.2	6.9	(39)
(40)		Clear-Sky Solar Irradiance	taub	0.254	0.267	0.295	0.320	0.326	0.327	0.324	0.322	0.307	0.301	0.274	0.253	(40)
(41)	taud		2.576	2.553	2.502	2.438	2.455	2.469	2.473	2.484	2.520	2.550	2.581	2.586	(41)	
(42)	Ebn at Noon		287	300	301	300	299	298	298	295	293	281	275	277	(42)	
(43)	Edh at Noon		20	24	30	34	35	34	34	32	29	24	20	18	(43)	
(44)	All-Sky Solar Radiation	RadAvg	493	786	1159	1500	1806	2122	2125	1832	1399	862	541	434	(44)	
(45)		RadStd	58	85	116	156	156	136	133	106	92	96	70	54	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	+1.78	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (33 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page