

AUBENAS AP, France

WMO: 075700

Lat: 44.5383N

Lon: 4.3672E

Elev: 280

StdP: 98.01

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-3.9	-2.4	-12.8	1.3	0.3	-10.2	1.6	0.3	11.8	3.6	10.4	4.1	2.9	10	0.478

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.6	34.2	20.2	32.5	19.6	30.9	19.1	21.5	30.6	20.7	29.4	20.0	28.3	3.6	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.0	14.3	23.1	18.1	13.5	23.0	17.3	12.8	22.4	63.5	30.6	60.8	29.5	58.4	28.4	25.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.3	8.9	7.8	-6.2	36.8	2.3	1.8	-7.8	38.1	-9.2	39.2	-10.5	40.2	-12.1	41.5		
(5)			-7.5	22.8	2.3	1.1	-9.1	23.6	-10.5	24.2	-11.8	24.8	-13.4	25.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	13.8	5.1	5.8	9.4	12.8	16.2	21.1	23.6	22.7	19.0	14.3	9.1	5.9
	DBStd	7.22	3.25	3.51	3.38	3.16	3.14	3.22	2.77	2.87	2.80	3.28	3.32	3.12
	HDD10.0	523	154	121	50	8	1	0	0	0	0	7	53	129
	HDD18.3	2106	410	351	276	167	79	9	1	2	24	127	276	384
	CDD10.0	1917	3	4	32	94	193	334	422	394	270	141	27	3
	CDD18.3	457	0	0	0	2	14	93	164	137	44	3	0	0
	CDH23.3	4670	0	0	1	38	166	992	1699	1351	399	24	0	0
	CDH26.7	1867	0	0	0	2	30	387	755	580	109	3	0	0
Wind	WSAvg	3.0	2.9	3.3	3.4	3.3	3.2	3.1	3.0	3.0	2.8	2.6	3.0	2.5
Precipitation	PrecAvg	1247	100	64	60	94	100	69	59	68	158	190	179	106
	PrecMax	2035	336	225	201	229	269	249	199	211	356	373	545	286
	PrecMin	728	3	0	2	13	12	18	7	21	31	15	14	4
	PrecStd	300	84	62	55	58	65	46	43	41	92	88	127	86
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	16.3	18.6	22.6	26.7	29.5	35.4	36.0	37.2	32.1	26.2	19.8	15.3
		MCWB	10.6	10.1	11.9	15.6	17.5	20.6	20.6	20.4	19.1	16.2	14.0	10.3
	2%	DB	13.8	15.5	20.1	24.2	27.2	32.7	34.1	34.2	29.6	23.1	17.1	13.3
		MCWB	8.7	9.1	11.2	14.2	16.8	19.9	20.2	19.9	18.1	16.0	12.5	9.6
	5%	DB	11.7	13.2	18.0	22.1	25.1	30.9	32.6	32.1	27.6	21.4	15.4	12.0
		MCWB	7.8	7.8	10.6	13.2	15.9	19.3	19.7	19.4	17.3	15.4	11.9	9.1
	10%	DB	10.2	11.3	16.0	19.8	23.1	29.0	31.0	30.0	25.5	19.9	14.2	10.8
		MCWB	7.1	7.1	9.5	12.2	15.0	18.6	19.3	18.8	16.6	14.9	11.4	8.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.2	11.1	13.1	16.0	19.1	22.5	22.4	22.0	20.7	18.6	15.1	12.2
		MCDB	14.8	16.7	19.9	24.9	26.7	32.0	31.3	30.4	27.9	21.3	17.3	13.6
	2%	WB	9.9	9.8	12.0	14.8	17.6	21.2	21.5	21.1	19.5	17.5	13.8	10.9
		MCDB	12.0	13.8	18.3	22.7	25.0	30.1	30.8	29.7	25.2	20.5	15.9	12.2
	5%	WB	8.8	8.8	11.1	13.7	16.6	20.1	20.7	20.4	18.7	16.6	12.9	10.0
		MCDB	10.9	12.0	16.4	20.4	23.4	28.9	29.8	28.7	24.6	19.8	14.5	11.3
	10%	WB	7.7	7.7	10.2	12.7	15.6	19.2	20.0	19.6	17.8	15.7	12.0	8.8
		MCDB	9.7	10.5	14.7	18.4	21.6	27.5	28.7	27.7	23.6	18.8	13.6	10.3
Mean Daily Temperature Range	5% DB	MDBR	7.7	8.7	10.3	10.7	11.0	12.3	12.6	12.5	11.1	9.1	7.8	7.6
		MCDBR	9.9	12.5	14.0	14.8	14.6	15.2	15.3	16.1	14.7	11.7	9.9	9.3
		MCWBR	6.4	7.2	7.2	6.8	6.4	5.7	5.1	5.3	5.7	5.9	6.0	6.3
	5% WB	MCDBR	8.0	10.6	12.3	13.7	13.1	14.4	14.0	14.0	11.8	9.3	7.5	6.9
		MCWBR	5.6	6.6	6.6	6.6	6.2	5.6	5.2	5.3	5.1	5.1	5.0	5.3
Clear-Sky Solar Irradiance	taub	0.308	0.328	0.364	0.390	0.398	0.398	0.393	0.390	0.374	0.371	0.334	0.306	
	taud	2.488	2.433	2.352	2.293	2.317	2.344	2.356	2.373	2.403	2.414	2.473	2.504	
	Ebn at Noon	816	860	868	871	873	872	872	862	847	795	774	781	
	Edh at Noon	69	87	108	124	125	122	120	114	102	89	71	63	
All-Sky Solar Radiation	RadAvg	1.52	2.44	3.69	4.78	5.73	6.74	6.71	5.77	4.42	2.72	1.67	1.32	
	RadStd	0.18	0.25	0.39	0.50	0.49	0.39	0.43	0.28	0.29	0.30	0.23	0.17	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (34 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page