

MONTELMAR-ANCONE AP, France

WMO: 075770

Lat: 44.5811N

Lon: 4.7331E

Elev: 243

StdP: 14.57

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	27.2	29.6	15.7	12.3	31.8	19.6	14.8	35.0	27.4	39.0	25.4	39.3	9.8	20	0.501

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.0	93.2	69.4	90.1	68.7	87.3	68.0	71.9	86.7	70.6	85.0	69.4	83.2	8.5	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
67.5	102.1	76.7	66.1	97.0	75.9	64.7	92.3	74.7	35.7	86.2	34.5	85.4	33.5	83.3	78.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.4	21.0	19.0	23.5	97.6	3.3	3.4	21.2	100.0	19.3	102.0	17.5	104.0	15.1	106.5
			21.9	74.3	3.4	1.5	19.5	75.4	17.5	76.3	15.5	77.2	13.0	78.3
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	57.6	41.8	43.8	50.3	55.4	62.6	70.3	74.8	73.9	66.3	59.1	48.9	42.9
	DBStd	12.92	5.82	6.10	5.66	5.55	5.30	5.71	5.01	5.09	5.25	5.76	6.40	6.19
	HDD50	852	257	184	66	14	0	0	0	0	0	6	94	231
	HDD65	3593	718	594	457	289	108	16	2	2	46	195	482	684
	CDD50	3626	4	10	74	177	391	610	768	742	488	288	62	12
	CDD65	893	0	0	0	2	34	177	306	279	84	11	0	0
	CDH74	8230	0	0	1	50	360	1666	2929	2554	627	43	0	0
	CDH80	3172	0	0	0	3	64	612	1247	1079	165	2	0	0
Wind	WSAvg	8.3	8.8	9.3	8.8	8.3	7.9	8.3	8.4	8.0	7.8	7.3	8.5	8.4
Precipitation	PrecAvg	36.6	2.6	2.9	3.0	2.4	3.5	2.4	1.4	2.8	5.0	4.5	3.8	2.9
	PrecMax	53.6	5.5	8.8	7.3	6.3	8.9	5.6	4.1	7.2	12.3	16.4	14.4	9.5
	PrecMin	24.8	0.2	0.1	0.0	0.2	0.6	0.2	0.0	0.1	0.0	0.3	0.1	0.4
	PrecStd	7.7	1.5	2.3	2.0	1.3	2.0	1.3	1.1	1.9	3.9	3.7	3.2	2.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	58.9	63.3	71.4	79.6	85.6	95.1	96.8	99.2	89.0	78.3	67.5	60.4
		MCWB	51.9	51.7	55.1	60.8	65.6	70.9	70.0	70.4	67.0	64.2	58.4	53.5
	2%	DB	55.5	59.7	67.5	74.4	81.4	90.0	93.2	93.2	84.8	74.4	64.0	57.3
		MCWB	49.6	50.1	54.0	58.5	63.6	69.1	69.4	69.4	66.2	63.3	57.1	52.2
	5%	DB	52.9	56.6	64.3	70.7	78.1	86.7	90.2	89.7	80.8	71.4	61.2	54.8
		MCWB	48.1	48.7	52.5	56.5	62.2	67.9	68.7	68.8	64.7	62.1	55.7	50.4
	10%	DB	50.5	53.4	61.1	67.1	74.6	83.2	87.2	86.2	77.4	68.5	58.5	52.5
		MCWB	46.7	47.3	50.9	54.8	60.7	66.4	68.0	68.1	63.9	61.0	54.1	48.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	52.7	53.1	57.3	61.8	67.8	73.7	73.6	73.6	70.4	66.8	60.5	55.0
		MCDB	57.2	60.1	67.6	76.3	81.7	89.8	89.1	87.5	80.6	72.9	64.8	58.3
	2%	WB	50.6	51.3	55.1	59.5	65.3	71.0	71.7	71.8	68.5	65.1	58.0	52.9
		MCDB	54.2	57.8	64.8	72.1	77.9	85.2	87.8	85.8	78.7	71.5	62.1	56.3
	5%	WB	48.9	49.7	53.6	57.6	63.5	69.2	70.4	70.5	67.0	63.5	56.4	51.1
		MCDB	52.1	55.2	62.0	68.1	75.0	83.0	85.7	84.5	77.1	69.7	60.4	54.2
	10%	WB	47.3	47.8	52.0	55.9	61.8	67.5	69.2	69.3	65.3	61.7	54.5	49.0
		MCDB	50.2	52.7	59.6	64.7	72.1	80.8	83.7	82.8	74.7	67.2	58.2	52.0
Mean Daily Temperature Range	5% DB	MDBR	10.8	13.6	17.2	18.1	18.9	19.9	21.0	20.8	18.1	14.8	11.5	10.1
		MCDBR	15.1	20.7	23.8	25.8	26.1	26.7	27.1	27.8	25.3	19.2	15.6	13.5
		MCWBR	10.6	12.7	12.7	12.3	11.6	9.8	8.6	8.8	10.1	9.9	10.0	9.4
	5% WB	MCDBR	13.5	18.0	20.8	22.5	22.5	24.4	24.3	24.2	20.4	16.5	13.8	11.3
MCWBR		9.9	11.6	11.6	11.5	10.7	9.8	8.7	8.7	9.0	9.0	9.4	8.4	
Clear-Sky Solar Irradiance	taub	0.317	0.337	0.374	0.396	0.404	0.404	0.398	0.395	0.382	0.381	0.342	0.314	
	taud	2.470	2.410	2.328	2.286	2.312	2.340	2.355	2.372	2.395	2.395	2.452	2.487	
	Ebn at Noon	255	269	272	274	275	275	275	272	266	248	241	244	
	Edh at Noon	23	28	35	40	40	39	38	36	33	29	23	20	
All-Sky Solar Radiation	RadAvg	489	781	1178	1525	1822	2145	2143	1844	1409	874	535	423	
	RadStd	55	83	122	154	154	120	135	87	95	93	73	53	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		+0.56	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (37 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page