

CHATEAU-ARNOUX-ST-AUBAN AP, France

WMO: 075880

Lat: 44.0622N

Lon: 5.9897E

Elev: 461

StdP: 95.91

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -4.4	(c) -3.0	(d) -13.1	(e) 1.3	(f) 1.2	(g) -11.0	(h) 1.5	(i) 1.6	(j) 12.9	(k) 7.0	(l) 11.6	(m) 6.1	(n) 3.0	(o) 30	(p) 0.522

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.6	33.4	19.0	32.0	18.7	30.5	18.4	20.6	29.7	19.8	29.0	19.2	28.1	4.8	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.7	13.4	23.1	16.9	12.7	22.3	16.1	12.1	22.1	61.1	29.5	58.4	29.0	56.3	28.2	24.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 10.8	(b) 9.2	(c) 7.9	(e) -6.7	(f) 35.7	(g) 1.9	(h) 1.9	(i) -8.0	(j) 37.1	(k) -9.1	(l) 38.2	(m) -10.2	(n) 39.3	(o) -11.6	(p) 40.7		
(4) 10.8	(5) 9.2	(6) 7.9	(7) -6.7	(8) 35.7	(9) 1.9	(10) 1.9	(11) -8.0	(12) 37.1	(13) -9.1	(14) 38.2	(15) -10.2	(16) 39.3	(17) -11.6	(18) 40.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	13.3	4.7	5.7	9.1	12.0	15.9	20.3	23.1	22.6	18.2	14.1	8.6	5.1	(6)
(7)		DBStd	7.13	3.04	3.14	3.12	2.97	2.97	3.18	2.49	2.50	2.80	2.97	3.30	3.03	(7)
(8)		HDD10.0	582	167	123	54	13	1	0	0	0	0	5	64	153	(8)
(9)		HDD18.3	2233	424	354	287	191	86	16	2	2	37	132	293	410	(9)
(10)		CDD10.0	1792	2	2	26	72	184	311	405	391	244	133	21	1	(10)
(11)		CDD18.3	402	0	0	0	1	10	76	149	134	31	2	0	0	(11)
(12)		CDH23.3	4273	0	0	1	16	148	853	1574	1343	313	26	0	0	(12)
(13)		CDH26.7	1659	0	0	0	1	24	311	688	565	69	2	0	0	(13)
(14)	Wind	WSAvg	3.4	3.5	3.6	3.6	3.5	3.5	3.7	3.5	3.2	2.8	3.2	3.2	(14)	
(15)	Precipitation	PrecAvg	746	54	60	64	60	77	62	39	63	62	76	69	61	(15)
(16)		PrecMax	1053	130	139	135	129	157	117	116	123	162	296	129	242	(16)
(17)		PrecMin	390	0	2	0	8	10	28	0	6	0	4	0	3	(17)
(18)		PrecStd	159	38	41	38	30	42	26	32	35	48	65	38	47	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	16.0	18.1	22.3	25.4	29.3	34.1	34.9	35.9	30.6	25.9	19.2	15.0	(19)
(20)			MCWB	9.4	9.3	11.3	14.6	17.4	19.8	19.1	19.2	18.3	15.9	12.6	10.0	(20)
(21)		2%	DB	13.6	15.4	19.8	22.8	26.7	32.0	33.4	33.4	28.7	23.6	17.2	12.9	(21)
(22)			MCWB	8.1	8.3	10.4	13.4	16.0	18.8	19.0	18.9	17.4	15.5	11.5	8.1	(22)
(23)		5%	DB	11.6	13.4	17.8	20.9	24.9	30.2	32.1	31.7	27.0	21.8	15.5	11.5	(23)
(24)			MCWB	6.9	7.3	9.9	12.2	15.4	18.3	18.7	18.7	16.7	14.8	10.7	7.5	(24)
(25)		10%	DB	9.8	11.5	15.9	19.0	23.1	28.2	30.7	29.9	25.0	20.1	13.8	10.0	(25)
(26)			MCWB	5.8	6.2	8.8	11.2	14.5	17.7	18.4	18.3	16.0	13.9	10.1	6.6	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.4	10.3	12.6	15.2	18.5	21.6	21.8	21.5	19.7	17.6	13.9	11.0	(27)
(28)			MCDWB	14.1	16.3	19.2	23.3	26.2	31.4	30.7	30.1	26.8	22.8	16.2	13.3	(28)
(29)		2%	WB	8.9	8.9	11.4	14.1	17.2	20.0	20.6	20.3	18.6	16.5	12.7	9.5	(29)
(30)			MCDWB	12.4	13.7	17.7	21.4	25.0	29.4	30.0	29.2	26.0	21.6	15.6	11.6	(30)
(31)		5%	WB	7.6	7.9	10.4	13.0	16.1	19.1	19.8	19.6	17.8	15.6	11.6	8.3	(31)
(32)			MCDWB	10.8	12.2	16.4	19.5	23.0	28.1	29.3	28.6	24.8	20.3	14.4	10.5	(32)
(33)		10%	WB	6.3	6.8	9.5	11.9	15.2	18.2	19.2	19.0	16.9	14.6	10.6	7.1	(33)
(34)			MCDWB	9.1	10.7	14.9	17.6	21.6	26.7	28.4	27.9	22.9	18.7	13.4	9.3	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	8.6	10.3	11.7	11.7	11.9	13.0	13.6	13.4	12.0	10.7	8.9	8.2	(35)
(36)			MCDBR	11.0	13.6	15.0	14.8	14.9	15.9	16.2	16.4	14.9	13.1	11.1	10.0	(36)
(37)			MCWBR	6.9	7.9	7.8	7.1	6.5	5.8	5.5	5.5	5.8	6.4	6.5	6.3	(37)
(38)		5% WB	MCDBR	9.7	12.3	13.4	13.8	13.5	14.7	14.7	14.6	13.2	11.5	9.2	8.3	(38)
(39)			MCWBR	6.6	7.7	7.4	7.0	6.3	5.9	5.5	5.5	5.6	6.1	5.9	5.8	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.283	0.303	0.338	0.378	0.390	0.392	0.382	0.375	0.365	0.345	0.311	0.282	(40)	
(41)		taud	2.513	2.472	2.418	2.319	2.331	2.354	2.380	2.400	2.418	2.482	2.519	2.530	(41)	
(42)		Ebn at Noon	858	896	900	885	882	878	883	878	859	832	812	824	(42)	
(43)		Edh at Noon	68	84	101	121	124	121	117	111	101	83	68	61	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.81	2.73	3.97	5.03	5.95	6.94	7.06	6.12	4.65	3.01	1.89	1.55	(44)	
(45)		RadStd	0.20	0.29	0.40	0.42	0.49	0.35	0.38	0.25	0.31	0.29	0.25	0.17	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.36	N/A	N/A	+1.03	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (35 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page