

POINTE DE SOCOA, France

WMO: **076000**Lat: **43.3944N**Lon: **1.6864W**Elev: **25**StdP: **101.03**Time Zone: **1.00 (EUC)**Period: **94-19**WBAN: **99999**

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-0.6	0.9	-5.0	2.5	3.5	-3.0	2.9	4.7	20.1	9.8	17.3	10.6	2.8	190	0.493

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.2	29.8	21.2	27.5	20.9	25.8	20.4	23.4	27.1	22.4	25.8	21.5	24.7	4.9	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
22.2	16.9	25.6	21.2	15.9	24.6	20.3	15.0	23.6	69.6	27.4	65.8	25.8	62.6	24.8	27.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
15.0	12.6	10.7	-2.8	36.0	1.9	2.4	-4.2	37.8	-5.4	39.2	-6.4	40.5	-7.9	42.3		
			-3.5	25.4	1.9	1.1	-4.9	26.2	-6.0	26.8	-7.1	27.4	-8.5	28.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	15.0	9.5	9.6	11.5	13.1	15.8	18.8	20.8	21.2	19.2	17.0	12.4	10.4
	DBStd	5.24	3.58	3.71	3.45	2.82	2.79	2.69	2.22	2.16	2.62	3.47	3.62	3.93
	HDD10.0	184	52	47	21	4	0	0	0	0	0	1	17	43
	HDD18.3	1523	274	246	212	161	90	24	3	2	19	67	179	246
	CDD10.0	1998	36	34	69	96	178	264	334	347	276	218	89	56
	CDD18.3	295	0	1	2	3	10	38	78	90	45	26	3	0
	CDH23.3	1246	0	1	4	22	77	188	287	359	202	102	3	0
	CDH26.7	293	0	0	0	4	19	69	68	81	41	11	0	0
Wind	WSAvg	4.4	4.9	4.9	4.8	4.6	4.5	4.1	4.0	3.8	3.8	4.1	4.8	5.0
Precipitation	PrecAvg	1722	175	152	135	158	132	99	86	94	126	156	234	175
	PrecMax	2305	441	352	305	346	325	216	212	265	246	439	391	289
	PrecMin	1286	13	35	33	63	52	24	25	31	45	21	52	9
	PrecStd	227	102	90	72	81	57	50	49	56	58	98	99	79
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	19.6	21.8	23.7	26.3	29.1	32.9	33.2	32.2	30.4	28.3	23.3	20.6
		MCWB	12.2	11.9	13.7	15.3	18.8	22.2	22.8	22.7	20.5	19.0	15.4	12.3
	2%	DB	17.6	18.8	21.3	22.3	25.2	28.3	27.9	28.7	27.5	25.9	21.4	18.7
		MCWB	11.9	11.3	13.1	14.2	17.6	20.3	22.6	22.5	20.1	17.9	14.6	12.1
	5%	DB	16.1	17.0	19.1	19.7	22.5	24.8	25.8	26.5	25.5	24.3	19.5	17.3
		MCWB	11.3	10.7	12.3	13.5	16.9	20.3	21.8	22.1	20.1	17.4	13.7	11.7
	10%	DB	14.6	15.1	17.2	17.8	20.5	22.9	24.6	25.0	23.9	22.7	17.8	15.9
		MCWB	10.6	10.5	11.7	13.4	16.5	19.2	20.9	21.2	19.6	16.8	13.2	11.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	13.9	13.9	15.1	17.1	20.7	23.7	24.6	24.9	23.0	20.5	17.0	14.4
		MCDB	16.8	17.8	21.0	21.7	26.3	29.2	28.5	28.4	26.9	24.6	20.2	16.8
	2%	WB	13.0	12.8	14.1	15.7	18.9	21.5	23.2	23.5	21.7	19.4	15.7	13.5
		MCDB	15.6	15.9	18.7	19.8	22.9	25.8	26.6	27.1	25.2	23.3	18.9	16.5
	5%	WB	12.2	12.0	13.3	14.7	17.8	20.5	22.2	22.5	20.8	18.5	14.8	12.7
		MCDB	14.6	14.7	17.4	18.2	21.3	24.0	25.4	25.8	24.2	22.4	18.1	15.7
	10%	WB	11.4	11.3	12.5	13.9	16.8	19.6	21.3	21.6	19.9	17.7	14.0	11.9
		MCDB	13.8	13.9	16.0	16.9	19.7	22.6	24.2	24.6	23.2	21.3	16.8	14.8
Mean Daily Temperature Range	5% DB	MDBR	6.4	7.0	7.4	7.3	7.2	6.9	6.7	7.2	8.0	7.8	6.7	6.6
		MCDBR	7.8	9.8	10.4	11.3	12.1	11.8	9.6	10.3	10.8	9.8	8.4	7.6
		MCWBR	4.5	5.1	5.2	5.7	6.1	6.0	5.3	5.6	5.7	4.5	4.3	4.3
	5% WB	MCDBR	6.5	7.9	9.0	9.3	10.1	9.7	8.8	9.2	9.4	8.6	7.0	6.4
		MCWBR	4.6	5.2	5.4	5.7	5.8	5.4	5.3	5.3	5.5	4.8	4.5	4.4
Clear-Sky Solar Irradiance	taub	0.331	0.347	0.381	0.406	0.416	0.428	0.418	0.417	0.394	0.372	0.347	0.327	
	taud	2.489	2.431	2.342	2.284	2.300	2.302	2.335	2.346	2.398	2.458	2.474	2.495	
	Ebn at Noon	799	846	855	859	859	847	851	839	832	806	770	768	
	Edh at Noon	72	90	111	126	128	128	123	118	104	87	73	66	
All-Sky Solar Radiation	RadAvg	1.41	2.27	3.50	4.52	5.36	5.94	5.92	5.28	4.27	2.77	1.66	1.32	
	RadStd	0.17	0.29	0.43	0.48	0.43	0.37	0.33	0.33	0.22	0.23	0.20	0.16	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)			
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (16 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page